UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 5

DATE: July 2, 2013

SUBJECT: Case Closeout for:
Isle Public School Bus Garage
585 Isle Street Wes
Isle, Minnesota 56342

FROM: Mark Restaino MLR 7/2/13
Underground Storage Tanks Section

THROUGH: Sherry Kamke, Section Chief SAK 7/2/13
Underground Storage Tanks Section

TO: UST Enforcement File

This memorandum is to inform the official enforcement file that the Isle Public School Bus Garage located at 585 Isle Street West in Isle, Minnesota case is closed.

On October 25, 2012, a Field Citation was issued as a result of violations found during a compliance inspection conducted by Scott Hansen at the Isle Public School Bus Garage which operates two (2) regulated petroleum USTs.

The violation was for failure to provide an adequate release detection method.

On November 11, 2012, Mr. Mark Bruske submitted the signed Notice of Violation/Settlement Agreement, and a copy of a check for payment of penalty which he had submitted to the Cincinnati Finance Center.