EPA ID ARD047602752

AFS #AR0610001 6
A1/A1/CO
158

RECEIVED
MAR - 1 2002
Air/Toxics & Inspecti
Coordination Branch
6EN-A

Weyerhaeuser

P.O. Box 38
Dierks, Arkansas 71833
Tel (870) 286 2193

02 VOL
from 304469
A752

February 26, 2002

VIA CER

Vol. 325156

Arkansas Department of Environmental Quality
Air Division Enforcement Branch
Post Office Box 8913
Little Rock, Arkansas 72219-8913

Re: Annual Compliance Certification for February 1, 2001 – January 31, 2002
Weyerhaeuser Dierks Mill – CSN 31-0016, Permit #0023-AOP-R1

Dear Sirs:

Enclosed is the annual compliance certification for Weyerhaeuser Company's Dierks Mill (the Mill) in Dierks, Arkansas, as required by 40 CFR 70.6(c)(5). This certification was prepared using forms and instructions developed and supplied by the Arkansas Department of Environmental Quality (ADEQ). Also enclosed are copies of upset condition and excess emission reports submitted by the Mill to ADEQ during the reporting period.

If you have any questions about the enclosed information, please contact Mr. Jim Alexander at (870) 286-4267.

Sincerely,

WEYERHAEUSER COMPANY

Jim Alexander

Jim Alexander
Environmental Coordinator

Attachment

cc: Mr. Jim Alexander, Weyerhaeuser
Mr. Mike Wood, Weyerhaeuser

Ms. Donna Ascenzi, EPA Region VI
Air Enforcement Section (6EN-AA)
1445 Ross Ave.
Dallas, Texas 75202-2733

Action 081 3/22/02 cb

ADEQ

ARKANSAS

Department of Environmental Quality

Air Division – Compliance Enforcement
8001 National Drive, PO Box 8913
Little Rock, Arkansas 72219-8913
Phone: (501) 682-0729
Fax: (501) 682-0059

UPSET CONDITION REPORT FORM

Instructions:

1. *Please make copies of this form to complete. Additional copies of this form may be obtained from the Air Division of the Department.*
2. *Fax the report to Rhonda Wilson at (501) 682-0059, email it to WilsonR@adeq.state.ar.us, or mail it to the above address by the end of the next business day of the upset.*

Facility Name: **Weyerhaeuser Company**

Location: **Dierks, Arkansas**

Permit Number: **0023-AOP-R1** CSN: **31-0016**

Equipment in Upset: **No. 7 Boiler – Opacity**

SN# (source number listed in permit): **45**

Date of Upset: **10/26/01** Duration: **84 Minutes**

Time of Upset (starting & ending): **03:54 - 04:54 08:48 - 09:12**

Pollutant(s) Involved in Upset (if known): **Opacity**

Emission Rate During Upset (if known): **70.9**

Violated Emission Limit: **20%** (limit listed in your permit)

Cause of Upset: **Shut Boiler Down for Routine Maintenance and Cleaning**

Corrective Actions Taken: **Problem Stopped After Wood Burned Out in Furnace**

Name of Person Completing Report: **Jimmy C. Alexander**

Phone: **870-286-4267** Fax: **870-286-4267** Email: **jim.alexander@weyerhaeuser.com**

form updated 8/00

ADEQ

ARKANSAS

Department of Environmental Quality

Air Division – Compliance Enforcement
8001 National Drive, PO Box 8913
Little Rock, Arkansas 72219-8913
Phone: (501) 682-0729
Fax: (501) 682-0059

UPSET CONDITION REPORT FORM

Instructions:

1. *Please make copies of this form to complete. Additional copies of this form may be obtained fro Air Division of the Department.*
2. *Fax the report to Rhonda Wilson at (501) 682-0059, email it to WilsonR@adeq.state.ar.us, or m to the above address by the end of the next business day of the upset.*

Facility Name: **Weyerhaeuser Company**

Location: **Dierks, Arkansas**

Permit Number: **0023-AOP-R1** CSN: **31-0016**

Equipment in Upset: **No. 7 Boiler – Opacity**

SN# (source number listed in permit): **45**

Date of Upset: **10-29-01** Duration: **12 HR. 12 MIN.**

Time of Upset (starting & ending): **1:00 PM 11-29-01 / 2:06AM 11-30-01**

Pollutant(s) Involved in Upset (if known): **OPACITY**

Emission Rate During Upset (if known): **80%**

Violated Emission Limit: **20%** (limit listed in your permit)

Cause of Upset: **Start -up Boiler after shut down for normal repairs**

Corrective Actions Taken:

Name of Person Completing Report: **James Cook**

Phone: **870-286-4362** Fax: _____ Email: **james.cook@weyerhaeuser.com**

form updated 8/00

ADEQ
ARKANSAS
Department of Environmental Quality

Air Division – Compliance Enforcement
8001 National Drive, PO Box 8913
Little Rock, Arkansas 72219-8913
Phone: (501) 682-0729
Fax: (501) 682-0059

UPSET CONDITION REPORT FORM

Instructions:

1. *Please make copies of this form to complete. Additional copies of this form may be obtained from the Air Division of the Department.*
2. *Fax the report to Rhonda Wilson at (501) 682-0059, email it to WilsonR@adeq.state.ar.us, or mail it to the above address by the end of the next business day of the upset.*

Facility Name: **Weyerhaeuser Company**

Location: **Dierks, Arkansas**

Permit Number: **0023-AOP-R1** CSN: **31-0016**

Equipment in Upset: **No. 7 Boiler – Opacity**

SN# (source number listed in permit): **45**

Date of Upset: **11-25-2001** Duration: **312 minutes**

Time of Upset (starting & ending): **08:42 - 13:48**

Pollutant(s) Involved in Upset (if known): **Opacity**

Emission Rate During Upset (if known): **80%**

Violated Emission Limit: **20%** (limit listed in your permit)

Cause of Upset: **Start up of boiler after being down for maintenance.**

Corrective Actions Taken: **Started precipitator when boiler heated up**

Name of Person Completing Report: **Jimmy Alexander**

Phone: **870-286-4267** Fax: **870-286-4241** Email: **jim.alexander@weyerhaeuser.com**

form updated 8/00