Ordered ISKS

Water Quality Noncompliance Notification - REVISED

X Unauthorized Discharge of Wastewater Reportable Effluent Violation Other

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

X Permitte Subscriber

TCEQ Region: 13 County: Bexar Permit Number 10137-008-Salado Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 5903 Sinclair Rd (FERG 233C5) Approximately 3500 gallons spilled into Creek Bed (Fish killed 65 1"-4" Perch / 1 Crawfish=66).

SR#: 1 ; INSPT#: 506120; WO#: ; Sewer Main 90929 90931

Cause of Noncompliance: Debris

Duration: Start 12/25/2017 15:00 (Date) (Time) End 12/25/2017 15:20 (Date) (Time)

Or expected to be Corrected _____ (Date)

Potential Dangers to Human Health and Safety or the Environment: Potential Fish Kill (65 1"-4" Perch / 1 Crawfish=66)

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

____	yes	X	no	Field Measurements
____	yes	X	no	Laboratory Samples
X	yes	____	no	Fish Kill, If yes, estimated number killed 66

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected,

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main,

Verification Information

Information Reported By Christopher A Luna (Name) / LC/TV III (Title)

Date Reported 12/25/2017 Signature [signature] (Revised), 12/26/17

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096 TCEQ Region 13 Fax: 545-4329

Received
JAN
GEN-W