Message

From: Brown, Jamesr [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=6F64739EE90E4087B2A77B32C4E4549F-BROWN, JAMESR]
Sent: 10/11/2018 1:10:50 PM
To: Taheri, Diane [Taheri.Diane@epa.gov]
CC: Garcia, David [Garcia.David@epa.gov]; Maguire, Charles [maguire.charles@epa.gov]
Subject: RE: Weekly Write Up for Jacksonville

Looks great! Just a couple slight edits.
Thanks.
Jim

Craft Turney Water Supply Corporation, Jacksonville, Texas
On October 3, Craft Turney notified TCEQ of a backflow incident impacting a small portion of the water system causing a fungicide to enter the water supply. A "do not use order" was issued for a limited number of customers but was later expanded as a precaution. Sampling results from October 5 and 6 are being evaluated. The EPA Lab in Houston is testing samples collected on October 10 for Methylene bis-thiocyanate (MBT) analysis. Flushing continues throughout the distribution system in the affected pressure plane. The Region continues to work closely with TCEQ on monitoring the resolution of this situation.

James R. Brown, P.G.
Associate Director
Safe Drinking Water Branch
Water Division
U.S. EPA Region 6
1445 Ross Avenue (Mail Code: 6WQ-S)
Dallas, Texas 75202-2733
Phone: (214) 665-3175

https://www.epa.gov/

From: Taheri, Diane
Sent: Thursday, October 11, 2018 8:07 AM
To: Brown, Jamesr <brown.jamesr@epa.gov>
Cc: Garcia, David <Garcia.David@epa.gov>; Maguire, Charles <maguire.charles@epa.gov>
Subject: Weekly Write Up for Jacksonville
Importance: High

Jim, please edit or approve and return to me asap. Thanks.

Craft Turney Water Supply Corporation, Jacksonville, Texas
On October 3, Craft Turney notified TCEQ of a backflow incident impacting a small portion of the water system causing a fungicide to enter the water supply. A "do not use

order" was issued for a limited number of customers but was later expanded as a precaution. Sampling results from October 5 and 6 are being evaluated. The EPA Lab in Houston is test samples collected on October 10 for Methylene bis-thiocyanate (MBT) analysis. Flushing continues throughout the distribution system in the affected plane. The region continues to work closely with TCEQ on monitoring the resolution of this situation.

Diane Taheri
Acting Director
Office of External Affairs
EPA Region 6
Direct: (214) 665-7460
Mobile: (214) 864-7241