Hi Macy,
As discussed, here is the list of missing historical SSO reports.

TX47058-OSO, 12/3/07, 3/4/08, 3/28/08, 4/15/08, 4/16/08, 4/22/08 (3), 4/23/08, 10/9/08(Eagle Drive), 10/9/08(Devon Drive), 1/4/09(Francesca), 2/16/09(Honeysuckle), 2/18/09(Hanley), 3/6/09(Parkway), 4/8/09 (Oso Pkwy), 4/17/09 (Rodd), 4/25/09 (Middle), 5/13/09 (Jordan), 5/26/09, 6/1/09, 7/1/09(Glazebrook), 11/2/09(S. Alameda), 12/4/09(Blanche), 1/12/10(Harrison), 1/13/10, 1/14/10(Juanita), 1/15/10 (Greenwood Water Recycling Plant, Wharton Street(2), Kokol Drive, Choctaw Drive, McBride Lane and Upriver Road, Pearse Drive, McBride Lane, Dixie),1/17/10(Shely Street), 1/18/10 (Maryland, Niagara, Clark, Ayers Street and Painter Drive), 1/19/10, 1/20/10(Weber, McArdle Rd),1/22/10 (Carrolleton), 1/27/10 (High Meadow), 3/4/10 (Oso), 3/7/10 (Lawnview), 4/23/10 (Lamont), 5/2/10 (Topeka), 5/5/10(Daly), 6/1/10 (2), 6/5/10(3), 6/20/10(Ashland),9/21/10(4), 9/24/20 (Lawnview), 1/20/11 (2), 1/23/11 (Lazy), 1/24/11(Hayward), 1/25/11(RioVista), 1/26/11(Sam),2/10/11(Airline), 3/25/11(Houston Street, Ohio Ave), 3/31/11 (2), 5/7/11(Edgebrook), 5/9/11, 5/29/11 (Lawnview), 6/4/11, 6/7/11(2), 6/8/11, 6/9/11, 7/27/11, 9/3/11(Cape Hatteras), 9/4/11 (Ocean Drive), 9/7/11 (Christie Street), 9/9/11-

TX47066-Broadway, 9/11/08 (Water St),9/16/08, 10/1/08(Twelfth),10/9/08 (Coleman Ave, S. Carancahua), 1/4/09 (SPID), 3/31/09 (Braniff), 6/4/09 (Up River Rd), 7/21/09(N

Capparral),8/17/09 (Mueller), 11/29/09 (Sixth Streeet), 3/2/10(Glendale), 3/9/10 (Tenth St), 4/25/10(Fairmont), 5/31/10 (2), 6/1/10(2),6/3/10, 6/3/10, 6/4/10(2), 9/21/10 (Cole), 10/12/10(Leopard), 1/17/11(N Nineteenth), 1/20/11, 2/13/11(2), 3/3/11(2), 5/23/11, 6/1/11, 6/4/11, 6/9/11, 8/8/11, 8/24/11(Baldwin), 8/24/11(Baldwin)-

TX0047074-Greenwood, 8/10/06, 10/15/06, 7/2/07, 9/5/07, 1/3/08(unknown), 10/14/08,10/25/08, 8/21/09, 10/19/09, 10/21/09, 10/22/09, 4/13/10(Deforrest), 4/25/10, 5/12/10, 5/31/10(2 on Cresthaven), 6/1/10, 6/4/10,7/23/10 (Louisiana), 7/24/10,9/10/10, 9/20/10(1H37), 9/24/10 (Triple Crown), 11/3/10(Bevecrest), 11/19/10, 11/27/10(S. Port), 2/8/11(Prescott), 3/3/11, 5/24/11, 5/26/11, 6/3/11, 6/4/11, 7/12/11, 7/14/11, 7/28/11, 8/8/11 (2), 9/4/2011 thru 10/13/2011-

TX0047082-3/8/06, 6/9/06, 9/18/06, 9/20/08,11/17/08, 2/23/09, 2/24/09, 2/26/09, 3/30/09, 7/6/09, 9/28/09(2), 1/15/10 (N. Clarkwood, McNorton),2/14/10, 4/28/10,6/3/10(2),9/21/10(2),11/15/10, 5/27/11, 7/10/11-

TX47104-Laguna, 4/26/10 (Selkirk), 6/3/10, 1/26/11, 1/27/11, 3/3/11,7/8/11, 7/11/11, 8/2/11,8/7/11, 8/9/11-

TX47121-Whitecap, 12/28/08 (Leeward), 12/31/09 (Primavera), 3/25/11, 3/26/11, 6/1/11, 8/10/11, 9/5/11(Dorsal)-

Thanking you in advance for all the assistance in preparing this case.

Judy
214/665/8582

omwD | 10401-006 | RP

City of Corpus Christi

WASTEWATER DEPARTMENT

PO Box 9277
Corpus Christi
Texas 78469-9277
Phone 361-826-1800
Fax 361-826-1715
www.cctexas.com

Date Emailed: April 30, 2010

Mr. Kelly Ruble
TCEQ Region 14
NRC Building, Suite 1200
6300 Ocean Drive, Unit #5839
Corpus Christi, TX 78412-5839

RECEIVED
MAY 03 2010
ENFORCEMENT DIVISION

SUBJECT: NONCOMPLIANCE NOTIFICATION: April 23, 2010
April 24, 2010
April 25, 2010
April 26, 2010
April 27, 2010
April 28, 2010
April 29, 2010

Dear Mr. Ruble:

The list of overflows for the time period of April 23, 24, 25, 26, 27, 28, 29, 2010, is included as an email attachment with this letter.

The location of the reported overflows will be added to the City's overflow tracking list/map. The frequency of the City's Preventative Maintenance Program for these areas will be evaluated in an effort to prevent the recurrence of future backups.

If you have any questions or require further information, please contact Charles Baish III, P.E., Wastewater Collection Superintendent at (361) 826-1807.

Sincerely,

Foster Crowell
Wastewater Director

xc:
TCEQ/WQCMT (MC224) Enforcement Division, PO Box 13087, Austin TX 78711-3087
Oscar R. Martinez, Assistant City Manager
Foster Crowell, Wastewater Director
Joe F. Trejo., P. E., R.P.L.S., Assistant Wastewater Director
Valerie Gray, P. E., Director of Storm Water and Street Operations
Peggy L. Sumner, CHMM, CFM, Director of Environmental Services
Cliff Beaber, Wastewater Treatment Superintendent
Charles Baish III, P. E., Wastewater Collection Superintendent
Gerald Garcia, Work Coordinator
Margaret Castaneda, Finance and Resource Mgmt. Superintendent
Administration File

TCEQ CENTRAL FILEROOM
JUN 15 2010

All-America City

WQ MWD/ REPORTS
1st: 10401 2nd: 006 Vol: 001 4/23/2010
BBC: 100042556
IBC: 100196045

City of Corpus Christi Noncompliance Notification for : April 23, 24, 25, 26 , 27, 28, 29 2010

Track #	Regulated Entity	Start Date	Start Time	End Date	End Time	Date of 24 hr notification	5-day notification date	Amount/Gallons	Cause	Corrective/Preventive Actions Taken	Location of Discharge		Media	Structure	Potential danger to the environment.	Serv Prem	Additional Information
	RN101610079 WQ0010401006 Allison	04/26/10	17:00	04/26/10	19:30	04/29/10		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	10601	Leopard Street	No	Cleanout	No	139640	
	RN101610186 WQ0010401005 Broadway	04/25/10	12:15	04/25/10	13:30	04/25/10		10	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	3518	Fairmont Drive	No	Manhole	No	40692	
	RN101610186 WQ0010401005 Broadway	04/29/10	12:00	04/29/10	12:50	04/29/10		15	Line Blockage (other than grease)	Disinfected	449	Pueblo Street	No	Cleanout	No	72900	Private Cleanout
	RN101610400 WQ0010401003 Greenwood	04/25/10	21:45	04/25/10	22:00	04/26/10		15	Line Blockage (other than grease)	Cleared, Disinfected	5406	Hitching Post Court	No	Manhole	No	118970	Phoned in to TCEQ, Sergio Gonzalez on 04/26/10 8:19 a.m.
	RN101610400 WQ0010401003 Greenwood	04/26/10	17:00	04/26/10	17:30	04/27/10		4	Line Blockage (other than grease)	Disinfected	1913	Lorlite Drive	No	Cleanout	No	101940	Private Cleanout
	RN101610400 WQ0010401003 Greenwood	04/27/10	19:45	04/27/10	20:45	04/28/10		15	Line Break	Cleared, Vacuumed, Disinfected	5410	Buggywhip Drive	No	Wastewater Line	No	118928	Overflow within trench
	RN101610400 WQ0010401003 Greenwood	04/29/10	8:15	04/29/10	9:05	04/29/10		20	Line Blockage (other than grease)	Cleared, Disinfected	4930	Old Brownsville Road	No	Cleanout	No	67152	Private Cleanout
	RN101610400 WQ0010401003 Greenwood	04/29/10	17:30	04/30/10	7:50	04/30/10		10	Line Blockage (other than grease)	Cleared, Disinfected	4060	South Port Avenue	No	Cleanout	No	36702	Private Cleanout
	RN101609915 WQ0010404008 Laguna Madre	04/26/10	8:31	04/26/10	9:30	04/26/10		15	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1101	Selkirk Drive	No	Manhole	No	180598	
	RN101609915 WQ0010404008 Laguna Madre	04/26/10	8:31	04/26/10	9:30	04/26/10		15	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1101	Ontario Drive	No	Manhole	No	186380	
	RN101610327 WQ0010401004 Oso	04/23/10	21:15	04/23/10	23:05	04/24/10		30	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	4100	Lamont Street	No	Manhole	No	105273906	
	RN101610327 WQ0010401004 Oso	04/26/10	8:00	04/26/10	9:20	04/26/10		100	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1249	Sandpiper Drive	No	Manhole	No	14974	
	RN101610327 WQ0010401004 Oso	04/26/10	9:00	04/26/10	11:00	04/27/10		10	Line Break	Cleared, Disinfected	5230	Cromwell Drive	No	Wastewater Line	No	56570	Overflow within the trench
	RN101610327 WQ0010401004 Oso	04/28/10	19:15	04/28/10	20:00	04/29/10		10	Line Blockage (other than grease)	Cleared, Disinfected	4629	Christie Street	No	Cleanout	No	87714	
	RN101610327 WQ0010401004 Oso	04/29/10	20:15			04/30/10		50	Line Break	Cleared, Disinfected	3813	Lamont Street	No	Wastewater Line	No	34696	Overflow within a cave-in, pending repairs

MWD | 10401-005 | RP

City of Corpus Christi

Date Emailed: June 24, 2010

Mr. Kelly Ruble
TCEQ Region 14
NRC Building, Suite 1200
6300 Ocean Drive, Unit #5839
Corpus Christi, TX 78412-5839

SUBJECT: NONCOMPLIANCE NOTIFICATION: June 18, 2010
June 19, 2010
June 20, 2010
June 21, 2010
June 22, 2010
June 23, 2010
June 24, 2010

WASTEWATER DEPARTMENT

PO Box 9277
Corpus Christi
Texas 78469-9277
Phone 361-826-1800
Fax 361-826-1715
www.cctexas.com

RECEIVED
JUL 05 2010
TCEQ
CENTRAL FILE ROOM

Dear Mr. Ruble:

The list of overflows for the time period of June 18, 19, 20, 21, 22, 23, 24, 2010 is included as an email attachment with this letter.

The location of the reported overflows will be added to the City's overflow tracking list/map. The frequency of the City's Preventative Maintenance Program for these areas will be evaluated in an effort to prevent the recurrence of future backups.

If you have any questions or require further information, please contact Charles Baish III, P.E., Wastewater Collection Superintendent at (361) 826-1807.

Sincerely,

Foster Crowell
Wastewater Director

xc:
TCEQ/WQCMT (MC224) Enforcement Division, PO Box 13087, Austin TX 78711-3087
Oscar R. Martinez, Assistant City Manager
Foster Crowell, Wastewater Director
Joe F. Trejo., P. E., R.P.L.S., Assistant Wastewater Director
Valerie Gray, P. E., Director of Storm Water and Street Operations
Peggy L. Sumner, CHMM, CFM, Director of Environmental Services
Cliff Beaber, Wastewater Treatment Superintendent
Charles Baish III, P. E., Wastewater Collection Superintendent
Gerald Garcia, Work Coordinator
Margaret Castaneda, Finance and Resource Mgmt. Superintendent
Administration File

All-America City

06-28-10 RCVD 1248

City of Corpus Christi Noncompliance Notification for :
June 18, 19, 20, 21, 22, 23, 24 2010

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
10	Track #	Regulated Entity	Start Date	Start Time	End Date	End Time	Date of 24 hr notification	5-day notification date	Amount/Gallons	Cause	Corrective/Preventive Actions Taken	Location of Discharge		No	Structure	Potential danger to the environment.	Serv Prem	Additional Information
11		RN101610186 WQ0010401005 Broadway	06/18/10	13:00	06/18/10	14:00	06/18/10		40	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1600	Hancock Street	No	Manhole	No	105288155	
12		RN101610186 WQ0010401005 Broadway	06/23/10	16:00	06/23/10	16:40	06/24/10		150	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1116	North Staples Street	No	Cleanout	No	111254	
13		RN101610186 WQ0010401005 Broadway	06/24/10	8:00	06/24/10	8:30	06/24/10		15	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1602	Morgan	No	Cleanout	No	27632	
14																		
15		RN101610400 WQ0010401003 Greenwood	06/18/10	16:00	06/18/10	16:50	06/18/10		200	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1141	Dona Drive	No	Manhole	No	1122834	
16		RN101610400 WQ0010401003 Greenwood	06/20/10	13:44	06/20/10	15:00	06/20/10		23	Line Blockage (other than grease)	Cleared, Disinfected	902	Airport Road	No	Manhole	No	350362	Private Manhole
17		RN101610400 WQ0010401003 Greenwood	06/24/10	8:05	06/24/10	11:20	06/24/10		30	Line Blockage (other than grease)	Cleared, Disinfected	1469	Miami Drive	No	Manhole	No	32590	
18																		
19		RN101609915 WQ0010404003 Laguna Madre	06/18/10	9:15	06/18/10	14:37	06/18/10		2	Line Break	Cleared, Disinfected	826	Redmond Street	No	Wastewater Line	No	179500	Overflow within trench
20																		
21		RN101610327 WQ0010401004 Oso	06/19/10	10:00	06/19/10	12:15	06/19/10		20	Line Blockage (other than grease)	Cleared, Disinfected	2601	Nemec Street	No	Cleanout	No	1172	Private Cleanout
22		RN101610327 WQ0010401004 Oso	06/20/10	12:30	06/20/10	14:00	06/20/10		7	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	901	Ashland Drive	No	Manhole	No	169648	
23		RN101610327 WQ0010401004 Oso	06/20/10	17:30	06/20/10	18:20	06/21/10		3	Line Blockage (other than grease)	Cleared, Disinfected	4936	Williams Drive	No	Cleanout	No	79344	
24		RN101610327 WQ0010401004 Oso	06/21/10	18:27	06/21/10	19:37	06/22/10		22	Line Blockage (other than grease)	Disinfected	4310	Acushnet Drive	No	Cleanout	No	46090	Private Cleanout

City of Corpus Christi Noncompliance Notification for :
June 18, 19, 20, 21, 22, 23, 24 2010

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
25		RN101610327 WQ0010401004 Oso	06/22/10	19:29	06/22/10	20:35	06/23/10		27	Line Blockage (other than grease)	Cleared, Disinfected	1402	El Paso Street	No	Manhole	No	108754	
26		RN101610327 WQ0010401004 Oso	06/23/10	9:40	06/23/10	15:30	06/23/10		3	Line Break	Cleared, Disinfected	913	Zarsky Drive	No	Wastewater Line	No	20498	Overflow within trench
27		RN101610327 WQ0010401004 Oso	06/23/10	14:30	06/23/10	16:00	06/24/10		5	Other	Cleared, Disinfected	4134	Crenshaw Drive	No	Wastewater Line	No	48586	Private cleanout, overflow inside excavated trench

mwd | 10401-006 | RP
100042556

City of Corpus Christi

Date Emailed: September 24, 2010

Mr. Kelly Ruble
TCEQ Region 14
NRC Building, Suite 1200
6300 Ocean Drive, Unit #5839
Corpus Christi, TX 78412-5839

RECEIVED
SEP 27 2010
ENFORCEMENT DIVISION

SUBJECT: NONCOMPLIANCE NOTIFICATION: September 17, 2010
September 18, 2010
September 19, 2010
September 20, 2010
September 21, 2010
September 22, 2010
September 23, 2010

WASTEWATER DEPARTMENT

PO Box 9277
Corpus Christi
Texas 78469-9277
Phone 361-826-1800
Fax 361-826-1715
www.cctexas.com

RECEIVED
OCT 13 2010
TCEQ
CENTRAL FILE ROOM

Dear Mr. Ruble:

The list of overflows for the time period of September 17, 18, 19, 20, 21, 22, 23, 2010 is included as an email attachment with this letter.

The location of the reported overflows will be added to the City's overflow tracking list/map. The frequency of the City's Preventative Maintenance Program for these areas will be evaluated in an effort to prevent the recurrence of future backups.

If you have any questions or require further information, please contact Charles Baish III, P.E., Wastewater Collection Superintendent at (361) 826-1807.

Sincerely,

Foster Crowell
Wastewater Director

xc:
TCEQ/WQCMT (MC224) Enforcement Division, PO Box 13087, Austin TX 78711-3087
Oscar R. Martinez, Assistant City Manager
Foster Crowell, Wastewater Director
Joe F. Trejo., P. E., R.P.L.S., Assistant Wastewater Director
Valerie Gray, P. E., Director of Storm Water and Street Operations
Peggy L. Sumner, CHMM, CFM, Director of Environmental Services
Cliff Beaber, Wastewater Treatment Superintendent
Charles Baish III, P. E., Wastewater Collection Superintendent
Gerald Garcia, Work Coordinator
Margaret Castaneda, Finance and Resource Mgmt. Superintendent
Administration File

All-America City

WQ MWD/ REPORTS
1st: 10401 2nd: 006 Vol: 001 9/17/2010
BBC: 100042556
IBC: 100268865

RECEIVED
SEP 27 2010
ENFORCEMENT DIVISION

City of Corpus Christi Noncompliance Notification for :
September 17, 18, 19, 20, 21, 22, 23, 2010

Track #	Regulated Entity	Start Date	Start Time	End Date	End Time	Date of 24 hr notification	5-day rec'd n date	Amount	Cause	Corrective/Preventive Actions Taken	Location of Discharge		Media	Structure	Potential danger to the environment.	Serv Prem	Additional Information
	RN101610079 WQ0010401006 Allison	09/20/10	12:40	09/20/10	22:30	09/20/10		15	Other	Disinfected	9009	Mc Norton Road	No	Manhole	No	125542	Rain water
	RN101610079 WQ0010401006 Allison	09/20/10	12:45	09/20/10	22:40	09/20/10		15	Other	Disinfected	8815	Mc Norton Road	No	Manhole	No	125434	Rain water
	RN101610079 WQ0010401006 Allison	09/21/10	19:50	09/21/10	21:10	09/22/10		75	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	10821	Eastwood Drive	No	Manhole	No	146772	
	RN101610079 WQ0010401006 Allison	09/21/10	22:30	09/22/10	2:00	09/22/10		150	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	3647	Starlite Lane	No	Manhole	No	475479129	
	RN101610186 WQ0010401005 Broadway	09/20/10	9:00	09/20/10	22:00	09/20/10		300	Other	Disinfected	400	Old Robstown Road	No	Manhole	No	1125304	Rain water, Heavy rain event
	RN101610186 WQ0010401005 Broadway	09/20/10	9:00	09/20/10	22:05	09/20/10		200	Other	Disinfected	462	Old Robstown Road	No	Manhole	No	1131000	Rain water, Heavy rain event
	RN101610186 WQ0010401005 Broadway	09/20/10	10:30	09/20/10	21:55	09/20/10		70	Other	Disinfected		Virginia Avenue/Navajo Street	No	Manhole	No	1125437	Rain water, Heavy rain event
	RN101610186 WQ0010401005 Broadway	09/20/10	10:40	09/20/10	21:45	09/20/10		200	Other	Disinfected		Virgina Avenue/Chippawa Street	No	Manhole	No	1135362	Rain water, Heavy rain event
	RN101610186 WQ0010401005 Broadway	09/20/10	14:20	09/20/10	22:15	09/20/10		100	Other	Disinfected	4506	Baldwin Boulevard	No	Manhole	No	90308	Rain water, Heavy rain event
	RN101610186 WQ0010401005 Broadway	09/19/10	17:30	09/19/10	18:30	09/20/10		5000	Other	Disinfected	1402	West Broadway	No	Other	No	No service prem	Rain water, Intermediate clarifier overflow
	RN101610186 WQ0010401005 Broadway	09/19/10	23:00	09/20/10	1:00	09/20/10		5000	Other	Disinfected	1402	West Broadway	No	Other	No	No service prem	Rain water, Intermediate clarifier overflow
	RN101610186 WQ0010401005 Broadway	09/21/10	9:55	09/21/10	13:30	09/21/10		10	Line Blockage (other than grease)	Cleared, Disinfected	449	Cole Street	No	Cleanout	No	166020	
	RN101610186 WQ0010401005 Broadway	09/22/10	9:00	09/22/10	11:00	09/22/10		40	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	302	Louisiana Avenue	No	Manhole	No	161568	
	RN101610186 WQ0010401005 Broadway	09/22/10	21:20	09/22/10	23:15	09/23/10		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	304	Spruce Street	No	Manhole	No	90026	
	RN101610186 WQ0010401005 Broadway	09/22/10	13:30	09/22/10	15:30	09/23/10		5000.	Other	Other (describe in additional info)	1402	West Broadway	No	Other	No	No service prem	Rain water, Intermediate clarifier overflow, Initial Notice should not have a checkmark in "If released to the water of the state"
	RN101610186 WQ0010401005 Broadway	09/22/10	22:00	09/23/10	6:00	09/23/10		3000	Other	Other (describe in additional info)	1402	West Broadway	No	Other	No	No service prem	Rain water, Intermediate clarifier overflow, Initial Notice should not have a checkmark in "If released to the water of the state"
	RN101610400 WQ0010401003 Greenwood	09/17/10	9:15	09/17/10	9:45	09/17/10		20	Line Blockage (other than grease)	Contained, Disinfected	1441	Maryland Drive	No	Cleanout	No	33168	Private Cleanout
	RN101610400 WQ0010401003 Greenwood	09/18/10	11:00	09/18/10	11:10	09/18/10		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	2613	Presa Street	No	Cleanout	No	103300	

City of Corpus Christi Noncompliance Notification for : September 17, 18, 19, 20, 21, 22, 23, 2010

Track #	Regulated Entity	Start Date	Start Time	End Date	End Time	Date of 24 hr notification	5-day notification date	Amount/Gallons	Cause	Corrective/Preventive Actions Taken	Location of Discharge		Media	Structure	Potential danger to the environment.	Serv Prem	Additional Information
	RN101610400 WQ0010401003 Greenwood	09/18/10	22:00	09/18/10	23:30	09/19/10		10000	Other	Disinfected	6541	Greenwood Drive	No	Other	Yes	No service prem	Rain water, Bar screen overflow
	RN101610400 WQ0010401003 Greenwood	09/19/10	14:00	09/21/10	9:45	09/20/10		100000	Other	Other (describe in additional info)	6541	Greenwood Drive	YES	Manhole	Yes	No service prem	Rain water, Press Release, Reached waters of the State, Phoned TCEQ, Reported address should have been Saratoga and La Volla Creek
	RN101610400 WQ0010401003 Greenwood	09/20/10	10:30	09/20/10	21:30	09/20/10		150	Other	Other (describe in additional info)	3126	Naples Street	No	Manhole	No	1125718	Rain water, Heavy rain event
	RN101610400 WQ0010401003 Greenwood	09/20/10	10:30	09/20/10	20:30	09/21/10		250	Line Break	Cleared, Vacuumed, Disinfected	5501	IH 37 Access Road	No	Force main	No	136504	
	RN101610400 WQ0010401003 Greenwood	09/20/10	10:30	09/20/10	21:20	09/20/10		150	Other	Disinfected		Naples Street/Blevins Street	No	Manhole	No	1130021	Rain water, Heavy rain event
	RN101610400 WQ0010401003 Greenwood	09/20/10	14:00	09/20/10	22:25	09/20/10		100	Other	Disinfected	2751	South Port Avenue	YES	Manhole	No	1131082	Rain water, Heavy rain event
	RN101610400 WQ0010401003 Greenwood	09/22/10	13:00	09/23/10	10:00	09/22/10		200	Other	Disinfected	4421	Castenon Street	No	Manhole	No	74222	Rain water
	RN101610400 WQ0010401003 Greenwood	09/22/10	13:20	09/22/10	17:00	09/22/10		500	Line Break	Disinfected	4102	Crosstown State Highway	No	Manhole	No	426862	Rain water
	RN101610400 WQ0010401003 Greenwood	09/22/10	13:45	09/23/10	10:30	09/22/10		200	Other	Disinfected	1205	Maryland Drive	No	Manhole	No	1123272	Rain water
	RN101610400 WQ0010401003 Greenwood	09/22/10	15:00			09/22/10		200	Other	Other (describe in additional info)		Port Avenue/Home Road	No	Other	No	15649961	Rain water, overflow onside excavation, line break in Stormwater line, cleared and contained
	RN101610400 WQ0010401003 Greenwood	09/22/10	15:30	09/23/10	10:30	09/23/10		400	Other	Disinfected	3249	Greenwood Drive	No	Manhole	No	41068	
	RN101610400 WQ0010401003 Greenwood	09/22/10	16:30	09/23/10	7:15	09/23/10		15000	Other	Other (describe in additional info)		Saratoga Boulevard/Greenwood Drive	No	Manhole	Yes	1130280	Rain water, Cleared
	RN101610400 WQ0010401003 Greenwood	09/23/10	19:00	09/23/10	22:30	09/24/10		30	Line Blockage (other than grease)	Cleared, Disinfected	4925	Pels Avenue	No	Manhole	No	109752	
	RN101609915 WQ0010404006 Laguna Madre	09/23/10	18:15	09/23/10	20:00	09/24/10		30	Other	Cleared, Vacuumed, Disinfected	2610	Debra Lane	No	Manhole	No	185476	Rainwater
	RN101610327 WQ0010401004 Oso	09/18/10	20:00	09/21/10	7:15	09/19/10		1000	Other	Disinfected	4902	Dodd Drive	No	Manhole	No	80162	Heavy Rain Event
	RN101610327 WQ0010401004 Oso	09/18/10	20:30	09/23/10	10:45	09/19/10		400	Other	Disinfected	4902	Ayers Street	No	Manhole	No	1129906	Heavy Rain Event
	RN101610327 WQ0010401004 Oso	09/18/10	19:00	09/21/10	7:15	09/19/10		400	Other	Other (describe in additional info)		Dodd Drive/McArdle Road	No	Manhole	No	1124100	Heavy Rain Event - Overflow not stopped, disinfected, not repaired no potential impact. Was not on the 24 hr. notice, pending repairs
	RN101610327 WQ0010401004 Oso	09/19/10	8:00	09/21/10	7:15	09/19/10		200	Other	Disinfected		McArdle Road/Archer Drive	No	Manhole	No	1130126	Heavy Rain Event.

City of Corpus Christi Noncompliance Notification for : September 17, 18, 19, 20, 21, 22, 23, 2010

Track #	Regulated Entity	Start Date	Start Time	End Date	End Time	Date of 24 hr notification	5-day notification date	Amount/Gallons	Cause	Corrective/Preventive Actions Taken	Location of Discharge		Media	Structure	Potential danger to the environment.	Serv Prem	Additional Information
	RN101610327 WQ0010401004 Oso	09/19/10	14:30	09/19/10	15:30	09/20/10		1000	Other	Disinfected	501	Nile Drive	No	Other	No	No service prem	Rainwater, Return activated sludge overflow
	RN101610327 WQ0010401004 Oso	09/19/10	16:10	09/19/10	18:00	09/20/10		5000	Other	Other (describe in additional info)	5601	South Alameda Street	No	Manhole	Yes	354518	Heavy Rain Event - Please note potential danger to environment is yes instead of no. Marked wrong on the 24 hr. notice.
	RN101610327 WQ0010401004 Oso	09/20/10	7:30	09/20/10	10:00	09/21/10		5000	Other	Disinfected	601	Nile Drive	No	Other	Yes	No service prem	Rainwater, Return activated sludge overflow
	RN101610327 WQ0010401004 Oso	09/20/10	11:20	09/20/10	21:00	09/20/10		500	Other	Disinfected	1660	Devon Drive	No	Manhole	No	1125541	Rain Water, Heavy rain event
	RN101610327 WQ0010401004 Oso	09/20/10	19:40	09/20/10	22:00	09/21/10		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	401	Peerman Place	No	Manhole	No	184330	
	RN101610327 WQ0010401004 Oso	09/23/10	10:30	09/23/10	12:00	09/23/10		5	Other	Cleared, Disinfected	502	Driftwood Place	No	Wastewater Line	No	117262	Overflow within the trench, Line break caused by the Water Department
	RN101610327 WQ0010401004 Oso	09/21/10	9:30	09/21/10	12:00	09/21/10		40	Line Blockage (other than grease)	Cleared, Disinfected	4842	Rogerson Drive	No	Manhole	No	838	
	RN101610327 WQ0010401004 Oso	09/21/10	11:25	09/23/10	15:30	09/21/10		20	Line Break	Disinfected	3522	Lawnview Street	No	Cleanout	No	166994	
	RN101610327 WQ0010401004 Oso	09/21/10	15:30	09/23/10	14:30	09/22/10		10	Line Break	Disinfected	6310	North Washam Drive	No	Cleanout	No	53536	
	RN101610327 WQ0010401004 Oso	09/21/10	22:30	09/23/10	11:10	09/22/10		10	Line Break	Disinfected	3335	San Antonio Street	No	Cleanout	No	163406	
	RN101610327 WQ0010401004 Oso	09/22/10	14:00	09/23/10	10:45	09/22/10		300	Other	Disinfected	157	Rossiter Street	No	Manhole	No	1130791	Rainwater
	RN101610327 WQ0010401004 Oso	09/22/10	14:50	09/23/10	10:45	09/23/10		800	Other	Disinfected	4902	Dodd Drive	No	Manhole	No	80182	Rainwater
	RN101610327 WQ0010401004 Oso	09/22/10	14:50	09/23/10	10:50	09/23/10		100	Other	Disinfected		Mc Ardle Road/Archer Drive	No	Manhole	No	105273464	Rainwater
	RN101610327 WQ0010401004 Oso	09/22/10	14:50	09/23/10	10:45	09/23/10		400	Other	Disinfected		Dodd Drive/McArdle Road	No	Manhole	No	1124100	Rainwater
	RN101610327 WQ0010401004 Oso	09/22/10	14:50	09/23/10	10:48	09/23/10		400	Other	Disinfected	4902	Ayers Street	No	Manhole	No	1129906	Rainwater
	RN101609782 WQ0010401009 Whitecap	09/23/10	17:15	09/23/10	20:30	09/24/10		15	Line Blockage (other than grease)	Cleared, Disinfected	15934	El Soccorro Loop	No	Cleanout	No	194942	

MWD/10401-006/RP

100042556

Date Emailed: October 15, 2010

City of Corpus Christi

Mr. Kelly Ruble
TCEQ Region 14
NRC Building, Suite 1200
6300 Ocean Drive, Unit #5839
Corpus Christi, TX 78412-5839

RECEIVED
OCT 18 2010
ENFORCEMENT DIVISION

SUBJECT: NONCOMPLIANCE NOTIFICATION: October 08, 2010
October 09, 2010
October 10, 2010
October 11, 2010
October 12, 2010
October 13, 2010
October 14, 2010

RECEIVED
OCT 27 2010
TCEQ
CENTRAL FILE ROOM

WASTEWATER DEPARTMENT

PO Box 9277
Corpus Christi
Texas 78469-9277
Phone 361-826-1800
Fax 361-826-1715
www.cctexas.com

Dear Mr. Ruble:

The list of overflows for the time period of October 08, 09, 10, 11, 12, 13, 14, 2010 is included as an email attachment with this letter.

The location of the reported overflows will be added to the City's overflow tracking list/map. The frequency of the City's Preventative Maintenance Program for these areas will be evaluated in an effort to prevent the recurrence of future backups.

If you have any questions or require further information, please contact Brian J. Butscher, P.E., Wastewater Collection Superintendent at (361) 826-1807.

Sincerely,

Foster Crowell FOR
Wastewater Director

xc:
TCEQ/WQCMT (MC224) Enforcement Division, PO Box 13087, Austin TX 78711-3087
Oscar R. Martinez, Assistant City Manager
Foster Crowell, Wastewater Director
Joe F. Trejo., P. E., R.P.L.S., Assistant Wastewater Director
Valerie Gray, P. E., Director of Storm Water and Street Operations
Peggy L. Sumner, CHMM, CFM, Director of Environmental Services
Cliff Beaber, Wastewater Treatment Superintendent
Brian J. Butscher, P. E., Wastewater Collection Superintendent
Gerald Garcia, Work Coordinator
Margaret Castaneda, Finance and Resource Mgmt. Superintendent
Administration File

All-America City

WQ MWD/ REPORTS
1st: 10401 2nd: 006 Vol: 001 10/15/2010
BBC: 100042556
IBC: 100276614

City of Corpus Christi Noncompliance Notification for :
October 8, 9, 10, 11, 12, 13, 14, 2010

Track #	Regulated Entity	Start Date	Start Time	End Date	End Time	Date of 24 hr notification	5-day notification date	Amount/Gallons	Cause	Corrective/Preventive Actions Taken	Location of Discharge		Media	Structure	Potential danger to the environment	Serv Prem	Additional Information
	RN101610079 WQ0010401006 Allison	10/08/10	8:40	10/08/10	10:30	10/08/10		15	Line Blockage (other than grease)	Cleared Disinfected	11609	Chaps Creek Drive	No	Cleanout	No	146699	
	RN101610079 WQ0010401006 Allison	10/11/10	10:00	10/11/10	10:35	10/11/10		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	10914	Shady Lane	No	Cleanout	No	143060	
	RN101610079 WQ0010401006 Allison	10/11/10	20:00	10/11/10	21:30	10/12/10		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	4302	Western Drive	No	Manhole	No	301332	
	RN101610079 WQ0010401006 Allison	10/13/10	18:30	10/13/10	20:30	10/14/10		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	10821	Stacy Lane	No	Cleanout	No	475479163	
	RN101610188 WQ0010401005 Broadway	10/11/10	11:15	10/11/10	11:35	10/11/10		30	Line Blockage (other than grease)	Disinfected	507	Eighteenth Street	No	Cleanout	No	81698	Private Cleanout
	RN101610188 WQ0010401005 Broadway	10/11/10	13:30	10/11/10	14:15	10/11/10		30	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1111	Twelfth Street	No	Cleanout	No	27445	
	RN101610188 WQ0010401005 Broadway	10/11/10	14:30	10/11/10	16:30	10/12/10		80	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	400	Mann Street	No	Cleanout	No	107375	
	RN101610188 WQ0010401005 Broadway	10/12/10	8:00	10/12/10	8:30	10/12/10		10	Line Blockage (other than grease)	Disinfected	1225	Second Street	No	Cleanout	No	347995	Private Cleanout
	RN101610188 WQ0010401005 Broadway	10/12/10	22:00	10/12/10	23:00	10/13/10		10	Line Blockage (other than grease)	Cleared, Disinfected	3312	Leopard Street	No	Cleanout	No	121838	Private Cleanout
	RN101610188 WQ0010401005 Broadway	10/14/10	13:35	10/14/10	14:30	10/14/10		10	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	222	Longview West	No	Manhole	No	38524	
	RN101610400 WQ0010401003 Greenwood	10/10/10	15:40	10/10/10	18:30	10/11/10		10	Line Blockage (other than grease)	Cleared, Disinfected	2829	Elizbeth Street	No	Cleanout	No	10952	
	RN101610400 WQ0010401003 Greenwood	10/12/10	8:00	10/12/10	9:20	10/12/10		50	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	2000	South Padre Island Drive	No	Cleanout	No	297469	
	RN101610400 WQ0010401003 Greenwood	10/13/10	18:30	10/13/10	19:00	10/14/10		10	Line Blockage (other than grease)	Disinfected	3700	Itaska Court	No	Cleanout	No	105281614	Private Cleanout
	RN101610400 WQ0010401003 Greenwood	10/14/10	11:00	10/14/201	12:15	10/14/10		75	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	2341	Pearse Drive	No	Cleanout	No	402058	
	RN101610327 WQ0010401004 Oso	10/08/10	12:30	10/09/10	12:30	10/09/10		20	Line Break	Disinfected	718	Collingwood Drive	No	Cleanout	No	1640	Phoned In to TCEQ on 10/08/10. Faxed In on 10/09/10, TCEQ's fax down on 10/08/10
	RN101610327 WQ0010401004 Oso	10/09/10	12:30	10/09/10	13:25	10/09/10		100	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	350	Pasadena Place	No	Manhole	No	164334	
	RN101610327 WQ0010401004 Oso	10/10/10	14:14	10/10/10	16:30	10/11/10		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	4834	Easter Drive	No	Manhole	No	78824	
	RN101610327 WQ0010401004 Oso	10/11/10	8:00	10/11/10	8:50	10/11/10		20	Line Blockage (other than grease)	Cleared, Disinfected	653	Sorrell Street	No	Manhole	No	132676	
	RN101610327 WQ0010401004 Oso	10/14/10	9:00	10/14/10	9:30	10/14/10		10	Line Blockage (other than grease)	Cleared, Disinfected	1118	Prince Drive	No	Cleanout	No	4646	

omu3|10401-006|RP

City of Corpus Christi

WASTEWATER DEPARTMENT

PO Box 9277
Corpus Christi
Texas 78469-9277
Phone 361-826-1800
Fax 361-826-1715
www.cctexas.com

Date Emailed: November 19, 2010

Mr. Kelly Ruble
TCEQ Region 14
NRC Building, Suite 1200
6300 Ocean Drive, Unit #5839
Corpus Christi, TX 78412-5839

RECEIVED
NOV 23 2010
ENFORCEMENT DIVISION

SUBJECT: NONCOMPLIANCE NOTIFICATION: November 13, 2010
November 14, 2010
November 15, 2010
November 16, 2010
November 18, 2010

RECEIVED
NOV 23 2010
ENFORCEMENT DIVISION

Dear Mr. Ruble:

The list of overflows for the time period of November 13, 14, 15, 16, 18, 2010 is included as an email attachment with this letter.

The location of the reported overflows will be added to the City's overflow tracking list/map. The frequency of the City's Preventative Maintenance Program for these areas will be evaluated in an effort to prevent the recurrence of future backups.

If you have any questions or require further information, please contact Brian J. Butscher, P.E., Wastewater Collection Superintendent at (361) 826-1807.

Sincerely,

Foster Crowell
Wastewater Director

xc:
TCEQ/WQCMT (MC224) Enforcement Division, PO Box 13087, Austin TX 78711-3087
Oscar R. Martinez, Assistant City Manager
Foster Crowell, Wastewater Director
Joe F. Trejo., P. E., R.P.L.S., Assistant Wastewater Director
Valerie Gray, P. E., Director of Storm Water and Street Operations
Peggy L. Sumner, CHMM, CFM, Director of Environmental Services
Cliff Beaber, Wastewater Treatment Superintendent
Brian J. Butscher, P. E., Wastewater Collection Superintendent
Gerald Garcia, Work Coordinator
Margaret Castaneda, Finance and Resource Mgmt. Superintendent
Administration File

RECEIVED
DEC 14 2010
TCEQ
CENTRAL FILE ROOM

All-America City

WQ MWD/ REPORTS
1st: 10401 2nd: 006 Vol: 001 11/19/2010
BBC: 100042556
IBC: 100306225

City of Corpus Christi Noncompliance Notification for :
November 13, 14, 15, 16, 18, 2010

Track #	Regulated Entity	Start Date	Start Time	End Date	End Time	Date of 24 hr notification	5-day notification date	Amount/Gallons	Cause	Corrective/Preventive Actions Taken	Location of Discharge		Media	Structure	Potential danger to the environment.	Serv Prem	Additional Information
	RN101610079 WQ0010401006 Allison	11/15/10	10:30	11/15/10	20:30	11/16/10		40	Line Break	Disinfected	11613	Chiepa Creek Drive	No	Cleanout	No	148898	
	RN101610079 WQ0010401006 Allison	11/16/10	13:10	11/16/10	13:50	11/16/10		100	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	3829	US Highway 77 Road	No	Manhole	No	144892	
	RN101610188 WQ0010401005 Broadway	11/13/10	20:00	11/13/10	21:00	11/14/10		10	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	444	North Shoreline Boulevard	No	Manhole	No	111528	
	RN101610188 WQ0010401005 Broadway	11/15/10	16:00	11/15/10	18:50	11/16/10		100	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1101	Eleventh Street	No	Manhole	No	1134057	
	RN101610188 WQ0010401005 Broadway	11/16/10	18:00	11/16/10	19:30	11/17/10		150	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	201	South Upper Broadway Street	No	Manhole	No	295106	
	RN101610188 WQ0010401005 Broadway	11/18/10	10:55	11/18/10	12:25	11/18/10		6	Line Blockage (other than grease)	Cleared, Disinfected	426	South Tancahua Street	No	Manhole	No	1129543	
	RN101510400 WQ0010401003 Greenwood	11/16/10	18:30	11/16/10	20:00	11/17/10		50	Line Blockage (other than grease)	Cleared, Disinfected	2800	Ayers Street	No	Cleanout	No	105279543	Private Cleanout
	RN101509915 WQ0010404008 Laguna Madre	11/16/10	18:50	11/16/10	22:30	11/17/10		30	Line Blockage (other than grease)	Cleared, Disinfected	9505	Blue Jay Street	No	Manhole	No	177520	
	RN101610327 WQ0010401004 Oso	11/13/10	13:41	11/13/10	14:29	11/13/10		10	Line Blockage (other than grease)	Cleared, Disinfected	6225	Norchester Drive	No	Cleanout	No	86854	Private Cleanout
	RN101610327 WQ0010401004 Oso	11/14/10	17:00	11/14/10	19:30	11/15/10		20	Line Break	Cleared, Vacuumed, Disinfected	6688	South Padre Island Drive	No	Force main	No	21126	
	RN101610327 WQ0010401004 Oso	11/15/10	18:25	11/16/10	20:50	11/16/10		30	Line Blockage (other than grease)	Cleared, Disinfected	5037	Anthony Street	No	Cleanout	No	78164	
	RN101610327 WQ0010401004 Oso	11/18/10	16:00	11/18/10	20:30	11/19/10		20	Line Blockage (other than grease)	Cleared, Disinfected	642	Robinson Street	No	Manhole	No	153170	

mailed 10401-006 RP

City of Corpus Christi

Date Emailed: February 18, 2011

Mr. Kelly Ruble
TCEQ Region 14
NRC Building, Suite 1200
6300 Ocean Drive, Unit #5839
Corpus Christi, TX 78412-5839

RECEIVED
FEB 22 2011
ENFORCEMENT DIVISION

SUBJECT: NONCOMPLIANCE NOTIFICATION: February 11, 2011
February 12, 2011
February 13, 2011
February 14, 2011
February 15, 2011
February 16, 2011
February 17, 2011

WASTEWATER DEPARTMENT

PO Box 9277
Corpus Christi
Texas 78469-9277
Phone 361-826-1800
Fax 361-826-1715
www.cctexas.com

Dear Mr. Ruble:

The list of overflows for the time period of February 11, 12, 13, 14, 15, 16, 17, 2011 is included as an email attachment with this letter.

The location of the reported overflows will be added to the City's overflow tracking list/map. The frequency of the City's Preventative Maintenance Program for these areas will be evaluated in an effort to prevent the recurrence of future backups.

If you have any questions or require further information, please contact Brian J. Butscher, P.E., Wastewater Collection Superintendent at (361) 826-1807.

Sincerely,

Foster Crowell
Wastewater Director

RECEIVED
MAR 04
TCEQ
CENTRAL FILE

XC:
TCEQ/WQCMT (MC224) Enforcement Division, PO Box 13087, Austin TX 78711-3087
Oscar R. Martinez, Assistant City Manager
Foster Crowell, Wastewater Director
Joe F. Trejo., P. E., R.P.L.S., Assistant Wastewater Director
Valerie Gray, P. E., Director of Storm Water and Street Operations
Pete Anaya, P.E. Director of Engineering
Brian J. Butscher, P. E., Wastewater Collection Superintendent
Gerald Garcia, Interim Wastewater Treatment Superintendent
Margaret Castaneda, Finance and Resource Mgmt. Superintendent
Administration File

1st: 10401 2nd: 006 Vol: 001 2/18/2011
BBC: 100328887
IBC: 100345329

All-America City

City of Corpus Christi Noncompliance Notification for :
February 11, 12, 13, 14, 15, 16, 17, 2011

Track #	Regulated Entity	Start Date	Start Time	End Date	End Time	Date of 24 hr notification	5-day notification date	Amount/Gallons	Cause	Corrective/Preventive Actions Taken	Location of Discharge		Media	Structure	Potential danger to the environment.	Serv Prem	Additional Information
	RN101610079 WQ0010401006 Allison	02/12/11	15:56	02/12/11	17:30	02/13/11		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	9301	Mars Avenue	No	Manhole	No	120724	
	RN101610166 WQ0010401005 Broadway	02/12/11	16:34	02/12/11	23:40	02/13/11		20	Line Blockage (other than grease)	Cleared, Disinfected	3742	Liberty Drive	No	Cleanout	No	124066	
	RN101610166 WQ0010401005 Broadway	02/13/11	9:30	02/13/11	10:00	02/13/11		20	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	813	Dolores Street	No	Cleanout	No	100574	
	RN101610166 WQ0010401005 Broadway	02/13/11	8:56	02/14/11	12:00	02/14/11		40	Line Break	Contained, Disinfected	216	North Ninateenth Street	No	Cleanout	No	90088	
	RN101610166 WQ0010401005 Broadway	02/16/11	17:00	02/16/11	21:15	02/17/11		10	Line Blockage (other than grease)	Cleared, Disinfected	2617	Segreat Street	No	Cleanout	No	3022	
	RN101610166 WQ0010401005 Broadway	02/16/11	21:30	02/16/11	23:00	02/17/11		100	Line Blockage (other than grease)	Cleared, Disinfected	3622	Bartlett Drive	No	Manhole	No	99116	
	RN101610166 WQ0010401005 Broadway	02/17/11	17:20	02/17/11	17:30	02/18/11		40	Line Blockage (other than grease)	Cleared, Disinfected	2734	Cleo Street	No	Cleanout	No	3704	
	RN101610166 WQ0010401005 Broadway	02/17/11	13:50	02/17/11	14:25	02/17/11		30	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	3029	Summers Street	No	Manhole	No	1129831	
	RN101610400 WQ0010401003 Greenwood	02/12/11	19:50	02/12/11	22:00	02/13/11		10	Line Blockage (other than grease)	Cleared, Disinfected	1801	Roslyn Street	No	Manhole	No	101834	
	RN101610400 WQ0010401003 Greenwood	02/13/11	17:00	02/13/11	18:30	02/14/11		20	Line Blockage (other than grease)	Cleared, Disinfected	1542	El Paso Street	No	Cleanout	No	108712	Private Cleanout
	RN101610400 WQ0010401003 Greenwood	02/13/11	20:00	02/13/11	21:10	02/14/11		10	Line Blockage (other than grease)	Contained, Disinfected	5101	Green Park Drive	No	Cleanout	No	69172	Private Cleanout
	RN101610400 WQ0010401003 Greenwood	02/13/11	21:30	02/13/11	22:00	02/14/11		10	Line Blockage (other than grease)	Contained, Disinfected	1710	Robin Drive	No	Cleanout	No	8544	Private Cleanout
	RN101610400 WQ0010401003 Greenwood	02/15/11	11:30	02/15/11	14:30	02/15/11		30	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	254	Adams Drive	No	Wastewater Line	No	39300	Exfiltration from City main line
	RN101610400 WQ0010401003 Greenwood	02/15/11	13:15	02/15/11	14:30	02/15/11		25	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	218	Roosevelt Drive	No	Manhole	No	39300	
	RN101610400 WQ0010401003 Greenwood	02/16/11	11:30	02/16/11	13:00	02/16/11		20	Line Blockage (other than grease)	Cleared, Disinfected	1102	Villarreal Drive	No	Manhole	No	1120417	Private Manhole
	RN101609916 WQ0010404008 Laguna Madre	02/11/11	13:30	02/11/11	17:00	02/12/11		70	Line Blockage (other than grease)	Cleared, Disinfected	9706	South Padre Island Drive	No	Manhole	No	333010	Private manhole and cleanout
	RN101609916 WQ0010404008 Laguna Madre	02/14/11	10:44	02/14/11	14:30	02/14/11		20	Line Blockage (other than grease)	Cleared, Disinfected	526	Skipper Lane	No	Cleanout	No	188032	Private Cleanout
	RN101609916 WQ0010404008 Laguna Madre	02/15/11	13:30	02/15/11	14:30	02/15/11		50	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	701	St. Lucy Drive	No	Manhole	No	1132721	
	RN101610327 WQ0010401004 Oso	02/11/11	13:05	02/11/11	13:20	02/11/11		75	Line Blockage (other than grease)	Contained, Disinfected	3221	South Staples Street	No	Cleanout	No	12199	Private Cleanout

RECEIVED
FEB 22 2011
ENFORCEMENT DIVISION

City of Corpus Christi Noncompliance Notification for :
February 11, 12, 13, 14, 15, 16, 17, 2011

	RN101610327 WQ0010401004 Oso	02/11/11	16:11	02/11/11	18:14	02/12/11		30	Line Blockage (other than grease)	Contained, Disinfected	3938	Montego Drive	No	Cleanout	No	14734	Private Cleanout
	RN101610327 WQ0010401004 Oso	02/13/11	9:45	02/13/11	11:10	02/13/11		5	Line Blockage (other than grease)	Cleared, Disinfected	3410	Bollinger Street	No	Cleanout	No	53800	Private Cleanout
	RN101610327 WQ0010401004 Oso	02/13/11	11:00	02/13/11	12:30	02/13/11		10	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	4514	Grand Lake Drive	No	Manhole	No	57552	
	RN101610327 WQ0010401004 Oso	02/13/11	13:45	02/13/11	15:30	02/13/11		180	Line Blockage (other than grease)	Cleared, Disinfected	321	Oleander Avenue	No	Manhole	No	154210	
	RN101610327 WQ0010401004 Oso	02/14/11	11:10	02/14/11	23:30	02/15/11		10	Line Blockage (other than grease)	Cleared, Disinfected	6018	Lost Creek Drive	No	Cleanout	No	77014	Private Cleanout
	RN101610327 WQ0010401004 Oso	02/15/11	8:15	02/15/11	11:00	02/15/11		70	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	3221	Quail Creek Drive	No	Manhole	No	397378	
	RN101610327 WQ0010401004 Oso	02/16/11	9:34	02/16/11	10:45	02/16/11		40	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	1114	Stratton Drive	No	Manhole	No	6572	
	RN101610327 WQ0010401004 Oso	02/16/11	9:53	02/16/11	11:49	02/16/11		20	Line Blockage (other than grease)	Contained, Disinfected	4314	Moravian Drive	No	Cleanout	No	74846	Private Cleanout
	RN101610327 WQ0010401004 Oso	02/16/11	16:30	02/17/11	16:15	02/17/11		20	Line Break	Contained, Disinfected	322	Oleander Avenue	No	Cleanout	No	154274	
	RN101610327 WQ0010401004 Oso	02/16/11	20:30	02/16/11	22:00	02/17/11		50	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	4109	Del Starr Drive	No	Manhole	No	93284	
	RN101610327 WQ0010401004 Oso	02/17/11	16:10	02/17/11	16:30	02/18/11		30	Line Blockage (other than grease)	Cleared, Vacuumed, Disinfected	4706	Megal Drive	No	Cleanout	No	56366	
	RN101610327 WQ0010401004 Oso	02/17/11	11:15	02/17/11	14:00	02/17/11		10	Line Blockage (other than grease)	Cleared, Disinfected	4738	Gabriel Drive	No	Wastewater Line	No	60778	Exfiltration from City main line
	RN101610327 WQ0010401004 Oso	02/17/11	15:45	02/18/11	14:40	02/18/11		5	Line Break	Contained, Disinfected	3501	San Antonio Street	No	Cleanout	No	163456	