TOWN OF SPRINGER

P.O. BOX 488 606 COLBERT AVE.

PHONE 483-2682

SPRINGER, NEW MEXICO 87747

To: Mr. Stephen Gilrein

From: Mr. James Montoya

CC: Ms. Mona Tates

Date: 10/20/2020

Re: Administrative Order Docket Number: CWA-06-2020-1783
Town of Springer Water Treatment Plant
NMPDES Permit Number: NM0030627

On 09/23/2020 I received a copy of the Administrative order above from Mayor Boe Lopez. We immediately placed an order for a dechlorination agent. We are currently using Ascorbic Acid Tablets to dechlorinate the Backwash water prior to it entering the ponds. We implemented this method on 09/30/2020. We have seen great results and are currently working on our dosages.

The following is a table of our current monthly average and our weekly averages.

Total Chlorine Residuals		
Current Average	Week 1 Average	Week 2 Average
17 ug/l	10 ug/l	24 ug/l

We will continue to report our progress as we believe we will be in compliance with the standards of the permit soon.

Thank You
James Montoya
Town of Springer
Water/Wastewater Superintendent

EVERYBODY IS SOMEBODY IN NEW MEXICO!!!!