Table A
Permit Limits

Effluent Characteristics	Discharge Limitations for Outfall 001A			
	Loading (lbs/day)	Concentration (µg/l)		
	30 Day Avg.	30 Day Avg.	7 Day Avg.	Daily Max.
Total Residual Chlorine (TRC)	N/A	N/A	N/A	11 µg/l

Table B
Effluent Violations

Date	Outfall	Parameter	Violation	Permit Limit
Oct 2019	001	Total Residual Chlorine	20 µg/l	11 µg/l
Nov 2019	001	Total Residual Chlorine	24 µg/l	11 µg/l
Dec 2019	001A	Total Residual Chlorine	49 µg/l	11 µg/l
Jan 2020	001A	Total Residual Chlorine	28 µg/l	11 µg/l
Feb 2020	001A	Total Residual Chlorine	1180 µg/l	11 µg/l
Mar. 2020	001A	Total Residual Chlorine	740 µg/l	11 µg/l
Apr 2020	001A	Total Residual Chlorine	880 µg/l	11 µg/l
May 2020	001A	Total Residual Chlorine	240 µg/l	11 µg/l