

Cleaned 4 Fixtures
3 New Ballast

Room 2

OK 9/26/14

M.F.





Cleaned 3 Fixtures

Replaced 3 Ballasts

Room 3
OK 8/27/14
M.F.



Cleaned 2
Fixtures
1 New Ballast

Room 4
OK 8/27/14
M. F.



4 Cleaned Fixtures
2 New Ballasts



OK
8/27/14
MF

Room 5

Cleaned 6 Fixtures
Replace 4 Ballast
Replace 1 Plate





OK 8/27/14 Room 6
MF

cleaned 3
Replaced 2 Ballasts
Replace 1 Plate



Room 7

OK 8/27/14
MF

East

door



Clean 1 Filter
change 1 Ballast

door

OK 8/27/14
MF

Room 8

Replace 1 Ballast
Clean 1 Fixture



SOUTH POD

CLEANED ALL
16 FIXTURES
10 NEW
BALLASTS



NORTH POD

All New Type
Ballasts – NO PCBS



EAST POD

No Exceptions Reported



OK 8/27/14
mF

Room 9

Cleaned 4 Fixture
Replaced 4 Ballasts



OK 8/27/14
mt

Room 10

cleaned 5 Fixtures
Replaced 5 Ballasts



OK 8/27/14 Room 11
MF

Cleaned 2 Fixtures
Replaced 2 Ballasts



OK 8/27/14
MF

Room 12

3 cleaned
3 Ballast Replaced



Sky Valley Education Center

EVACUATION LOCATIONS

EMERGENCY EVACUATION ROUTES



ED_001594_00087383

EPA_002284

Room 13 North

OK 8/28/14

M.F.

door





ok 8/28/14
MF

Room 114

Cleaned 2 Fixtures
Replaced 2 Ballasts



ok 8/28/14
mF

Room 15

Cleaned 2 Fixtures
Replaced 2 Ballasts



OK 8/28/14
MF

Room 16

Cleared 1 Fixtures
Replaced 1 Ballast



Room 17

M Flannery
10/6/14



M. Flanning
10/6/14

Room 18

Cleaned 1 Fixture
Replaced 1 Ballast



M Flanny
10/6/14

Room 19

Clean 2 Fixtures
Replace 2 Ballasts



OK
10/17/14
MIKE FLOWERY

Room
20
Cleaned 2 Fixtures
Replaced 1 Plate



6 Fixtures cleaned
5 New ballasts
2 New Plates

[illegible]
10/17/14

Library
Main







Cleaned 2 Fixtures
Replaced 2 Ballasts

M Flaherty
10/17/14

Library
South
END




FASCE
No PCB Ballast
in Main Room
Replace 1 Plate
Clean 1 Fixture
S
11/10/14
CHECKED OK
Store Room
Replace Plat
all ok
Door
N

....CHECKED OK
11/13/14

N

Room A

Cleaned 1 Fixture

All Ballasts NO PCBS
IN This Room



S

CHECKED OK
11/13/14



.... CHECKED OK
11/13/14

Room D
Cleaned 4 Fixtures
Replaced 1 Ballast





CHECKED OK
11/13/14

Prep Area
Between
Room A+C
Cleaned 4
Fixtures

N



S

CHECKED OK
11/13/14

Room C



CHECKED OK
11/13/14

Kelsey → N

Room F

Replaced 2 Plates

Cleared 2 Fixtures



11/13/14
CHECKED OK

CBP
ROOM

Cleaned 6 Fixtures
Replaced 1 Plate



Master pg 3

Music Room Storage + Music Room

Clean 6 Fixtures
Replace 2 Ballasts
Replace 2 Plates



Music Room

Master pg 2