Attachment 3

Non-Contact Cooling Water Chlorine Residual Results

ATTACHMENT 3
PLATFORM ELLEN
NON-CONTACT COOLING WATER
CHLORINE RESULTS
January 1, 2017 through March 31, 2017

Discharge	Measurement Frequency	Average Monthly Limit [1] Post Dilution (mg/l)	Maximum Daily Limit [1] Post Dilution (mg/l)	Result Post Dilution (mg/l)	End-of-Pipe Concentration (mg/l) EPA Method 330.5	EPA Plumes Dilution
009 Non-contact Cooling Water Sample Date: 01/27/17	Once/Quarter	0.00583	0.0104	0.002	0.3	149:1

[1] Limits are post-dilution as listed in the permit, Appendix C.