AtlasPipeline

Oklahoma City Offices
14000 Quail Springs Pkwy, Ste 215
Oklahoma City, OK 73134
Tel: 405.749.5600
www.atlaspipeline.com

March 29, 2012

VIA UPS 1Z 09Y 07W 21 1000 0060

Air Compliance Section
Kansas Department of Health and Environment
1000 SW Jackson, Suite 310
Topeka, Kansas 66612

6661

Subject: Anthony Compressor Station
Air Permit No. 0770055
Initial Notification for a Reciprocating Internal Combustion Engine
Subject to 40 CFR Part 63 Subpart ZZZZ

Atlas Pipeline Mid-Continent WestOK, LLC (WESTOK) is providing initial notification for an engine subject to 40 CFR Part 63, Subpart ZZZZ as required by 40 CFR 63.6645(a) and 40 CFR 63.9(b)(2). The required information is provided below.

Name and Address of Owner/Operator: Atlas Pipeline Mid-Continent WestOk, LLC
110 West 7th Street, Suite 2300
Tulsa, Oklahoma 74119

Address of Affected Source: Anthony Compressor Station
Section 10, Township 34S, Range 8W
Harper County, Kansas

Relevant Standard: 40 CFR Part 63, Subpart ZZZZ: National Emissions Standards For Hazardous Air Pollutants For Stationary Reciprocating Internal Combustion Engines

Compliance Date: October 19, 2013

Engine Information:

Engine ID	Make	Model	Serial Number	Max HP	Method of Operation	HAP
C3	Caterpillar	G3516LE	4EK03847	1340	Natural Gas	Formaldehyde

Affected Source Type: The equipment provided in this notification is an area source and is located at an area source of Hazardous Air Pollutants.

If you require additional information or have any questions, please contact me at 405.749.5606 or by email at jgregg@atlaspipeline.com.

ATLAS PIPELINE MID-CONTINENT WESTOK, LLC

Jarrod Gregg
Sr. Environmental Specialist

cc: VIA UPS 1Z 09Y 07W 21 1000 0079
Air Permits Section
Environmental Protection Agency – Region 7
901 North 5th Street
Kansas City, KS 66101

A. Krush, E. Hiland, J. Herron, J. Faulkner, B. Peterson, B. Martin