2-24-14

631 E Chestnut called out to Sewer problem at 10:30 AM checked out line it was home owner problem 11:40 AM (Bob & Shawn)

2-24-14 210 S Dunnegan st called out for sewer coming out Cleanout at 2:45pm arrived at 3:00pm Jetted line did not fix problem the problem is on their side left at 4:05pm. (SW & BA)

3-11-14 2224 W Auburn st recived a call of sewer smell at 10:00 am arrived at 10:15 am Check Main it was flowing freely checked under house had sewer under house possible break of clog on owners property owners responsibilty left at 10:45 am (JB)

3/14/14 417 E locust st recieved a call of sewer problems at 10:00 am arrived at 10:15 am checked main it was clear Checked there clean out cap it was clear not our problem left at 10:45 am (JB)

3/17/14 717 E Van Buren recieved at 6:20 am arrived at 6:45 am checked main and it was fine property owners ~~No~~ problem left at 7:00 am. (SW)

3-4-14 Called out to Northwood & Maple Circle Sewer backed up in Man hole jetted from Northwood North to Northwood and Maple Cir intersection with root nozzle opened it up ran slow coming back (1100 Maple Circle) clog was in front of 1024 s Maple Circle (BA)