Town of Hot Springs 7/16/14 MT0020591
Unsigned copy of permit at Town Hall.
Check to see if comments changes from PN.
PWD - Ruben Loberg, does monitoring
Sierra Nazaro, aerators & Cl, skim ponds, etc.
Changed to Chlorine tablets instead of chlorine gas. Tablets dissolve, inject chlorine into effluent at same location as gas chlorine. Did in summer 2013.
Ruben does daily visuals and collects samples at beginning of month to allow time to resample if needed. Discharge point is the same.
DMRs and analytical reports in Town Hall files.
Does chlorine samples with color meter which gives digital readout.
* Verify percent removal requirement for BOD & TSS in permit. Let Ruben know.
SSO situation is under control. Have camera to look at system. Fix lines when problems are found. Have jetter also, have a regular schedule to jet lines. Working w/engineers for water and sewer system upgrades. Ongoing project for PER and plans. Morrison-Maierle. Pursuing funding.
Want to reduce inflow-infiltration.