3/6/13 Hull WWTF 9:00

Safety in brief w/ Beth Murphy (Unitech H2O) -

Signed to confirm safety brief

introduced to plant Manager, Pete Nyberg & a # of Unitech folk. Met Dan Marson, United Regional guy.

Walk thru - many

Grit chamber of line, but everything else on-line w/ external power & pumps.

pump 3 failure ~ 3pm Wed (before plant failure, struck check valve

Marine fishery # on DEP @ website is wrong. D. Burns notified

Outbrief:

Q from facility:

① Composite sampling not flow-weighted (Don't have accurate metering or link to sampler, told them this is OK

② Don't have continuous TRC, Are doing 6 grabs/day, we told them this is OK

③ SOP for emergency bypass pumping during upcoming storm. Decision will be based on interceptor level, wet well level. primary split box level. Ability of plant to handle flow. We told them this sounds good in principle.

- would not plan to collect bypass off discharge samples during storm, for safety reason.

[Biomag going into operation in mystic this summer, if we want to do tour]