July 30, 2009

Ms. Cheryl Heying
Utah Division of Air Quality
P.O. Box 144820
Salt Lake City, UT 84114-4820

Dear Ms. Heying:

Units One and Two Second Quarter, 2009 Emissions Report
Operating Permit #2700010003

As part of Intermountain Power Service Corporation's reporting requirements for the Intermountain Generating Station (IGS), we are submitting Units One and Unit Two Second Quarter, 2009, Emissions Report in the ASCII electronic format for your review. The report was electronically transmitted to Mr. Norm Erikson of the UDAQ.

If you have any questions or comments, please contact Mr. Jon P. Christensen, IPSC's Superintendent of Technical Services, at (435) 864-6401.

Sincerely,

George W. Cross

George W. Cross
President & Chief Operations Officer and Responsible Official
APC
MAF/BP:jmj

cc: Saif Mogri
Blaine Ipson

*EPA Request dated Oct 12, 2010, for Information Pursuant to Section 114 . Response #16 of 17 of Appendix B.

INTERMOUNTAIN POWER SERVICE CORPORATION

November 3, 2010

Ms. Cheryl Heying
Utah Division of Air Quality
P.O. Box 144820
Salt Lake City, UT 84114-4820

Dear Ms. Heying:

Amended Units One and Two Second Quarter, 2009 Emissions Report
Operating Permit #2700010003

As part of Intermountain Power Service Corporation's reporting requirements for the Intermountain Generating Station (IGS), we are submitting an amended Units One and Two Second Quarter, 2009, Emissions Report in the ASCII electronic format for your review. The report was electronically transmitted to Mr. Norm Erikson of the UDAQ.

If you have any questions or comments, please contact Mr. Jon P. Christensen, IPSC's Superintendent of Technical Services, at (435) 864-6401.

Sincerely,

Jon A Finlinson

Jon A. Finlinson
President & Chief Operations Officer and Responsible Official

MAF/BP:jmj

cc: Saif Mogri
Blaine Ipson

850 West Brush Wellman Road Delta, Utah 84624 / Telephone: (435) 864-4414 / FAX: (435) 864-6670 / Fed. I.D. #87-0388573

July 30, 2009

Ms. Cheryl Heying
Division of Air Quality
P.O. Box 144820
Salt Lake City, Utah 84114-4820

Dear Ms. Heying:

Signed Statement, Deviation Report
Units One and Two Second Quarter 2009

As required by 40 CFR 60.49a (f)(g), this signed statement is being submitted for Units One and Two for the Second Quarter 2009, Quarterly Report.

1. For any periods for which opacity, sulfur dioxide, or nitrogen oxide emission data are not available, changes were not made in the operation of the emission control system.

2. The required continuous monitoring system calibration, span and drift checks and other periodic audits have been performed as specified.

3. The data used to show compliance was obtained in accordance with approved methods and procedures of Subpart Da and is representative of plant performance.

4. The minimum data requirements have been met.

5. Compliance with the standards has been achieved during the reporting period.

Under penalty of law, all information contained in the report is truthful and accurate, and is a complete record of all monitoring related events which occurred during the reporting period.

This letter provides notice that this report constitutes a deviation report as required under Section I.S.2.C and Section II.B.2.e.3 of our Title V Operating Permit #2700010003. This report is considered prompt notification as stated in Section II.B.2.e.3.d of our Operating Permit.

I certify based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

Sincerely,

George W Cross

George W. Cross
President & Chief Operations Officer and Responsible Official

Apc
MAF/BP:jmj

cc: Saif Mogri
Blaine Ipson

*EPA Request dated Oct 12, 2010, for Information Pursuant to Section 114 . Response #16 of 17 of Appendix B.

INTERMOUNTAIN POWER SERVICE CORPORATION

November 3, 2010

Ms. Cheryl Heying
Division of Air Quality
P.O. Box 144820
Salt Lake City, Utah 84114-4820

Dear Ms. Heying:

Signed Statement, Deviation Report
Amended Units One and Two Second Quarter 2009

As required by 40 CFR 60.49a (f)(g), this signed statement is being submitted for an amended Units One and Two Quarterly Report for the Second Quarter 2009.

1. For any periods for which opacity, sulfur dioxide, or nitrogen oxide emission data are not available, changes were not made in the operation of the emission control system.

2. The required continuous monitoring system calibration, span, and drift checks and other periodic audits have been performed as specified.

3. The data used to show compliance was obtained in accordance with approved methods and procedures of Subpart Da and is representative of plant performance.

4. The minimum data requirements have been met.

5. Compliance with the standards has been achieved during the reporting period.

Under penalty of law, all information contained in the report is truthful and accurate, and is a complete record of all monitoring related events which occurred during the reporting period.

This letter provides notice that this report constitutes a deviation report as required under Section I.S.2.C and Section II.B.2.e.3 of our Title V Operating Permit #2700010003. This report is considered prompt notification as stated in Section II.B.2.e.3.d of our Operating Permit.

I certify based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

Sincerely,

Jon A Finlinson

Jon A. Finlinson
President & Chief Operations Officer and Responsible Official
JPC
MAF/BP:jmj

cc: Saif Mogri
Blaine Ipson

850 West Brush Wellman Road, Delta, Utah 84624 / Telephone: (435) 864-4414 / FAX: (435) 864-6670 / Federal ID #87-0265738

State of Utah

GARY R. HERBERT
Governor

Department of
Environmental Quality

Amanda Smith
Acting Executive Director

DIVISION OF AIR QUALITY
Cheryl Heying
Director

GWC
AUG 24 2009

August 19, 2009

DAQC-943-09
Site ID 10327 (B5)

George W. Cross
IPP
850 W. Brush Wellman Rd.
Delta, UT 84624-9546

Dear Mr. Cross:

Re: IPP - Second Quarter 2009 - State Electronic Data Report (SEDR), Millard County - AIRS # 027 00010

Your SEDR was reviewed and appears to conform to the intent of Utah Administrative Code (UAC) R307-170. The Utah Division of Air Quality (DAQ) understands that the following conditions existed during this reporting period.

If you are in disagreement with these conclusions, notify the DAQ immediately.

% Monitor Availability				Excess Emissions Summary (Start-up/Shutdown Excluded)			
Source	Channel	Percent Availability	Percent QA Calibrations	Source	Channel	Hours	Percent
Unit 1	CO2	99.08%	0.18%	Unit 1	NOx	0.00	0.00%
Unit 1	CO2	98.09%	0.25%	Unit 1	Opacity	0.00	0.00%
Unit 1	NOx	98.09%	0.25%	Unit 1	SO2	0.00	0.00%
Unit 1	Opacity	98.11%	0.41%	Unit 2	NOx	0.00	0.00%
Unit 1	SO2	99.08%	0.18%	Unit 2	Opacity	0.00	0.00%
Unit 1	SO2	98.09%	0.25%	Unit 2	SO2	0.00	0.00%
Unit 2	CO2	98.47%	0.10%				
Unit 2	CO2	98.37%	0.15%				
Unit 2	NOx	98.37%	0.15%				
Unit 2	Opacity	99.54%	0.45%				
Unit 2	SO2	98.47%	0.10%				
Unit 2	SO2	98.37%	0.15%				

Excess Emission Report - Hourly Summary

150 North 1950 West • Salt Lake City, UT
Mailing Address: P.O. Box 144820 • Salt Lake City, UT 84114-4820
Telephone (801) 536-4000 • Fax (801)536-4099 • T.D.D. (801) 536-4414
www.deq.utah.gov
Printed on 100% recycled paper

Source	Channel	Start up & Shutdown	Control Equipment Problems	Process Problems	Other Known Causes	Unknown Causes	Emission Limit
Unit 1	NOx	0	0	0	0	0	0.46 lb/mmbtu - 30 DRA
Unit 1	Opacity	23.8	0	0	0	0	20 % - 6 min.
Unit 1	SO2	0	0	0	0	0	0.138 lb/mmbtu - 30 DRA
Unit 2	NOx	0	0	0	0	0	0.46 lb/mmbtu - 30 DRA
Unit 2	Opacity	24.7	0	0	0	0	20 % - 6 min.
Unit 2	SO2	0	0	0	0	0	0.138 lb/mmbtu - 30 DRA

CMS Performance Summary - Hourly Summary						
Source	Channel	Monitor Malfunction	Non-monitor Malfunction	QA Calibrations	Other Known Causes	Unknown Causes
Unit 1	CO2	5.00	0.00	3.00	7.00	0.00
Unit 1	CO2	16.00	0.00	4.00	11.00	0.00
Unit 1	NOx	16.00	0.00	4.00	11.00	0.00
Unit 1	Opacity	24.00	0.00	6.70	0.00	0.00
Unit 1	SO2	5.00	0.00	3.00	7.00	0.00
Unit 1	SO2	16.00	0.00	4.00	11.00	0.00
Unit 2	CO2	2.00	0.00	2.00	27.00	0.00
Unit 2	CO2	4.00	0.00	3.00	26.00	0.00
Unit 2	NOx	4.00	0.00	3.00	26.00	0.00
Unit 2	Opacity	0.00	0.00	9.20	0.20	0.00
Unit 2	SO2	2.00	0.00	2.00	27.00	0.00
Unit 2	SO2	4.00	0.00	3.00	26.00	0.00

Pollutant Concentration Exceeded Span of CEM	Monitor Outage During Source Operation	Alternate Sampling	CEM Modifications
0.00 Hours	324.10 Hours	0.00 Hours	8.00 Events

Your cooperation in this and all environmental matters is appreciated. If you have any questions regarding the Continuous Emissions Monitoring Program, contact Norman Erikson at (801) 536-4063.

Sincerely,

Rusty Ruby

Rusty Ruby, Manager
Air Standards Branch
Division of Air Quality

RR:NAE:lk

cc: Central Utah Health Department

*EPA Request dated Oct 12, 2010, for Information Pursuant to Section 114 . Response #16 of 17 of Appendix B.

State of Utah

GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF AIR QUALITY
Cheryl Heying
Director

JAF
NOV 22 2010

November 18, 2010

DAQC-1259-10
Site ID 10327 (B5)

Jon A. Finlinson
IPP
850 W. Brush Wellman Rd.
Delta, UT 84624-9546

Dear Mr. Finlinson:

Re: IPP - Amended Second Quarter 2009 - State Electronic Data Report (SEDR), Millard County - AIRS # 027 00010

Your SEDR was reviewed and appears to conform to the intent of Utah Administrative Code (UAC) R307-170. The Utah Division of Air Quality (DAQ) understands that the following conditions existed during this reporting period.

If you are in disagreement with these conclusions, notify the DAQ immediately.

% Monitor Availability				Excess Emissions Summary (Start-up/Shutdown Excluded)			
Source	Channel	Percent Availability	Percent QA Calibrations	Source	Channel	Hours	Percent
Unit 1	CO2	99.06%	0.19%	Unit 1	NOx	0.00	0.00%
Unit 1	CO2	98.06%	0.25%	Unit 1	Opacity	0.00	0.00%
Unit 1	NOx	98.06%	0.25%	Unit 1	SO2	0.00	0.00%
Unit 1	Opacity	98.08%	0.42%	Unit 2	NOx	0.00	0.00%
Unit 1	SO2	99.06%	0.19%	Unit 2	Opacity	0.00	0.00%
Unit 1	SO2	98.06%	0.25%	Unit 2	SO2	0.00	0.00%
Unit 2	CO2	98.47%	0.10%				
Unit 2	CO2	98.37%	0.15%				
Unit 2	NOx	98.37%	0.15%				
Unit 2	Opacity	99.54%	0.45%				
Unit 2	SO2	98.47%	0.10%				
Unit 2	SO2	98.37%	0.15%				

195 North 1950 West • Salt Lake City, UT
Mailing Address: P.O. Box 144820 • Salt Lake City, UT 84114-4820
Telephone (801) 536-4000 • Fax (801) 536-4099 • T.D.D. (801) 536-4414
www.deq.utah.gov
Printed on 100% recycled paper

Excess Emission Report - Hourly Summary							
Source	Channel	Start up & Shutdown	Control Equipment Problems	Process Problems	Other Known Causes	Unknown Causes	Emission Limit
Unit 1	NOx	0	0	0	0	0	0.46 lb/mmbtu - 30 DRA
Unit 1	Opacity	23.8	0	0	0	0	20 % - 6 min.
Unit 1	SO2	0	0	0	0	0	0.138 lb/mmbtu - 30 DRA
Unit 2	NOx	0	0	0	0	0	0.46 lb/mmbtu - 30 DRA
Unit 2	Opacity	24.7	0	0	0	0	20 % - 6 min.
Unit 2	SO2	0	0	0	0	0	0.138 lb/mmbtu - 30 DRA

CMS Performance Summary - Hourly Summary						
Source	Channel	Monitor Malfunction	Non-monitor Malfunction	QA Calibrations	Other Known Causes	Unknown Causes
Unit 1	CO2	5.00	0.00	3.00	7.00	0.00
Unit 1	CO2	16.00	0.00	4.00	11.00	0.00
Unit 1	NOx	16.00	0.00	4.00	11.00	0.00
Unit 1	Opacity	24.00	0.00	6.70	0.00	0.00
Unit 1	SO2	5.00	0.00	3.00	7.00	0.00
Unit 1	SO2	16.00	0.00	4.00	11.00	0.00
Unit 2	CO2	2.00	0.00	2.00	27.00	0.00
Unit 2	CO2	4.00	0.00	3.00	26.00	0.00
Unit 2	NOx	4.00	0.00	3.00	26.00	0.00
Unit 2	Opacity	0.00	0.00	9.20	0.20	0.00
Unit 2	SO2	2.00	0.00	2.00	27.00	0.00
Unit 2	SO2	4.00	0.00	3.00	26.00	0.00

Pollutant Concentration Exceeded Span of CEM	Monitor Outage During Source Operation	Alternate Sampling	CEM Modifications
0.00 Hours	324.10 Hours	0.00 Hours	8.00 Events

Your cooperation in this and all environmental matters is appreciated. If you have any questions regarding the Continuous Emissions Monitoring Program, contact Norman Erikson at (801) 536-4063.

Sincerely,

Rusty Ruby, Manager
Compliance Branch
Division of Air Quality

RR:NAE:lk

cc: Central Utah Health Department

100 George W. C IPP 850 W Brush Delta UT 846 027 00010 435-864-441· Jon Christensen

110 Unit 1		2	2009	1596						
200 Unit 1	InletSO2	TECO	43i		534613720	500	1000	11/27/2005		Scrubber Inlet
200 Unit 1	InletCO2	TECO	410i		834333318	20		4/6/2009		Scrubber Inlet
200 Unit 1	Opacity	Phoenix Instr	OPAC 20/20		OPAC-1203	100		8/27/2008		Scrubber Inlet
200 Unit 1	OutletSO2	TECO	43i		534613714	50	1000	11/28/2005		Stack
200 Unit 1	OutletNOx	TECO	42i		534613722	500	1000	11/28/2005		Stack
200 Unit 1	OutletCO2	TECO	410i		834333319	20		4/15/2009		Stack
220 Unit 1	InletSO2	4/26/2009		8:00	4/26/2009	9:00	724	724C		N
220 Unit 1	InletCO2	4/26/2009		8:00	4/26/2009	9:00	724	724C		N
220 Unit 1	InletSO2	4/29/2009		9:00	4/29/2009	12:00	723	723A		N
220 Unit 1	InletCO2	4/29/2009		9:00	4/29/2009	12:00	723	723A		N
220 Unit 1	InletSO2	5/4/2009		15:00	5/4/2009	16:00	724	724C		N
220 Unit 1	InletCO2	5/4/2009		15:00	5/4/2009	16:00	724	724C		N
220 Unit 1	InletSO2	5/5/2009		3:00	5/5/2009	8:00	721	721E		Y
220 Unit 1	InletCO2	5/5/2009		3:00	5/5/2009	8:00	721	721E		Y
220 Unit 1	InletSO2	5/17/2009		6:00	5/17/2009	11:00	724	724C		N
220 Unit 1	InletCO2	5/17/2009		6:00	5/17/2009	11:00	724	724C		N
220 Unit 1	OutletSO2	4/26/2009		13:00	4/26/2009	14:00	724	724C		N
220 Unit 1	OutletNOx	4/26/2009		13:00	4/26/2009	14:00	724	724C		N
220 Unit 1	OutletCO2	4/26/2009		13:00	4/26/2009	14:00	724	724C		N
220 Unit 1	OutletSO2	4/27/2009		9:00	4/27/2009	11:00	724	724C		N
220 Unit 1	OutletNOx	4/27/2009		9:00	4/27/2009	11:00	724	724C		N
220 Unit 1	OutletCO2	4/27/2009		9:00	4/27/2009	11:00	724	724C		N
220 Unit 1	OutletSO2	4/27/2009		17:00	4/27/2009	22:00	724	724C		N
220 Unit 1	OutletNOx	4/27/2009		17:00	4/27/2009	22:00	724	724C		N
220 Unit 1	OutletCO2	4/27/2009		17:00	4/27/2009	22:00	724	724C		N
220 Unit 1	OutletSO2	4/28/2009		2:00	4/28/2009	6:00	721	721E		Y
220 Unit 1	OutletNOx	4/28/2009		2:00	4/28/2009	6:00	721	721E		N
220 Unit 1	OutletCO2	4/28/2009		2:00	4/28/2009	6:00	721	721E		N
220 Unit 1	OutletSO2	4/28/2009		16:00	4/28/2009	17:00	724	724C		N
220 Unit 1	OutletNOx	4/28/2009		16:00	4/28/2009	17:00	724	724C		N
220 Unit 1	OutletCO2	4/28/2009		16:00	4/28/2009	17:00	724	724C		N
220 Unit 1	OutletSO2	4/28/2009		19:00	4/28/2009	23:00	723	723A		N
220 Unit 1	OutletNOx	4/28/2009		19:00	4/28/2009	23:00	723	723A		N
220 Unit 1	OutletCO2	4/28/2009		19:00	4/28/2009	23:00	723	723A		N
220 Unit 1	OutletSO2	5/2/2009		2:00	5/2/2009	5:00	721	721E		Y
220 Unit 1	OutletNOx	5/2/2009		2:00	5/2/2009	5:00	721	721E		Y
220 Unit 1	OutletCO2	5/2/2009		2:00	5/2/2009	5:00	721	721E		N
220 Unit 1	OutletSO2	5/4/2009		2:00	5/4/2009	5:00	721	721E		Y
220 Unit 1	OutletNOx	5/4/2009		2:00	5/4/2009	5:00	721	721E		Y
220 Unit 1	OutletCO2	5/4/2009		2:00	5/4/2009	5:00	721	721E		N
220 Unit 1	OutletSO2	5/5/2009		18:00	5/5/2009	19:00	724	724C		N
220 Unit 1	OutletNOx	5/5/2009		18:00	5/5/2009	19:00	724	724C		N
220 Unit 1	OutletCO2	5/5/2009		18:00	5/5/2009	19:00	724	724C		N
220 Unit 1	OutletSO2	5/30/2009		2:00	5/30/2009	4:00	721	721E		Y
220 Unit 1	OutletNOx	5/30/2009		2:00	5/30/2009	4:00	721	721E		Y
220 Unit 1	OutletCO2	5/30/2009		2:00	5/30/2009	4:00	721	721E		Y
220 Unit 1	OutletSO2	6/26/2009		2:00	6/26/2009	6:00	721	721E		Y
220 Unit 1	OutletNOx	6/26/2009		2:00	6/26/2009	6:00	721	721E		Y
220 Unit 1	OutletCO2	6/26/2009		2:00	6/26/2009	6:00	721	721E		N
220 Unit 1	OutletSO2	6/26/2009		6:00	6/26/2009	7:00	724	724C		N

220 Unit 1	OutletNOx	6/26/2009	6:00	6/26/2009	7:00	724	724C	N
220 Unit 1	OutletCO2	6/26/2009	6:00	6/26/2009	7:00	724	724C	N
220 Unit 1	Opacity	4/25/2009	8:00	4/25/2009	8:06	723	723C	
220 Unit 1	Opacity	4/26/2009	8:00	4/26/2009	8:06	723	723C	
220 Unit 1	Opacity	4/27/2009	8:00	4/27/2009	8:06	723	723C	
220 Unit 1	Opacity	4/28/2009	8:00	4/28/2009	8:06	723	723C	
220 Unit 1	Opacity	4/29/2009	8:00	4/29/2009	8:06	723	723C	
220 Unit 1	Opacity	4/30/2009	8:00	4/30/2009	8:06	723	723C	
220 Unit 1	Opacity	5/1/2009	8:00	5/1/2009	8:06	723	723C	
220 Unit 1	Opacity	5/2/2009	8:00	5/2/2009	8:06	723	723C	
220 Unit 1	Opacity	5/3/2009	8:00	5/3/2009	8:06	723	723C	
220 Unit 1	Opacity	5/4/2009	8:00	5/4/2009	8:06	723	723C	
220 Unit 1	Opacity	5/5/2009	8:00	5/5/2009	8:06	723	723C	
220 Unit 1	Opacity	5/6/2009	8:00	5/6/2009	8:06	723	723C	
220 Unit 1	Opacity	5/7/2009	8:00	5/7/2009	8:06	723	723C	
220 Unit 1	Opacity	5/8/2009	8:00	5/8/2009	8:06	723	723C	
220 Unit 1	Opacity	5/9/2009	8:00	5/9/2009	8:06	723	723C	
220 Unit 1	Opacity	5/10/2009	8:00	5/10/2009	8:06	723	723C	
220 Unit 1	Opacity	5/11/2009	8:00	5/11/2009	8:06	723	723C	
220 Unit 1	Opacity	5/12/2009	8:00	5/12/2009	8:06	723	723C	
220 Unit 1	Opacity	5/13/2009	8:00	5/13/2009	8:06	723	723C	
220 Unit 1	Opacity	5/14/2009	8:00	5/14/2009	8:06	723	723C	
220 Unit 1	Opacity	5/15/2009	8:00	5/15/2009	8:06	723	723C	
220 Unit 1	Opacity	5/16/2009	8:00	5/16/2009	8:06	723	723C	
220 Unit 1	Opacity	5/17/2009	8:00	5/18/2009	0:00	721	721A	
220 Unit 1	Opacity	5/18/2009	0:00	5/18/2009	8:00	721	721A	
220 Unit 1	Opacity	5/18/2009	8:00	5/18/2009	8:06	723	723C	
220 Unit 1	Opacity	5/19/2009	8:00	5/19/2009	8:06	723	723C	
220 Unit 1	Opacity	5/20/2009	8:00	5/20/2009	8:06	723	723C	
220 Unit 1	Opacity	5/21/2009	8:00	5/21/2009	8:06	723	723C	
220 Unit 1	Opacity	5/22/2009	8:00	5/22/2009	8:06	723	723C	
220 Unit 1	Opacity	5/23/2009	8:00	5/23/2009	8:06	723	723C	
220 Unit 1	Opacity	5/24/2009	8:00	5/24/2009	8:06	723	723C	
220 Unit 1	Opacity	5/25/2009	8:00	5/25/2009	8:06	723	723C	
220 Unit 1	Opacity	5/26/2009	8:00	5/26/2009	8:06	723	723C	
220 Unit 1	Opacity	5/27/2009	8:00	5/27/2009	8:06	723	723C	
220 Unit 1	Opacity	5/28/2009	8:00	5/28/2009	8:06	723	723C	
220 Unit 1	Opacity	5/29/2009	8:00	5/29/2009	8:06	723	723C	
220 Unit 1	Opacity	5/30/2009	8:00	5/30/2009	8:06	723	723C	
220 Unit 1	Opacity	5/31/2009	8:00	5/31/2009	8:06	723	723C	
220 Unit 1	Opacity	6/1/2009	8:00	6/1/2009	8:06	723	723C	
220 Unit 1	Opacity	6/2/2009	8:00	6/2/2009	8:06	723	723C	
220 Unit 1	Opacity	6/3/2009	6:00	6/3/2009	6:06	723	723C	
220 Unit 1	Opacity	6/3/2009	8:00	6/3/2009	8:06	723	723C	
220 Unit 1	Opacity	6/4/2009	6:00	6/4/2009	6:06	723	723C	
220 Unit 1	Opacity	6/5/2009	6:00	6/5/2009	6:06	723	723C	
220 Unit 1	Opacity	6/6/2009	6:00	6/6/2009	6:06	723	723C	
220 Unit 1	Opacity	6/7/2009	6:00	6/7/2009	6:06	723	723C	
220 Unit 1	Opacity	6/8/2009	6:00	6/8/2009	6:06	723	723C	
220 Unit 1	Opacity	6/9/2009	5:00	6/9/2009	5:06	723	723C	
220 Unit 1	Opacity	6/10/2009	5:00	6/10/2009	5:06	723	723C	
220 Unit 1	Opacity	6/11/2009	5:00	6/11/2009	5:06	723	723C	

220	Unit 1	Opacity	6/12/2009		5:00	6/12/2009	5:06	723	723C						
220	Unit 1	Opacity	6/13/2009		5:00	6/13/2009	5:06	723	723C						
220	Unit 1	Opacity	6/14/2009		5:00	6/14/2009	5:06	723	723C						
220	Unit 1	Opacity	6/15/2009		5:00	6/15/2009	5:06	723	723C						
220	Unit 1	Opacity	6/16/2009		5:00	6/16/2009	5:06	723	723C						
220	Unit 1	Opacity	6/17/2009		5:00	6/17/2009	5:06	723	723C						
220	Unit 1	Opacity	6/18/2009		5:00	6/18/2009	5:06	723	723C						
220	Unit 1	Opacity	6/19/2009		5:00	6/19/2009	5:06	723	723C						
220	Unit 1	Opacity	6/20/2009		5:00	6/20/2009	5:06	723	723C						
220	Unit 1	Opacity	6/21/2009		5:00	6/21/2009	5:06	723	723C						
220	Unit 1	Opacity	6/22/2009		5:00	6/22/2009	5:06	723	723C						
220	Unit 1	Opacity	6/23/2009		5:00	6/23/2009	5:06	723	723C						
220	Unit 1	Opacity	6/24/2009		5:00	6/24/2009	5:06	723	723C						
220	Unit 1	Opacity	6/25/2009		5:00	6/25/2009	5:06	723	723C						
220	Unit 1	Opacity	6/26/2009		5:00	6/26/2009	5:06	723	723C						
220	Unit 1	Opacity	6/27/2009		5:00	6/27/2009	5:06	723	723C						
220	Unit 1	Opacity	6/28/2009		5:00	6/28/2009	5:06	723	723C						
220	Unit 1	Opacity	6/29/2009		5:00	6/29/2009	5:06	723	723C						
220	Unit 1	Opacity	6/30/2009		5:00	6/30/2009	5:06	723	723C						
240	Unit 1	InletCO2	4/8/2009	Y		CO2 analyzer was replaced. Seven day drift test and the linearity and cylinder gas audit was performed within 168 hours after the unit was on line. See attached seven day drift file u1_inletCO2_7daytdrft.									
240	Unit 1	OutletCO2	4/10/2009	Y		CO2 analyzer was replaced. Seven day drift test and the linearity and cylinder gas audit was performed within 168 hours after the unit was on line. See attached seven day drift file u1_outletCO2_7daytdrft.									
240	Unit 1	InletProbe	4/21/2009	Y		The Inlet S1 sample conditioning system or the probe was replaced with a Perma Pure model 4P45XI SN4P04160904 dilution probe.									
240	Unit 1	OutletProbe	4/21/2009	Y		The Outlet U1 sample conditioning system or the probe was replaced with a Perma Pure model 4P45XI SN 4P04160903 dilution probe.									
250	Unit 1	InletSO2	5/7/2009	11/19/2008		6	lbs/mmbtu	1.498	1.497	0.68%	Pass				
250	Unit 1	InletCO2	5/7/2009	11/19/2008		6	%CO2	13.19	13.26	1.13%	Pass				
250	Unit 1	OutletSO2	5/8/2009	11/13/2008		6	lbs/mmbtu	0.12	0.111	9.73%	Pass				
250	Unit 1	OutletNOx	5/8/2009	11/13/2008		6	lbs/mmbtu	0.442	0.427	4.26%	Pass				
250	Unit 1	OutletCO2	5/8/2009	11/13/2008		6	%CO2	12.49	12.1	3.92%	Pass				
260	Unit 1	InletSO2	4/29/2009		1	CC86178	1/8/2010	P1	PPM	127.23	126	0.96%	P	LOW	
260	Unit 1	InletCO2	4/29/2009		1	CC86178	1/8/2010	P1	PERCENT	5.51	5.12	7.70%	P	LOW	
260	Unit 1	InletSO2	4/29/2009		1	CC246353	2/6/2010	P1	PPM	281.12	276	1.86%	P	HIGH	
260	Unit 1	InletSO2	4/29/2009		2	CC246353	2/6/2010	P1	PPM	275.78	276	-0.08%	P	LOW	
260	Unit 1	InletCO2	4/29/2009		2	CC131734	10/29/2010	P1	PERCENT	11.57	11.12	4.08%	P	LOW	
260	Unit 1	InletSO2	4/29/2009		2	CC187334	4/2/2010	P1	PPM	559.86	554	1.06%	P	HIGH	
260	Unit 1	OutletSO2	4/28/2009		1	CC246105	8/22/2010	P1	PPM	11.94	12.6	-5.26%	P	LOW	
260	Unit 1	OutletNOx	4/28/2009		1	CC246105	8/22/2010	P1	PPM	129.8	126	3.02%	P	LOW	
260	Unit 1	OutletCO2	4/28/2009		1	CC246105	8/22/2010	P1	PERCENT	5.28	5.1	3.59%	P	LOW	
260	Unit 1	OutletSO2	4/28/2009		1	CC246353	2/6/2010	P1	PPM	277.78	276	0.64%	P	HIGH	
260	Unit 1	OutletNOx	4/28/2009		1	CC246353	2/6/2010	P1	PPM	277.32	278	-0.25%	P	HIGH	
260	Unit 1	OutletSO2	4/28/2009		2	CC131734	10/29/2010	P1	PPM	26.82	27.8	-3.54%	P	LOW	
260	Unit 1	OutletNOx	4/28/2009		2	CC131734	10/29/2010	P1	PPM	274.45	278	-0.20%	P	LOW	
260	Unit 1	OutletCO2	4/28/2009		2	CC131734	10/29/2010	P1	PERCENT	11.13	11.12	0.11%	P	LOW	
260	Unit 1	OutletSO2	4/28/2009		2	CC187334	4/2/2010	P1	PPM	550.37	554	-0.66%	P	HIGH	
260	Unit 1	OutletNOx	4/28/2009		2	CC187334	4/2/2010	P1	PPM	546.21	551	-0.87%	P	HIGH	
270	Unit 1	OutletSO2	4/28/2009	Low		CC246105	8/22/2010	P1	PPM	11.94	12.6	0.66	P	LOW	
270	Unit 1	OutletNOx	4/28/2009	Low		CC246105	8/22/2010	P1	PPM	129.8	126	3.02	P	LOW	
270	Unit 1	OutletCO2	4/28/2009	Low		CC246105	8/22/2010	P1	PERCENT	5.28	5.1	3.59	P	LOW	
270	Unit 1	OutletSO2	4/28/2009	Low		CC246353	2/6/2010	P1	PPM	277.78	276	0.64	P	HIGH	
270	Unit 1	OutletNOx	4/28/2009	Low		CC246353	2/6/2010	P1	PPM	277.32	278	0.25	P	HIGH	
270	Unit 1	OutletSO2	4/28/2009	Mid		CC131734	10/29/2010	P1	PPM	26.82	27.8	3.54	P	LOW	
270	Unit 1	OutletNOx	4/28/2009	Mid		CC131734	10/29/2010	P1	PPM	274.45	275	0.2	P	LOW	
270	Unit 1	OutletCO2	4/28/2009	Mid		CC131734	10/29/2010	P1	PERCENT	11.13	11.12	0.11	P	LOW	

270 Unit 1	OutletSO2	4/28/2009 Mid		CC187334	4/2/2010 P1		PPM		550.37	554	0.66 P		HIGH
270 Unit 1	OutletNOx	4/28/2009 Mid		CC187334	4/2/2010 P1		PPM		546.21	551	0.87 P		HIGH
270 Unit 1	OutletSO2	4/28/2009 High		CC111230	10/9/2009 P1		PPM		40.37	41.4	2.48 P		LOW
270 Unit 1	OutletNOx	4/28/2009 High		CC111230	10/9/2009 P1		PPM		429.95	432	0.48 P		LOW
270 Unit 1	OutletCO2	4/28/2009 High		CC111230	10/9/2009 P1		PERCENT		18.73	18.73	0 P		LOW
270 Unit 1	OutletSO2	4/28/2009 High		CC200320	10/27/2009 P1		PPM		889	884	0.78 P		HIGH
270 Unit 1	OutletNOx	4/28/2009 High		CC200320	10/27/2009 P1		PPM		891.13	886	1.2 P		HIGH
300 Unit 1	InletSO2		0.94%	15	5	0	3	7	0				
300 Unit 1	InletCO2		0.94%	15	5	0	3	7	0				
300 Unit 1	Opacity		1.92%	30.7	24	0	6.7	0	0				
300 Unit 1	OutletSO2		1.94%	31	16	0	4	11	0				
300 Unit 1	OutletNOx		1.94%	31	16	0	4	11	0				
300 Unit 1	OutletCO2		1.94%	31	16	0	4	11	0				
310 Unit 1	Opacity	23.8	1.49%	23.8	0	0	0	0	20	%		6 min.	
310 Unit 1	SO2	0	0.00%	0	0	0	0	0	0.138	lb/mmbtu		30 DRA	
310 Unit 1	NOx	0	0.00%	0	0	0	0	0	0.46	lb/mmblu		30 DRA	
400 Unit 1	4/25/2009	8:18	44	701	701A								
400 Unit 1	4/25/2009	8:24	67	701	701A								
400 Unit 1	4/25/2009	8:30	67	701	701A								
400 Unit 1	4/25/2009	8:36	67	701	701A								
400 Unit 1	4/25/2009	8:42	68	701	701A								
400 Unit 1	4/25/2009	8:48	68	701	701A								
400 Unit 1	4/25/2009	8:54	68	701	701A								
400 Unit 1	4/25/2009	9:00	67	701	701A								
400 Unit 1	4/25/2009	9:06	66	701	701A								
400 Unit 1	4/25/2009	9:12	64	701	701A								
400 Unit 1	4/25/2009	9:18	63	701	701A								
400 Unit 1	4/25/2009	9:24	66	701	701A								
400 Unit 1	4/25/2009	9:30	65	701	701A								
400 Unit 1	4/25/2009	9:36	64	701	701A								
400 Unit 1	4/25/2009	9:42	64	701	701A								
400 Unit 1	4/25/2009	9:48	64	701	701A								
400 Unit 1	4/25/2009	9:54	64	701	701A								
400 Unit 1	4/25/2009	10:00	64	701	701A								
400 Unit 1	4/25/2009	10:06	64	701	701A								
400 Unit 1	4/25/2009	10:12	64	701	701A								
400 Unit 1	4/25/2009	10:18	64	701	701A								
400 Unit 1	4/25/2009	10:24	64	701	701A								
400 Unit 1	4/25/2009	10:30	64	701	701A								
400 Unit 1	4/25/2009	10:36	64	701	701A								
400 Unit 1	4/25/2009	10:42	64	701	701A								
400 Unit 1	4/25/2009	10:48	64	701	701A								
400 Unit 1	4/25/2009	10:54	64	701	701A								
400 Unit 1	4/25/2009	11:00	64	701	701A								
400 Unit 1	4/25/2009	11:06	64	701	701A								
400 Unit 1	4/25/2009	11:12	64	701	701A								
400 Unit 1	4/25/2009	11:18	64	701	701A								
400 Unit 1	4/25/2009	11:24	64	701	701A								
400 Unit 1	4/25/2009	11:30	64	701	701A								
400 Unit 1	4/25/2009	11:36	64	701	701A								
400 Unit 1	4/25/2009	11:42	64	701	701A								
400 Unit 1	4/25/2009	11:48	64	701	701A								

400 Unit 1	4/25/2009	11:54	64	701 701A
400 Unit 1	4/25/2009	12:00	64	701 701A
400 Unit 1	4/25/2009	12:06	64	701 701A
400 Unit 1	4/25/2009	12:12	64	701 701A
400 Unit 1	4/25/2009	12:18	64	701 701A
400 Unit 1	4/25/2009	12:24	64	701 701A
400 Unit 1	4/25/2009	12:30	64	701 701A
400 Unit 1	4/25/2009	12:36	64	701 701A
400 Unit 1	4/25/2009	12:42	64	701 701A
400 Unit 1	4/25/2009	12:48	64	701 701A
400 Unit 1	4/25/2009	12:54	64	701 701A
400 Unit 1	4/25/2009	13:00	64	701 701A
400 Unit 1	4/25/2009	13:06	64	701 701A
400 Unit 1	4/25/2009	13:12	64	701 701A
400 Unit 1	4/25/2009	13:18	62	701 701A
400 Unit 1	4/25/2009	13:24	62	701 701A
400 Unit 1	4/25/2009	13:30	62	701 701A
400 Unit 1	4/25/2009	13:36	64	701 701A
400 Unit 1	4/25/2009	13:42	64	701 701A
400 Unit 1	4/25/2009	13:48	64	701 701A
400 Unit 1	4/25/2009	13:54	64	701 701A
400 Unit 1	4/25/2009	14:00	64	701 701A
400 Unit 1	4/25/2009	14:06	64	701 701A
400 Unit 1	4/25/2009	14:12	64	701 701A
400 Unit 1	4/25/2009	14:18	64	701 701A
400 Unit 1	4/25/2009	14:24	64	701 701A
400 Unit 1	4/25/2009	14:30	64	701 701A
400 Unit 1	4/25/2009	14:36	65	701 701A
400 Unit 1	4/25/2009	14:42	65	701 701A
400 Unit 1	4/25/2009	14:48	65	701 701A
400 Unit 1	4/25/2009	14:54	65	701 701A
400 Unit 1	4/25/2009	15:00	65	701 701A
400 Unit 1	4/25/2009	15:06	65	701 701A
400 Unit 1	4/25/2009	15:12	65	701 701A
400 Unit 1	4/25/2009	15:18	65	701 701A
400 Unit 1	4/25/2009	15:24	65	701 701A
400 Unit 1	4/25/2009	15:30	64	701 701A
400 Unit 1	4/25/2009	15:36	64	701 701A
400 Unit 1	4/25/2009	15:42	64	701 701A
400 Unit 1	4/25/2009	15:48	64	701 701A
400 Unit 1	4/25/2009	15:54	64	701 701A
400 Unit 1	4/25/2009	16:00	64	701 701A
400 Unit 1	4/25/2009	16:06	63	701 701A
400 Unit 1	4/25/2009	16:12	63	701 701A
400 Unit 1	4/25/2009	16:18	63	701 701A
400 Unit 1	4/25/2009	16:24	62	701 701A
400 Unit 1	4/25/2009	16:30	62	701 701A
400 Unit 1	4/25/2009	16:36	62	701 701A
400 Unit 1	4/25/2009	16:42	63	701 701A
400 Unit 1	4/25/2009	16:48	63	701 701A
400 Unit 1	4/25/2009	16:54	63	701 701A
400 Unit 1	4/25/2009	17:00	63	701 701A

400 Unit 1	4/25/2009	17:06	63	701 701A
400 Unit 1	4/25/2009	17:12	63	701 701A
400 Unit 1	4/25/2009	17:18	63	701 701A
400 Unit 1	4/25/2009	17:24	63	701 701A
400 Unit 1	4/25/2009	17:30	63	701 701A
400 Unit 1	4/25/2009	17:36	63	701 701A
400 Unit 1	4/25/2009	17:42	63	701 701A
400 Unit 1	4/25/2009	17:48	63	701 701A
400 Unit 1	4/25/2009	17:54	54	701 701A
400 Unit 1	4/25/2009	18:00	63	701 701A
400 Unit 1	4/25/2009	18:06	63	701 701A
400 Unit 1	4/25/2009	18:12	63	701 701A
400 Unit 1	4/25/2009	18:18	62	701 701A
400 Unit 1	4/25/2009	18:24	61	701 701A
400 Unit 1	4/25/2009	18:30	61	701 701A
400 Unit 1	4/25/2009	18:36	61	701 701A
400 Unit 1	4/25/2009	18:42	61	701 701A
400 Unit 1	4/25/2009	18:48	61	701 701A
400 Unit 1	4/25/2009	18:54	61	701 701A
400 Unit 1	4/25/2009	19:00	62	701 701A
400 Unit 1	4/25/2009	19:06	63	701 701A
400 Unit 1	4/25/2009	19:12	62	701 701A
400 Unit 1	4/25/2009	19:18	63	701 701A
400 Unit 1	4/25/2009	19:24	63	701 701A
400 Unit 1	4/25/2009	19:30	63	701 701A
400 Unit 1	4/25/2009	19:36	63	701 701A
400 Unit 1	4/25/2009	19:42	62	701 701A
400 Unit 1	4/25/2009	19:48	62	701 701A
400 Unit 1	4/25/2009	19:54	62	701 701A
400 Unit 1	4/25/2009	20:00	61	701 701A
400 Unit 1	4/25/2009	20:06	60	701 701A
400 Unit 1	4/25/2009	20:12	60	701 701A
400 Unit 1	4/25/2009	20:18	60	701 701A
400 Unit 1	4/25/2009	20:24	60	701 701A
400 Unit 1	4/25/2009	20:30	59	701 701A
400 Unit 1	4/25/2009	20:36	59	701 701A
400 Unit 1	4/25/2009	20:42	59	701 701A
400 Unit 1	4/25/2009	20:48	59	701 701A
400 Unit 1	4/25/2009	20:54	59	701 701A
400 Unit 1	4/25/2009	21:00	59	701 701A
400 Unit 1	4/25/2009	21:06	59	701 701A
400 Unit 1	4/25/2009	21:12	59	701 701A
400 Unit 1	4/25/2009	21:18	59	701 701A
400 Unit 1	4/25/2009	21:24	59	701 701A
400 Unit 1	4/25/2009	21:30	59	701 701A
400 Unit 1	4/25/2009	21:36	59	701 701A
400 Unit 1	4/25/2009	21:42	59	701 701A
400 Unit 1	4/25/2009	21:48	59	701 701A
400 Unit 1	4/25/2009	21:54	59	701 701A
400 Unit 1	4/25/2009	22:00	59	701 701A
400 Unit 1	4/25/2009	22:06	58	701 701A
400 Unit 1	4/25/2009	22:12	58	701 701A

400 Unit 1	4/25/2009	22:18	59	701 701A
400 Unit 1	4/25/2009	22:24	59	701 701A
400 Unit 1	4/25/2009	22:30	59	701 701A
400 Unit 1	4/25/2009	22:36	60	701 701A
400 Unit 1	4/25/2009	22:42	60	701 701A
400 Unit 1	4/25/2009	22:48	60	701 701A
400 Unit 1	4/25/2009	22:54	60	701 701A
400 Unit 1	4/25/2009	23:00	60	701 701A
400 Unit 1	4/25/2009	23:06	60	701 701A
400 Unit 1	4/25/2009	23:12	60	701 701A
400 Unit 1	4/25/2009	23:18	60	701 701A
400 Unit 1	4/25/2009	23:24	61	701 701A
400 Unit 1	4/25/2009	23:30	60	701 701A
400 Unit 1	4/25/2009	23:36	61	701 701A
400 Unit 1	4/25/2009	23:42	62	701 701A
400 Unit 1	4/25/2009	23:48	48	701 701A
400 Unit 1	4/26/2009	5:48	62	701 701A
400 Unit 1	4/26/2009	5:54	62	701 701A
400 Unit 1	4/26/2009	6:00	61	701 701A
400 Unit 1	4/26/2009	6:06	61	701 701A
400 Unit 1	4/26/2009	6:12	63	701 701A
400 Unit 1	4/26/2009	6:18	64	701 701A
400 Unit 1	4/26/2009	6:24	64	701 701A
400 Unit 1	4/26/2009	6:30	64	701 701A
400 Unit 1	4/26/2009	6:36	64	701 701A
400 Unit 1	4/26/2009	6:42	64	701 701A
400 Unit 1	4/26/2009	6:48	64	701 701A
400 Unit 1	4/26/2009	6:54	64	701 701A
400 Unit 1	4/26/2009	7:00	64	701 701A
400 Unit 1	4/26/2009	7:06	64	701 701A
400 Unit 1	4/26/2009	7:12	64	701 701A
400 Unit 1	4/26/2009	7:18	65	701 701A
400 Unit 1	4/26/2009	7:24	66	701 701A
400 Unit 1	4/26/2009	7:30	66	701 701A
400 Unit 1	4/26/2009	7:36	65	701 701A
400 Unit 1	4/26/2009	7:42	66	701 701A
400 Unit 1	4/26/2009	7:48	54	701 701A
400 Unit 1	4/26/2009	8:24	39	701 701A
400 Unit 1	4/26/2009	8:30	22	701 701A
400 Unit 1	4/26/2009	9:00	34	701 701A
400 Unit 1	4/26/2009	9:06	30	701 701A
400 Unit 1	4/26/2009	9:12	42	701 701A
400 Unit 1	4/26/2009	9:18	63	701 701A
400 Unit 1	4/26/2009	9:24	64	701 701A
400 Unit 1	4/26/2009	9:30	66	701 701A
400 Unit 1	4/26/2009	9:36	67	701 701A
400 Unit 1	4/26/2009	9:42	67	701 701A
400 Unit 1	4/26/2009	9:48	65	701 701A
400 Unit 1	4/26/2009	9:54	28	701 701A
400 Unit 1	4/26/2009	13:36	48	701 701A
400 Unit 1	4/26/2009	13:42	33	701 701A
400 Unit 1	4/26/2009	13:48	39	701 701A

400 Unit 1	4/26/2009	13:54	66	701 701A
400 Unit 1	4/26/2009	14:00	66	701 701A
400 Unit 1	4/26/2009	14:06	65	701 701A
400 Unit 1	4/26/2009	14:12	66	701 701A
400 Unit 1	4/26/2009	14:18	65	701 701A
400 Unit 1	4/26/2009	14:24	65	701 701A
400 Unit 1	4/26/2009	14:30	65	701 701A
400 Unit 1	4/26/2009	14:36	64	701 701A
400 Unit 1	4/26/2009	14:42	64	701 701A
400 Unit 1	4/26/2009	14:48	64	701 701A
400 Unit 1	4/26/2009	14:54	64	701 701A
400 Unit 1	4/26/2009	15:00	64	701 701A
400 Unit 1	4/26/2009	15:06	64	701 701A
400 Unit 1	4/26/2009	15:12	64	701 701A
400 Unit 1	4/26/2009	15:18	64	701 701A
400 Unit 1	4/26/2009	15:24	64	701 701A
400 Unit 1	4/26/2009	15:30	64	701 701A
400 Unit 1	4/26/2009	15:36	63	701 701A
400 Unit 1	4/26/2009	15:42	64	701 701A
400 Unit 1	4/26/2009	15:48	62	701 701A
400 Unit 1	4/26/2009	15:54	61	701 701A
400 Unit 1	4/26/2009	16:00	61	701 701A
400 Unit 1	4/26/2009	16:06	60	701 701A
400 Unit 1	4/26/2009	16:12	60	701 701A
400 Unit 1	4/26/2009	16:18	59	701 701A
400 Unit 1	4/26/2009	16:24	59	701 701A
400 Unit 1	4/26/2009	16:30	59	701 701A
400 Unit 1	4/26/2009	16:36	58	701 701A
400 Unit 1	4/26/2009	16:42	58	701 701A
400 Unit 1	4/26/2009	16:48	58	701 701A
400 Unit 1	4/26/2009	16:54	58	701 701A
400 Unit 1	4/26/2009	17:00	59	701 701A
400 Unit 1	4/26/2009	17:06	60	701 701A
400 Unit 1	4/26/2009	17:12	62	701 701A
400 Unit 1	4/26/2009	17:18	61	701 701A
400 Unit 1	4/26/2009	17:24	63	701 701A
400 Unit 1	4/26/2009	17:30	63	701 701A
400 Unit 1	4/26/2009	17:36	30	701 701A
400 Unit 1	4/26/2009	18:30	30	701 701A
400 Unit 1	4/26/2009	18:36	21	701 701A
400 Unit 1	4/26/2009	18:42	23	701 701A
400 Unit 1	4/26/2009	18:48	26	701 701A
400 Unit 1	4/26/2009	18:54	21	701 701A
400 Unit 1	4/26/2009	19:00	24	701 701A
400 Unit 1	4/26/2009	19:06	24	701 701A
400 Unit 1	4/26/2009	19:12	21	701 701A
411 Unit 1	4/25/2009	0.07	94	
411 Unit 1	4/26/2009	0.07	94	
411 Unit 1	4/27/2009	0.07	94	
411 Unit 1	4/28/2009	0.07	94	
411 Unit 1	4/29/2009	0.07	94	
411 Unit 1	4/30/2009	0.07	94	

411 Unit 1	5/1/2009	0.08	93
411 Unit 1	5/2/2009	0.08	93
411 Unit 1	5/3/2009	0.08	93
411 Unit 1	5/4/2009	0.08	93
411 Unit 1	5/5/2009	0.08	93
411 Unit 1	5/6/2009	0.08	93
411 Unit 1	5/7/2009	0.08	93
411 Unit 1	5/8/2009	0.08	93
411 Unit 1	5/9/2009	0.09	93
411 Unit 1	5/10/2009	0.09	93
411 Unit 1	5/11/2009	0.09	93
411 Unit 1	5/12/2009	0.09	93
411 Unit 1	5/13/2009	0.09	93
411 Unit 1	5/14/2009	0.09	93
411 Unit 1	5/15/2009	0.09	93
411 Unit 1	5/16/2009	0.09	93
411 Unit 1	5/17/2009	0.09	93
411 Unit 1	5/18/2009	0.09	93
411 Unit 1	5/19/2009	0.09	93
411 Unit 1	5/20/2009	0.09	93
411 Unit 1	5/21/2009	0.09	93
411 Unit 1	5/22/2009	0.09	93
411 Unit 1	5/23/2009	0.09	93
411 Unit 1	5/24/2009	0.09	93
411 Unit 1	5/25/2009	0.09	93
411 Unit 1	5/26/2009	0.09	93
411 Unit 1	5/27/2009	0.09	93
411 Unit 1	5/28/2009	0.09	93
411 Unit 1	5/29/2009	0.1	92
411 Unit 1	5/30/2009	0.09	93
411 Unit 1	5/31/2009	0.09	93
411 Unit 1	6/1/2009	0.09	93
411 Unit 1	6/2/2009	0.09	93
411 Unit 1	6/3/2009	0.09	93
411 Unit 1	6/4/2009	0.09	93
411 Unit 1	6/5/2009	0.09	93
411 Unit 1	6/6/2009	0.08	94
411 Unit 1	6/7/2009	0.08	94
411 Unit 1	6/8/2009	0.08	94
411 Unit 1	6/9/2009	0.08	93
411 Unit 1	6/10/2009	0.08	93
411 Unit 1	6/11/2009	0.08	93
411 Unit 1	6/12/2009	0.08	93
411 Unit 1	6/13/2009	0.08	93
411 Unit 1	6/14/2009	0.07	94
411 Unit 1	6/15/2009	0.07	94
411 Unit 1	6/16/2009	0.07	94
411 Unit 1	6/17/2009	0.07	94
411 Unit 1	6/18/2009	0.07	94
411 Unit 1	6/19/2009	0.07	94
411 Unit 1	6/20/2009	0.07	94
411 Unit 1	6/21/2009	0.07	94

411 Unit 1	6/22/2009	0.07	94
411 Unit 1	6/23/2009	0.07	94
411 Unit 1	6/24/2009	0.07	94
411 Unit 1	6/25/2009	0.07	94
411 Unit 1	6/26/2009	0.07	94
411 Unit 1	6/27/2009	0.07	94
411 Unit 1	6/28/2009	0.07	94
411 Unit 1	6/29/2009	0.07	94
411 Unit 1	6/30/2009	0.07	94
421 Unit 1	4/25/2009	0.36	
421 Unit 1	4/26/2009	0.35	
421 Unit 1	4/27/2009	0.35	
421 Unit 1	4/28/2009	0.35	
421 Unit 1	4/29/2009	0.36	
421 Unit 1	4/30/2009	0.36	
421 Unit 1	5/1/2009	0.36	
421 Unit 1	5/2/2009	0.37	
421 Unit 1	5/3/2009	0.37	
421 Unit 1	5/4/2009	0.37	
421 Unit 1	5/5/2009	0.37	
421 Unit 1	5/6/2009	0.38	
421 Unit 1	5/7/2009	0.38	
421 Unit 1	5/8/2009	0.38	
421 Unit 1	5/9/2009	0.38	
421 Unit 1	5/10/2009	0.39	
421 Unit 1	5/11/2009	0.39	
421 Unit 1	5/12/2009	0.39	
421 Unit 1	5/13/2009	0.39	
421 Unit 1	5/14/2009	0.39	
421 Unit 1	5/15/2009	0.39	
421 Unit 1	5/16/2009	0.39	
421 Unit 1	5/17/2009	0.39	
421 Unit 1	5/18/2009	0.39	
421 Unit 1	5/19/2009	0.39	
421 Unit 1	5/20/2009	0.39	
421 Unit 1	5/21/2009	0.39	
421 Unit 1	5/22/2009	0.39	
421 Unit 1	5/23/2009	0.39	
421 Unit 1	5/24/2009	0.39	
421 Unit 1	5/25/2009	0.39	
421 Unit 1	5/26/2009	0.4	
421 Unit 1	5/27/2009	0.4	
421 Unit 1	5/28/2009	0.4	
421 Unit 1	5/29/2009	0.4	
421 Unit 1	5/30/2009	0.4	
421 Unit 1	5/31/2009	0.4	
421 Unit 1	6/1/2009	0.4	
421 Unit 1	6/2/2009	0.39	
421 Unit 1	6/3/2009	0.39	
421 Unit 1	6/4/2009	0.39	
421 Unit 1	6/5/2009	0.39	
421 Unit 1	6/6/2009	0.39	

421	Unit 1	6/7/2009	0.38							
421	Unit 1	6/8/2009	0.38							
421	Unit 1	6/9/2009	0.38							
421	Unit 1	6/10/2009	0.38							
421	Unit 1	6/11/2009	0.38							
421	Unit 1	6/12/2009	0.37							
421	Unit 1	6/13/2009	0.37							
421	Unit 1	6/14/2009	0.37							
421	Unit 1	6/15/2009	0.37							
421	Unit 1	6/16/2009	0.36							
421	Unit 1	6/17/2009	0.37							
421	Unit 1	6/18/2009	0.37							
421	Unit 1	6/19/2009	0.36							
421	Unit 1	6/20/2009	0.36							
421	Unit 1	6/21/2009	0.36							
421	Unit 1	6/22/2009	0.35							
421	Unit 1	6/23/2009	0.35							
421	Unit 1	6/24/2009	0.35							
421	Unit 1	6/25/2009	0.35							
421	Unit 1	6/26/2009	0.35							
421	Unit 1	6/27/2009	0.35							
421	Unit 1	6/28/2009	0.35							
421	Unit 1	6/29/2009	0.35							
421	Unit 1	6/30/2009	0.35							
500	Unit 1	InletSO2	4/25/2009	724	726A					
500	Unit 1	InletCO2	4/25/2009	724	726A					
500	Unit 1	OutletSO2	4/25/2009	724	726A					
500	Unit 1	OutletNOx	4/25/2009	724	726A					
500	Unit 1	OutletCO2	4/25/2009	724	726A					
500	Unit 1	OutletSO2	4/27/2009	724	724C					
500	Unit 1	OutletNOx	4/27/2009	724	724C					
500	Unit 1	OutletCO2	4/27/2009	724	724C					
500	Unit 1	OutletSO2	4/28/2009	721	721E					
500	Unit 1	OutletNOx	4/28/2009	721	721E					
500	Unit 1	OutletCO2	4/28/2009	721	721E					
500	Unit 1	OutletSO2	4/28/2009	724	724C					
500	Unit 1	OutletNOx	4/28/2009	724	724C					
500	Unit 1	OutletCO2	4/28/2009	724	724C					
500	Unit 1	OutletSO2	4/28/2009	723	723A					
500	Unit 1	OutletNOx	4/28/2009	723	723A					
500	Unit 1	OutletCO2	4/28/2009	723	723A					
510	Unit 1	SO2	1800	Bituminous	19-7, Carbon Dioxide-Based F Factor, Wet Basis					
510	Unit 1	SO2	1800	Bituminous	19-23, Control Device Removal Efficiency					
510	Unit 1	SO2	1800	Bituminous	19-24, Compute average Inlet rate, Formula used as required.					
510	Unit 1	NOx	1800	Bituminous	19-7, Carbon Dioxide-Based F Factor, Wet Basis					
600	Unit 1	YES	YES	YES	YES					
110	Unit 2	2	2009	2026						
200	Unit 2	InletSO2	TECO	43i	534613725	500	1000	11/27/2005	Scrubber Inlet	
200	Unit 2	InletCO2	TECO	410i	834333317	20		4/15/2009	Scrubber Inlet	
200	Unit 2	Opacity	Phoenix	OPAC 20/20	OPAC-1202	100		4/16/2008	Scrubber Inlet	
200	Unit 2	OutletSO2	TECO	43i	534613718	50	1000	11/28/2005	Stack	
200	Unit 2	OutletNOx	TECO	42i	534613723	500	1000	11/28/2005	Stack	

200	Unit 2	OutletCO2	TECO	410i		834333320	20		4/15/2009	Stack
220	Unit 2	InletSO2	4/16/2009		15:00	4/16/2009	17:00	724	724C	N
220	Unit 2	InletCO2	4/16/2009		15:00	4/16/2009	17:00	724	724C	N
220	Unit 2	InletSO2	4/23/2009		20:00	4/23/2009	21:00	724	724C	N
220	Unit 2	InletCO2	4/23/2009		20:00	4/23/2009	21:00	724	724C	N
220	Unit 2	InletSO2	4/25/2009		8:00	4/25/2009	17:00	724	724D	N
220	Unit 2	InletCO2	4/25/2009		8:00	4/25/2009	17:00	724	724D	N
220	Unit 2	InletSO2	4/28/2009		9:00	4/28/2009	11:00	724	724C	N
220	Unit 2	InletCO2	4/28/2009		9:00	4/28/2009	11:00	724	724C	N
220	Unit 2	InletSO2	4/29/2009		13:00	4/29/2009	15:00	723	723A	N
220	Unit 2	InletCO2	4/29/2009		13:00	4/29/2009	15:00	723	723A	N
220	Unit 2	InletSO2	4/29/2009		16:00	4/29/2009	17:00	724	724C	N
220	Unit 2	InletCO2	4/29/2009		16:00	4/29/2009	17:00	724	724C	N
220	Unit 2	InletSO2	5/1/2009		7:00	5/1/2009	8:00	724	724C	N
220	Unit 2	InletCO2	5/1/2009		7:00	5/1/2009	8:00	724	724C	N
220	Unit 2	InletSO2	5/1/2009		10:00	5/1/2009	17:00	724	724C	N
220	Unit 2	InletCO2	5/1/2009		10:00	5/1/2009	17:00	724	724C	N
220	Unit 2	InletSO2	5/1/2009		18:00	5/1/2009	19:00	724	724C	N
220	Unit 2	InletCO2	5/1/2009		18:00	5/1/2009	19:00	724	724C	N
220	Unit 2	InletSO2	5/15/2009		3:00	5/15/2009	5:00	721	721D	N
220	Unit 2	InletCO2	5/15/2009		3:00	5/15/2009	5:00	721	721D	N
220	Unit 2	InletSO2	5/16/2009		9:00	5/16/2009	12:00	724	724C	N
220	Unit 2	InletCO2	5/16/2009		9:00	5/16/2009	12:00	724	724C	N
220	Unit 2	OutletSO2	4/12/2009		4:00	4/12/2009	8:00	721	721C	Y
220	Unit 2	OutletNOx	4/12/2009		4:00	4/12/2009	8:00	721	721C	Y
220	Unit 2	OutletCO2	4/12/2009		4:00	4/12/2009	8:00	721	721C	Y
220	Unit 2	OutletSO2	4/12/2009		8:00	4/12/2009	9:00	724	724C	N
220	Unit 2	OutletNOx	4/12/2009		8:00	4/12/2009	9:00	724	724C	N
220	Unit 2	OutletCO2	4/12/2009		8:00	4/12/2009	9:00	724	724C	N
220	Unit 2	OutletSO2	4/15/2009		7:00	4/15/2009	8:00	724	724A	N
220	Unit 2	OutletNOx	4/15/2009		7:00	4/15/2009	8:00	724	724A	N
220	Unit 2	OutletCO2	4/15/2009		7:00	4/15/2009	8:00	724	724A	N
220	Unit 2	OutletSO2	4/24/2009		9:00	4/24/2009	20:00	724	724D	N
220	Unit 2	OutletNOx	4/24/2009		9:00	4/24/2009	20:00	724	724D	N
220	Unit 2	OutletCO2	4/24/2009		9:00	4/24/2009	20:00	724	724D	N
220	Unit 2	OutletSO2	4/26/2009		11:00	4/26/2009	14:00	724	724C	N
220	Unit 2	OutletNOx	4/26/2009		11:00	4/26/2009	14:00	724	724C	N
220	Unit 2	OutletCO2	4/26/2009		11:00	4/26/2009	14:00	724	724C	N
220	Unit 2	OutletSO2	4/27/2009		13:00	4/27/2009	21:00	724	724C	N
220	Unit 2	OutletNOx	4/27/2009		13:00	4/27/2009	21:00	724	724C	N
220	Unit 2	OutletCO2	4/27/2009		13:00	4/27/2009	21:00	724	724C	N
220	Unit 2	OutletSO2	4/28/2009		14:00	4/28/2009	15:00	724	724C	N
220	Unit 2	OutletNOx	4/28/2009		14:00	4/28/2009	15:00	724	724C	N
220	Unit 2	OutletCO2	4/28/2009		14:00	4/28/2009	15:00	724	724C	N
220	Unit 2	OutletSO2	4/28/2009		19:00	4/28/2009	22:00	723	723A	N
220	Unit 2	OutletNOx	4/28/2009		19:00	4/28/2009	22:00	723	723A	N
220	Unit 2	OutletCO2	4/28/2009		19:00	4/28/2009	22:00	723	723A	N
220	Unit 2	OutletSO2	5/5/2009		18:00	5/5/2009	19:00	724	724C	N
220	Unit 2	OutletNOx	5/5/2009		18:00	5/5/2009	19:00	724	724C	N
220	Unit 2	OutletCO2	5/5/2009		18:00	5/5/2009	19:00	724	724C	N
220	Unit 2	Opacity	4/1/2009		8:00	4/1/2009	8:06	723	723C	
220	Unit 2	Opacity	4/2/2009		8:00	4/2/2009	8:06	723	723C	

220 Unit 2	Opacity	4/3/2009	8:00	4/3/2009	8:06	723 723C
220 Unit 2	Opacity	4/4/2009	8:00	4/4/2009	8:06	723 723C
220 Unit 2	Opacity	4/5/2009	8:00	4/5/2009	8:06	723 723C
220 Unit 2	Opacity	4/6/2009	8:00	4/6/2009	8:06	723 723C
220 Unit 2	Opacity	4/7/2009	8:00	4/7/2009	8:06	723 723C
220 Unit 2	Opacity	4/8/2009	8:00	4/8/2009	8:06	723 723C
220 Unit 2	Opacity	4/9/2009	8:00	4/9/2009	8:06	723 723C
220 Unit 2	Opacity	4/10/2009	8:00	4/10/2009	8:06	723 723C
220 Unit 2	Opacity	4/11/2009	8:00	4/11/2009	8:06	723 723C
220 Unit 2	Opacity	4/12/2009	8:00	4/12/2009	8:06	723 723C
220 Unit 2	Opacity	4/13/2009	8:00	4/13/2009	8:06	723 723C
220 Unit 2	Opacity	4/14/2009	8:00	4/14/2009	8:06	723 723C
220 Unit 2	Opacity	4/14/2009	12:30	4/14/2009	12:36	724 724C
220 Unit 2	Opacity	4/14/2009	12:36	4/14/2009	12:42	723 723C
220 Unit 2	Opacity	4/15/2009	8:00	4/15/2009	8:06	723 723C
220 Unit 2	Opacity	4/16/2009	8:00	4/16/2009	8:06	723 723C
220 Unit 2	Opacity	4/17/2009	8:00	4/17/2009	8:06	723 723C
220 Unit 2	Opacity	4/18/2009	8:00	4/18/2009	8:06	723 723C
220 Unit 2	Opacity	4/19/2009	8:00	4/19/2009	8:06	723 723C
220 Unit 2	Opacity	4/20/2009	8:00	4/20/2009	8:06	723 723C
220 Unit 2	Opacity	4/21/2009	8:00	4/21/2009	8:06	723 723C
220 Unit 2	Opacity	4/22/2009	8:00	4/22/2009	8:06	723 723C
220 Unit 2	Opacity	4/23/2009	8:00	4/23/2009	8:06	723 723C
220 Unit 2	Opacity	4/24/2009	8:00	4/24/2009	8:06	723 723C
220 Unit 2	Opacity	4/25/2009	8:00	4/25/2009	8:06	723 723C
220 Unit 2	Opacity	4/26/2009	8:00	4/26/2009	8:06	723 723C
220 Unit 2	Opacity	4/27/2009	8:00	4/27/2009	8:06	723 723C
220 Unit 2	Opacity	4/28/2009	8:00	4/28/2009	8:06	723 723C
220 Unit 2	Opacity	4/29/2009	8:00	4/29/2009	8:06	723 723C
220 Unit 2	Opacity	4/30/2009	8:00	4/30/2009	8:06	723 723C
220 Unit 2	Opacity	5/1/2009	8:00	5/1/2009	8:06	723 723C
220 Unit 2	Opacity	5/2/2009	8:00	5/2/2009	8:06	723 723C
220 Unit 2	Opacity	5/3/2009	8:00	5/3/2009	8:06	723 723C
220 Unit 2	Opacity	5/4/2009	8:00	5/4/2009	8:06	723 723C
220 Unit 2	Opacity	5/5/2009	8:00	5/5/2009	8:06	723 723C
220 Unit 2	Opacity	5/6/2009	8:00	5/6/2009	8:06	723 723C
220 Unit 2	Opacity	5/7/2009	8:00	5/7/2009	8:06	723 723C
220 Unit 2	Opacity	5/8/2009	8:00	5/8/2009	8:06	723 723C
220 Unit 2	Opacity	5/9/2009	8:00	5/9/2009	8:06	723 723C
220 Unit 2	Opacity	5/10/2009	8:00	5/10/2009	8:06	723 723C
220 Unit 2	Opacity	5/11/2009	8:00	5/11/2009	8:06	723 723C
220 Unit 2	Opacity	5/11/2009	12:30	5/11/2009	12:36	724 724C
220 Unit 2	Opacity	5/12/2009	8:00	5/12/2009	8:06	723 723C
220 Unit 2	Opacity	5/13/2009	8:00	5/13/2009	8:06	723 723C
220 Unit 2	Opacity	5/14/2009	8:00	5/14/2009	8:06	723 723C
220 Unit 2	Opacity	5/15/2009	8:00	5/15/2009	8:06	723 723C
220 Unit 2	Opacity	5/16/2009	8:00	5/16/2009	8:06	723 723C
220 Unit 2	Opacity	5/17/2009	8:00	5/17/2009	8:06	723 723C
220 Unit 2	Opacity	5/18/2009	8:00	5/18/2009	8:06	723 723C
220 Unit 2	Opacity	5/19/2009	8:00	5/19/2009	8:06	723 723C
220 Unit 2	Opacity	5/20/2009	8:00	5/20/2009	8:06	723 723C
220 Unit 2	Opacity	5/21/2009	8:00	5/21/2009	8:06	723 723C

220	Unit 2	Opacity	5/22/2009	8:00	5/22/2009	8:06	723	723C							
220	Unit 2	Opacity	5/23/2009	8:00	5/23/2009	8:06	723	723C							
220	Unit 2	Opacity	5/24/2009	8:00	5/24/2009	8:06	723	723C							
220	Unit 2	Opacity	5/25/2009	8:00	5/25/2009	8:06	723	723C							
220	Unit 2	Opacity	5/26/2009	8:00	5/26/2009	8:06	723	723C							
220	Unit 2	Opacity	5/27/2009	8:00	5/27/2009	8:06	723	723C							
220	Unit 2	Opacity	5/28/2009	8:00	5/28/2009	8:06	723	723C							
220	Unit 2	Opacity	5/29/2009	8:00	5/29/2009	8:06	723	723C							
220	Unit 2	Opacity	5/30/2009	8:00	5/30/2009	8:06	723	723C							
220	Unit 2	Opacity	5/31/2009	8:00	5/31/2009	8:06	723	723C							
220	Unit 2	Opacity	6/1/2009	8:00	6/1/2009	8:06	723	723C							
220	Unit 2	Opacity	6/2/2009	8:00	6/2/2009	8:06	723	723C							
220	Unit 2	Opacity	6/3/2009	6:00	6/3/2009	6:06	723	723C							
220	Unit 2	Opacity	6/4/2009	6:00	6/4/2009	6:06	723	723C							
220	Unit 2	Opacity	6/5/2009	6:00	6/5/2009	6:06	723	723C							
220	Unit 2	Opacity	6/6/2009	6:00	6/6/2009	6:06	723	723C							
220	Unit 2	Opacity	6/7/2009	6:00	6/7/2009	6:06	723	723C							
220	Unit 2	Opacity	6/8/2009	6:00	6/8/2009	6:06	723	723C							
220	Unit 2	Opacity	6/9/2009	5:00	6/9/2009	5:06	723	723C							
220	Unit 2	Opacity	6/10/2009	5:00	6/10/2009	5:06	723	723C							
220	Unit 2	Opacity	6/11/2009	5:00	6/11/2009	5:06	723	723C							
220	Unit 2	Opacity	6/12/2009	5:00	6/12/2009	5:06	723	723C							
220	Unit 2	Opacity	6/13/2009	5:00	6/13/2009	5:06	723	723C							
220	Unit 2	Opacity	6/14/2009	5:00	6/14/2009	5:06	723	723C							
220	Unit 2	Opacity	6/15/2009	5:00	6/15/2009	5:06	723	723C							
220	Unit 2	Opacity	6/16/2009	5:00	6/16/2009	5:06	723	723C							
220	Unit 2	Opacity	6/17/2009	5:00	6/17/2009	5:06	723	723C							
220	Unit 2	Opacity	6/18/2009	5:00	6/18/2009	5:06	723	723C							
220	Unit 2	Opacity	6/19/2009	5:00	6/19/2009	5:06	723	723C							
220	Unit 2	Opacity	6/20/2009	5:00	6/20/2009	5:06	723	723C							
220	Unit 2	Opacity	6/21/2009	5:00	6/21/2009	5:06	723	723C							
220	Unit 2	Opacity	6/22/2009	5:00	6/22/2009	5:06	723	723C							
220	Unit 2	Opacity	6/23/2009	5:00	6/23/2009	5:06	723	723C							
220	Unit 2	Opacity	6/24/2009	5:00	6/24/2009	5:06	723	723C							
220	Unit 2	Opacity	6/25/2009	5:00	6/25/2009	5:06	723	723C							
220	Unit 2	Opacity	6/26/2009	5:00	6/26/2009	5:06	723	723C							
220	Unit 2	Opacity	6/27/2009	5:00	6/27/2009	5:06	723	723C							
220	Unit 2	Opacity	6/28/2009	5:00	6/28/2009	5:06	723	723C							
220	Unit 2	Opacity	6/29/2009	5:00	6/29/2009	5:06	723	723C							
220	Unit 2	Opacity	6/30/2009	5:00	6/30/2009	5:06	723	723C							
240	Unit 2	InletCO2	4/15/2009	Y	CO2 analyzer was replaced. Seven day drift test and the linearity and cylinder gas audit was performed within 168 hours. See attached seven day drift file u2_inletCO2_7daytdrft.										
240	Unit 2	OutletCO2	4/15/2009	Y	CO2 analyzer was replaced. Seven day drift test and the linearity and cylinder gas audit was performed within 168 hours. See attached seven day drift file u2_outletCO2_7daytdrft.										
240	Unit 2	InletProbe	4/25/2009	Y	The Inlet S2 sample conditioning system or the probe was replaced with a Perma Pure model 4P45XI SN4P04160902 dilution probe.										
240	Unit 2	OutletProbe	4/24/2009	Y	The Outlet U2 sample conditioning system or the probe was replaced with a Perma Pure model 4P45XI SN 4P04160901 dilution probe.										
250	Unit 2	InletSO2	5/5/2009	11/20/2008	6	lbs/mmbtu	1.024	1.018	2.40%	Pass					
250	Unit 2	InletCO2	5/5/2009	11/20/2008	6	%CO2	13.03	13.63	4.70%	Pass					
250	Unit 2	OutletSO2	5/6/2009	11/18/2008	6	lbs/mmbtu	0.0913	0.0871	6.08%	Pass					
250	Unit 2	OutletNOx	5/6/2009	11/18/2008	6	lbs/mmbtu	0.375	0.358	5.27%	Pass					
250	Unit 2	OutletCO2	5/6/2009	11/18/2008	6	%CO2	12.522	11.937	6.02%	Pass					
260	Unit 2	InletSO2	4/29/2009	2	CC246353	2/6/2010	P1	PPM	275.55	276	-0.16%	P	LOW		
260	Unit 2	InletCO2	4/29/2009	2	CC131734	10/29/2010	P1	PERCENT	11.27	11.12	1.31%	P	LOW		
260	Unit 2	InletSO2	4/29/2009	2	CC187334	4/2/2010	P1	PPM	561.1	554	1.28%	P	HIGH		

260 Unit 2	OutletSO2	4/28/2009		1	CC246105	8/22/2010	P1	PPM	13.42	12.6	6.48%	P	LOW
260 Unit 2	OutletNOx	4/28/2009		1	CC246105	8/22/2010	P1	PPM	129.16	126	2.51%	P	LOW
260 Unit 2	OutletCO2	4/28/2009		1	CC246105	8/22/2010	P1	PERCENT	5.42	5.1	6.23%	P	LOW
260 Unit 2	OutletSO2	4/28/2009		1	CC246353	2/6/2010	P1	PPM	278.26	276	0.82%	P	HIGH
260 Unit 2	OutletNOx	4/28/2009		1	CC246353	2/6/2010	P1	PPM	278.88	278	0.32%	P	HIGH
260 Unit 2	OutletSO2	4/28/2009		2	CC131734	10/29/2010	P1	PPM	27.92	27.8	0.43%	P	LOW
260 Unit 2	OutletNOx	4/28/2009		2	CC131734	10/29/2010	P1	PPM	273.22	275	-0.65%	P	LOW
260 Unit 2	OutletCO2	4/28/2009		2	CC131734	10/29/2010	P1	PERCENT	11.14	11.12	0.17%	P	LOW
260 Unit 2	OutletSO2	4/28/2009		2	CC187334	4/2/2010	P1	PPM	552.28	554	-0.31%	P	HIGH
260 Unit 2	OutletNOx	4/28/2009		2	CC187334	4/2/2010	P1	PPM	550.51	551	-0.09%	P	HIGH
270 Unit 2	OutletSO2	4/28/2009	Low		CC246105	8/22/2010	P1	PPM	13.42	12.6	0.82	P	LOW
270 Unit 2	OutletNOx	4/28/2009	Low		CC246105	8/22/2010	P1	PPM	129.16	126	2.51	P	LOW
270 Unit 2	OutletCO2	4/28/2009	Low		CC246105	8/22/2010	P1	PERCENT	5.42	5.1	0.32	P	LOW
270 Unit 2	OutletSO2	4/28/2009	Low		CC246353	2/6/2010	P1	PPM	278.26	276	0.82	P	HIGH
270 Unit 2	OutletNOx	4/28/2009	Low		CC246353	2/6/2010	P1	PPM	278.88	278	0.32	P	HIGH
270 Unit 2	OutletSO2	4/28/2009	Mid		CC131734	10/29/2010	P1	PPM	27.92	27.8	0.43	P	LOW
270 Unit 2	OutletNOx	4/28/2009	Mid		CC131734	10/29/2010	P1	PPM	273.22	275	0.65	P	LOW
270 Unit 2	OutletCO2	4/28/2009	Mid		CC131734	10/29/2010	P1	PERCENT	11.14	11.12	0.17	P	LOW
270 Unit 2	OutletSO2	4/28/2009	Mid		CC187334	4/2/2010	P1	PPM	552.28	554	0.31	P	HIGH
270 Unit 2	OutletNOx	4/28/2009	Mid		CC187334	4/2/2010	P1	PPM	550.51	551	0.09	P	HIGH
270 Unit 2	OutletSO2	4/28/2009	High		CC111230	10/9/2009	P1	PPM	41.01	41.4	0.95	P	LOW
270 Unit 2	OutletNOx	4/28/2009	High		CC111230	10/9/2009	P1	PPM	430.53	432	0.34	P	LOW
270 Unit 2	OutletCO2	4/28/2009	High		CC111230	10/9/2009	P1	PERCENT	18.85	18.73	0.65	P	LOW
270 Unit 2	OutletSO2	4/28/2009	High		CC200320	10/27/2009	P1	PPM	895.39	884	0.07	P	HIGH
270 Unit 2	OutletNOx	4/28/2009	High		CC200320	10/27/2009	P1	PPM	897.23	886	0.53	P	HIGH
300 Unit 2	InletSO2			1.53%	31	2	0	2	27	0			
300 Unit 2	InletCO2			1.53%	31	2	0	2	27	0			
300 Unit 2	Opacity			0.46%	9.4	0	0	9.2	0.2	0			
300 Unit 2	OutletSO2			1.63%	33	4	0	3	26	0			
300 Unit 2	OutletNOx			1.63%	33	4	0	3	26	0			
300 Unit 2	OutletCO2			1.63%	33	4	0	3	26	0			
310 Unit 2	Opacity	24.7		1.22%	24.7	0	0	0	0	20	%	6 min.	
310 Unit 2	SO2	0		0.00%	0	0	0	0	0	0.138	lb/mmbtu	30 DRA	
310 Unit 2	NOx	0		0.00%	0	0	0	0	0	0.46	lb/mmblu	30 DRA	
400 Unit 2	4/17/2009	6:18		32	701	701F							
400 Unit 2	4/17/2009	6:24		64	701	701F							
400 Unit 2	4/17/2009	6:30		63	701	701F							
400 Unit 2	4/17/2009	6:36		63	701	701F							
400 Unit 2	4/17/2009	6:42		65	701	701F							
400 Unit 2	4/17/2009	6:48		66	701	701F							
400 Unit 2	4/17/2009	6:54		66	701	701F							
400 Unit 2	4/17/2009	7:00		66	701	701F							
400 Unit 2	4/17/2009	7:06		58	701	701F							
400 Unit 2	4/17/2009	7:12		56	701	701F							
400 Unit 2	4/17/2009	7:18		40	701	701F							
400 Unit 2	4/17/2009	7:24		32	701	701F							
400 Unit 2	4/17/2009	7:30		59	701	701F							
400 Unit 2	4/17/2009	7:36		62	701	701F							
400 Unit 2	4/17/2009	7:42		57	701	701F							
400 Unit 2	4/17/2009	7:48		35	701	701F							
400 Unit 2	4/17/2009	7:54		29	701	701F							
400 Unit 2	4/17/2009	8:06		39	701	701F							

400 Unit 2	4/17/2009	8:12	54	701 701F
400 Unit 2	4/17/2009	8:18	55	701 701F
400 Unit 2	4/17/2009	8:24	44	701 701F
400 Unit 2	4/17/2009	8:30	47	701 701F
400 Unit 2	4/17/2009	8:36	58	701 701F
400 Unit 2	4/17/2009	8:42	54	701 701F
400 Unit 2	4/17/2009	8:48	40	701 701F
400 Unit 2	4/17/2009	8:54	36	701 701F
400 Unit 2	4/17/2009	9:00	30	701 701F
400 Unit 2	4/17/2009	9:06	33	701 701F
400 Unit 2	4/17/2009	9:12	29	701 701F
400 Unit 2	4/17/2009	9:18	31	701 701F
400 Unit 2	4/17/2009	9:24	33	701 701F
400 Unit 2	4/17/2009	9:30	31	701 701F
400 Unit 2	4/17/2009	9:36	48	701 701F
400 Unit 2	4/17/2009	9:42	51	701 701F
400 Unit 2	4/17/2009	9:48	48	701 701F
400 Unit 2	4/17/2009	9:54	30	701 701F
400 Unit 2	4/17/2009	10:00	41	701 701F
400 Unit 2	4/17/2009	10:06	58	701 701F
400 Unit 2	4/17/2009	10:12	50	701 701F
400 Unit 2	4/17/2009	10:18	41	701 701F
400 Unit 2	4/17/2009	10:24	40	701 701F
400 Unit 2	4/17/2009	10:30	31	701 701F
400 Unit 2	4/17/2009	10:36	33	701 701F
400 Unit 2	4/17/2009	10:42	39	701 701F
400 Unit 2	4/17/2009	10:48	37	701 701F
400 Unit 2	4/17/2009	10:54	35	701 701F
400 Unit 2	4/17/2009	11:00	34	701 701F
400 Unit 2	4/17/2009	11:06	32	701 701F
400 Unit 2	4/17/2009	11:12	34	701 701F
400 Unit 2	4/17/2009	11:18	34	701 701F
400 Unit 2	4/17/2009	11:24	29	701 701F
400 Unit 2	4/17/2009	11:30	25	701 701F
400 Unit 2	4/17/2009	11:36	23	701 701F
400 Unit 2	4/17/2009	11:42	23	701 701F
400 Unit 2	4/17/2009	11:48	24	701 701F
400 Unit 2	4/17/2009	11:54	23	701 701F
400 Unit 2	4/17/2009	12:00	22	701 701F
400 Unit 2	4/17/2009	12:06	21	701 701F
400 Unit 2	4/17/2009	12:12	22	701 701F
400 Unit 2	4/17/2009	12:36	21	701 701F
400 Unit 2	4/17/2009	12:42	30	701 701F
400 Unit 2	4/17/2009	12:48	43	701 701F
400 Unit 2	4/17/2009	12:54	39	701 701F
400 Unit 2	4/17/2009	13:00	38	701 701F
400 Unit 2	4/17/2009	13:06	21	701 701F
400 Unit 2	4/18/2009	19:00	24	701 701G
400 Unit 2	4/18/2009	19:12	50	701 701G
400 Unit 2	4/18/2009	19:18	55	701 701G
400 Unit 2	4/18/2009	19:24	62	701 701G
400 Unit 2	4/18/2009	19:30	64	701 701G

400 Unit 2	4/18/2009	19:36	65	701 701G
400 Unit 2	4/18/2009	19:42	67	701 701G
400 Unit 2	4/18/2009	19:48	67	701 701G
400 Unit 2	4/18/2009	19:54	66	701 701G
400 Unit 2	4/18/2009	20:00	67	701 701G
400 Unit 2	4/18/2009	20:06	67	701 701G
400 Unit 2	4/18/2009	20:12	67	701 701G
400 Unit 2	4/18/2009	20:18	67	701 701G
400 Unit 2	4/18/2009	20:24	67	701 701G
400 Unit 2	4/18/2009	20:30	66	701 701G
400 Unit 2	4/18/2009	20:36	65	701 701G
400 Unit 2	4/18/2009	20:42	65	701 701G
400 Unit 2	4/18/2009	20:48	64	701 701G
400 Unit 2	4/18/2009	20:54	63	701 701G
400 Unit 2	4/18/2009	21:00	62	701 701G
400 Unit 2	4/18/2009	21:06	59	701 701G
400 Unit 2	4/18/2009	21:12	61	701 701G
400 Unit 2	4/18/2009	21:18	66	701 701G
400 Unit 2	4/18/2009	21:24	65	701 701G
400 Unit 2	4/18/2009	21:30	65	701 701G
400 Unit 2	4/18/2009	21:36	65	701 701G
400 Unit 2	4/18/2009	21:42	65	701 701G
400 Unit 2	4/18/2009	21:48	64	701 701G
400 Unit 2	4/18/2009	21:54	64	701 701G
400 Unit 2	4/18/2009	22:00	64	701 701G
400 Unit 2	4/18/2009	22:06	64	701 701G
400 Unit 2	4/18/2009	22:12	64	701 701G
400 Unit 2	4/18/2009	22:18	64	701 701G
400 Unit 2	4/18/2009	22:24	64	701 701G
400 Unit 2	4/18/2009	22:30	64	701 701G
400 Unit 2	4/18/2009	22:36	64	701 701G
400 Unit 2	4/18/2009	22:42	64	701 701G
400 Unit 2	4/18/2009	22:48	64	701 701G
400 Unit 2	4/18/2009	22:54	64	701 701G
400 Unit 2	4/18/2009	23:00	64	701 701G
400 Unit 2	4/18/2009	23:06	64	701 701G
400 Unit 2	4/18/2009	23:12	64	701 701G
400 Unit 2	4/18/2009	23:18	64	701 701G
400 Unit 2	4/18/2009	23:24	64	701 701G
400 Unit 2	4/18/2009	23:30	64	701 701G
400 Unit 2	4/18/2009	23:36	64	701 701G
400 Unit 2	4/18/2009	23:42	64	701 701G
400 Unit 2	4/18/2009	23:48	64	701 701G
400 Unit 2	4/18/2009	23:54	64	701 701G
400 Unit 2	4/19/2009	0:00	64	701 701G
400 Unit 2	4/19/2009	0:06	64	701 701G
400 Unit 2	4/19/2009	0:12	64	701 701G
400 Unit 2	4/19/2009	0:18	64	701 701G
400 Unit 2	4/19/2009	0:24	63	701 701G
400 Unit 2	4/19/2009	0:30	63	701 701G
400 Unit 2	4/19/2009	0:36	63	701 701G
400 Unit 2	4/19/2009	0:42	63	701 701G

400 Unit 2	4/19/2009	0:48	63	701 701G
400 Unit 2	4/19/2009	0:54	63	701 701G
400 Unit 2	4/19/2009	1:00	63	701 701G
400 Unit 2	4/19/2009	1:06	64	701 701G
400 Unit 2	4/19/2009	1:12	64	701 701G
400 Unit 2	4/19/2009	1:18	64	701 701G
400 Unit 2	4/19/2009	1:24	64	701 701G
400 Unit 2	4/19/2009	1:30	64	701 701G
400 Unit 2	4/19/2009	1:36	64	701 701G
400 Unit 2	4/19/2009	1:42	64	701 701G
400 Unit 2	4/19/2009	1:48	63	701 701G
400 Unit 2	4/19/2009	1:54	62	701 701G
400 Unit 2	4/19/2009	2:00	62	701 701G
400 Unit 2	4/19/2009	2:06	61	701 701G
400 Unit 2	4/19/2009	2:12	61	701 701G
400 Unit 2	4/19/2009	2:18	60	701 701G
400 Unit 2	4/19/2009	2:24	59	701 701G
400 Unit 2	4/19/2009	2:30	59	701 701G
400 Unit 2	4/19/2009	2:36	60	701 701G
400 Unit 2	4/19/2009	2:42	59	701 701G
400 Unit 2	4/19/2009	2:48	59	701 701G
400 Unit 2	4/19/2009	2:54	59	701 701G
400 Unit 2	4/19/2009	3:00	59	701 701G
400 Unit 2	4/19/2009	3:06	59	701 701G
400 Unit 2	4/19/2009	3:12	59	701 701G
400 Unit 2	4/19/2009	3:18	59	701 701G
400 Unit 2	4/19/2009	3:24	59	701 701G
400 Unit 2	4/19/2009	3:30	60	701 701G
400 Unit 2	4/19/2009	3:36	63	701 701G
400 Unit 2	4/19/2009	3:42	64	701 701G
400 Unit 2	4/19/2009	3:48	64	701 701G
400 Unit 2	4/19/2009	3:54	63	701 701G
400 Unit 2	4/19/2009	4:00	57	701 701G
400 Unit 2	6/23/2009	9:54	27	701 701I
400 Unit 2	6/28/2009	13:12	23	701 701J
400 Unit 2	6/28/2009	13:18	21	701 701J
400 Unit 2	6/28/2009	13:30	21	701 701J
400 Unit 2	6/28/2009	13:48	57	701 701J
400 Unit 2	6/28/2009	13:54	50	701 701J
400 Unit 2	6/28/2009	14:00	67	701 701J
400 Unit 2	6/28/2009	14:06	67	701 701J
400 Unit 2	6/28/2009	14:12	67	701 701J
400 Unit 2	6/28/2009	14:18	66	701 701J
400 Unit 2	6/28/2009	14:24	66	701 701J
400 Unit 2	6/28/2009	14:30	65	701 701J
400 Unit 2	6/28/2009	14:36	65	701 701J
400 Unit 2	6/28/2009	14:42	64	701 701J
400 Unit 2	6/28/2009	14:48	63	701 701J
400 Unit 2	6/28/2009	14:54	65	701 701J
400 Unit 2	6/28/2009	15:00	65	701 701J
400 Unit 2	6/28/2009	15:06	65	701 701J
400 Unit 2	6/28/2009	15:12	62	701 701J

400 Unit 2	6/28/2009	15:18	62	701 701J
400 Unit 2	6/28/2009	15:24	62	701 701J
400 Unit 2	6/28/2009	15:30	62	701 701J
400 Unit 2	6/28/2009	15:36	62	701 701J
400 Unit 2	6/28/2009	15:42	62	701 701J
400 Unit 2	6/28/2009	15:48	62	701 701J
400 Unit 2	6/28/2009	15:54	62	701 701J
400 Unit 2	6/28/2009	16:00	62	701 701J
400 Unit 2	6/28/2009	16:06	62	701 701J
400 Unit 2	6/28/2009	16:12	62	701 701J
400 Unit 2	6/28/2009	16:18	63	701 701J
400 Unit 2	6/28/2009	16:24	65	701 701J
400 Unit 2	6/28/2009	16:30	66	701 701J
400 Unit 2	6/28/2009	16:36	66	701 701J
400 Unit 2	6/28/2009	16:42	66	701 701J
400 Unit 2	6/28/2009	16:48	66	701 701J
400 Unit 2	6/28/2009	16:54	66	701 701J
400 Unit 2	6/28/2009	17:00	66	701 701J
400 Unit 2	6/28/2009	17:06	66	701 701J
400 Unit 2	6/28/2009	17:12	66	701 701J
400 Unit 2	6/28/2009	17:18	66	701 701J
400 Unit 2	6/28/2009	17:24	66	701 701J
400 Unit 2	6/28/2009	17:30	66	701 701J
400 Unit 2	6/28/2009	17:36	66	701 701J
400 Unit 2	6/28/2009	17:42	66	701 701J
400 Unit 2	6/28/2009	17:48	66	701 701J
400 Unit 2	6/28/2009	17:54	66	701 701J
400 Unit 2	6/28/2009	18:00	66	701 701J
400 Unit 2	6/28/2009	18:06	66	701 701J
400 Unit 2	6/28/2009	18:12	66	701 701J
400 Unit 2	6/28/2009	18:18	66	701 701J
400 Unit 2	6/28/2009	18:24	64	701 701J
400 Unit 2	6/28/2009	18:30	64	701 701J
400 Unit 2	6/28/2009	18:36	64	701 701J
400 Unit 2	6/28/2009	18:42	64	701 701J
400 Unit 2	6/28/2009	18:48	63	701 701J
400 Unit 2	6/28/2009	18:54	63	701 701J
400 Unit 2	6/28/2009	19:00	62	701 701J
400 Unit 2	6/28/2009	19:06	62	701 701J
400 Unit 2	6/28/2009	19:12	62	701 701J
400 Unit 2	6/28/2009	19:18	61	701 701J
400 Unit 2	6/28/2009	19:24	61	701 701J
400 Unit 2	6/28/2009	19:30	61	701 701J
400 Unit 2	6/28/2009	19:36	61	701 701J
400 Unit 2	6/28/2009	19:42	62	701 701J
400 Unit 2	6/28/2009	19:48	62	701 701J
400 Unit 2	6/28/2009	19:54	62	701 701J
400 Unit 2	6/28/2009	20:00	62	701 701J
400 Unit 2	6/28/2009	20:06	61	701 701J
400 Unit 2	6/28/2009	20:12	61	701 701J
400 Unit 2	6/28/2009	20:18	62	701 701J
400 Unit 2	6/28/2009	20:24	62	701 701J

400 Unit 2	6/28/2009	20:30	62	701 701J
400 Unit 2	6/28/2009	20:36	62	701 701J
400 Unit 2	6/28/2009	20:42	62	701 701J
400 Unit 2	6/28/2009	20:48	61	701 701J
400 Unit 2	6/28/2009	20:54	61	701 701J
400 Unit 2	6/28/2009	21:00	61	701 701J
400 Unit 2	6/28/2009	21:06	60	701 701J
400 Unit 2	6/28/2009	21:12	59	701 701J
400 Unit 2	6/28/2009	21:18	59	701 701J
400 Unit 2	6/28/2009	21:24	59	701 701J
400 Unit 2	6/28/2009	21:30	59	701 701J
400 Unit 2	6/28/2009	21:36	58	701 701J
400 Unit 2	6/28/2009	21:42	58	701 701J
400 Unit 2	6/28/2009	21:48	58	701 701J
400 Unit 2	6/28/2009	21:54	59	701 701J
400 Unit 2	6/28/2009	22:00	61	701 701J
400 Unit 2	6/28/2009	22:06	62	701 701J
400 Unit 2	6/28/2009	22:12	44	701 701J
400 Unit 2	6/28/2009	22:24	23	701 701J
400 Unit 2	6/28/2009	22:30	23	701 701J
400 Unit 2	6/28/2009	22:48	28	701 701J
411 Unit 2	4/1/2009	0.09	92	
411 Unit 2	4/2/2009	0.09	92	
411 Unit 2	4/3/2009	0.09	92	
411 Unit 2	4/4/2009	0.09	92	
411 Unit 2	4/5/2009	0.09	92	
411 Unit 2	4/6/2009	0.09	92	
411 Unit 2	4/7/2009	0.09	92	
411 Unit 2	4/8/2009	0.08	93	
411 Unit 2	4/9/2009	0.08	93	
411 Unit 2	4/10/2009	0.08	93	
411 Unit 2	4/11/2009	0.08	92	
411 Unit 2	4/12/2009	0.08	92	
411 Unit 2	4/13/2009	0.08	93	
411 Unit 2	4/14/2009	0.07	93	
411 Unit 2	4/15/2009	0.07	93	
411 Unit 2	4/16/2009	0.07	93	
411 Unit 2	4/17/2009	0.07	93	
411 Unit 2	4/18/2009	0.07	93	
411 Unit 2	4/19/2009	0.07	93	
411 Unit 2	4/20/2009	0.07	93	
411 Unit 2	4/21/2009	0.07	93	
411 Unit 2	4/22/2009	0.07	93	
411 Unit 2	4/23/2009	0.07	93	
411 Unit 2	4/24/2009	0.07	93	
411 Unit 2	4/25/2009	0.07	93	
411 Unit 2	4/26/2009	0.07	93	
411 Unit 2	4/27/2009	0.07	93	
411 Unit 2	4/28/2009	0.07	93	
411 Unit 2	4/29/2009	0.07	93	
411 Unit 2	4/30/2009	0.07	93	
411 Unit 2	5/1/2009	0.07	93	

411 Unit 2	5/2/2009	0.07	93
411 Unit 2	5/3/2009	0.07	93
411 Unit 2	5/4/2009	0.07	93
411 Unit 2	5/5/2009	0.07	93
411 Unit 2	5/6/2009	0.07	93
411 Unit 2	5/7/2009	0.07	94
411 Unit 2	5/8/2009	0.07	94
411 Unit 2	5/9/2009	0.07	94
411 Unit 2	5/10/2009	0.07	94
411 Unit 2	5/11/2009	0.07	94
411 Unit 2	5/12/2009	0.08	93
411 Unit 2	5/13/2009	0.08	93
411 Unit 2	5/14/2009	0.08	93
411 Unit 2	5/15/2009	0.08	93
411 Unit 2	5/16/2009	0.08	93
411 Unit 2	5/17/2009	0.08	93
411 Unit 2	5/18/2009	0.08	93
411 Unit 2	5/19/2009	0.08	93
411 Unit 2	5/20/2009	0.08	94
411 Unit 2	5/21/2009	0.08	94
411 Unit 2	5/22/2009	0.09	93
411 Unit 2	5/23/2009	0.09	93
411 Unit 2	5/24/2009	0.09	93
411 Unit 2	5/25/2009	0.09	93
411 Unit 2	5/26/2009	0.09	93
411 Unit 2	5/27/2009	0.09	93
411 Unit 2	5/28/2009	0.09	93
411 Unit 2	5/29/2009	0.09	93
411 Unit 2	5/30/2009	0.09	93
411 Unit 2	5/31/2009	0.09	93
411 Unit 2	6/1/2009	0.08	94
411 Unit 2	6/2/2009	0.09	93
411 Unit 2	6/3/2009	0.09	93
411 Unit 2	6/4/2009	0.09	93
411 Unit 2	6/5/2009	0.08	94
411 Unit 2	6/6/2009	0.08	94
411 Unit 2	6/7/2009	0.08	94
411 Unit 2	6/8/2009	0.08	93
411 Unit 2	6/9/2009	0.08	93
411 Unit 2	6/10/2009	0.08	93
411 Unit 2	6/11/2009	0.08	93
411 Unit 2	6/12/2009	0.08	93
411 Unit 2	6/13/2009	0.08	93
411 Unit 2	6/14/2009	0.08	93
411 Unit 2	6/15/2009	0.08	93
411 Unit 2	6/16/2009	0.08	93
411 Unit 2	6/17/2009	0.08	93
411 Unit 2	6/18/2009	0.08	93
411 Unit 2	6/19/2009	0.08	93
411 Unit 2	6/20/2009	0.08	93
411 Unit 2	6/21/2009	0.08	93
411 Unit 2	6/22/2009	0.08	93

411 Unit 2	6/23/2009	0.07	94
411 Unit 2	6/28/2009	0.07	94
411 Unit 2	6/29/2009	0.07	94
411 Unit 2	6/30/2009	0.07	94
421 Unit 2	4/1/2009	0.34	
421 Unit 2	4/2/2009	0.34	
421 Unit 2	4/3/2009	0.34	
421 Unit 2	4/4/2009	0.34	
421 Unit 2	4/5/2009	0.34	
421 Unit 2	4/6/2009	0.34	
421 Unit 2	4/7/2009	0.34	
421 Unit 2	4/8/2009	0.34	
421 Unit 2	4/9/2009	0.34	
421 Unit 2	4/10/2009	0.35	
421 Unit 2	4/11/2009	0.34	
421 Unit 2	4/12/2009	0.34	
421 Unit 2	4/13/2009	0.34	
421 Unit 2	4/14/2009	0.34	
421 Unit 2	4/15/2009	0.34	
421 Unit 2	4/16/2009	0.34	
421 Unit 2	4/17/2009	0.34	
421 Unit 2	4/18/2009	0.34	
421 Unit 2	4/19/2009	0.34	
421 Unit 2	4/20/2009	0.34	
421 Unit 2	4/21/2009	0.34	
421 Unit 2	4/22/2009	0.34	
421 Unit 2	4/23/2009	0.35	
421 Unit 2	4/24/2009	0.35	
421 Unit 2	4/25/2009	0.35	
421 Unit 2	4/26/2009	0.35	
421 Unit 2	4/27/2009	0.35	
421 Unit 2	4/28/2009	0.35	
421 Unit 2	4/29/2009	0.35	
421 Unit 2	4/30/2009	0.35	
421 Unit 2	5/1/2009	0.35	
421 Unit 2	5/2/2009	0.35	
421 Unit 2	5/3/2009	0.35	
421 Unit 2	5/4/2009	0.35	
421 Unit 2	5/5/2009	0.35	
421 Unit 2	5/6/2009	0.35	
421 Unit 2	5/7/2009	0.35	
421 Unit 2	5/8/2009	0.35	
421 Unit 2	5/9/2009	0.35	
421 Unit 2	5/10/2009	0.35	
421 Unit 2	5/11/2009	0.35	
421 Unit 2	5/12/2009	0.35	
421 Unit 2	5/13/2009	0.36	
421 Unit 2	5/14/2009	0.36	
421 Unit 2	5/15/2009	0.36	
421 Unit 2	5/16/2009	0.36	
421 Unit 2	5/17/2009	0.37	
421 Unit 2	5/18/2009	0.37	

421	Unit 2		5/19/2009	0.37	
421	Unit 2		5/20/2009	0.37	
421	Unit 2		5/21/2009	0.37	
421	Unit 2		5/22/2009	0.37	
421	Unit 2		5/23/2009	0.37	
421	Unit 2		5/24/2009	0.37	
421	Unit 2		5/25/2009	0.37	
421	Unit 2		5/26/2009	0.37	
421	Unit 2		5/27/2009	0.38	
421	Unit 2		5/28/2009	0.38	
421	Unit 2		5/29/2009	0.38	
421	Unit 2		5/30/2009	0.38	
421	Unit 2		5/31/2009	0.38	
421	Unit 2		6/1/2009	0.38	
421	Unit 2		6/2/2009	0.37	
421	Unit 2		6/3/2009	0.38	
421	Unit 2		6/4/2009	0.38	
421	Unit 2		6/5/2009	0.38	
421	Unit 2		6/6/2009	0.37	
421	Unit 2		6/7/2009	0.37	
421	Unit 2		6/8/2009	0.37	
421	Unit 2		6/9/2009	0.36	
421	Unit 2		6/10/2009	0.36	
421	Unit 2		6/11/2009	0.36	
421	Unit 2		6/12/2009	0.36	
421	Unit 2		6/13/2009	0.36	
421	Unit 2		6/14/2009	0.35	
421	Unit 2		6/15/2009	0.35	
421	Unit 2		6/16/2009	0.35	
421	Unit 2		6/17/2009	0.35	
421	Unit 2		6/18/2009	0.35	
421	Unit 2		6/19/2009	0.35	
421	Unit 2		6/20/2009	0.35	
421	Unit 2		6/21/2009	0.35	
421	Unit 2		6/22/2009	0.35	
421	Unit 2		6/23/2009	0.35	
421	Unit 2		6/28/2009	0.35	
421	Unit 2		6/29/2009	0.35	
421	Unit 2		6/30/2009	0.35	
500	Unit 2	InletSO2	4/17/2009	724	726A
500	Unit 2	InletCO2	4/17/2009	724	726A
500	Unit 2	InletSO2	4/18/2009	724	726A
500	Unit 2	InletCO2	4/18/2009	724	726A
500	Unit 2	InletSO2	4/25/2009	724	724D
500	Unit 2	InletCO2	4/25/2009	724	724D
500	Unit 2	OutletSO2	4/17/2009	724	726A
500	Unit 2	OutletNOx	4/17/2009	724	726A
500	Unit 2	OutletCO2	4/17/2009	724	726A
500	Unit 2	OutletSO2	4/18/2009	724	726A
500	Unit 2	OutletNOx	4/18/2009	724	726A
500	Unit 2	OutletCO2	4/18/2009	724	726A
500	Unit 2	OutletSO2	4/24/2009	724	724D

500	Unit 2	OutletNOx	4/24/2009	724	724D	
500	Unit 2	OutletCO2	4/24/2009	724	724D	
500	Unit 2	OutletSO2	4/27/2009	724	724C	
500	Unit 2	OutletNOx	4/27/2009	724	724C	
500	Unit 2	OutletCO2	4/27/2009	724	724C	
500	Unit 2	InletSO2	5/1/2009	724	724C	
500	Unit 2	InletCO2	5/1/2009	724	724C	
500	Unit 2	OutletSO2	6/23/2009	724	726A	
500	Unit 2	OutletNOx	6/23/2009	724	726A	
500	Unit 2	OutletCO2	6/23/2009	724	726A	
500	Unit 2	OutletSO2	6/28/2009	724	726A	
500	Unit 2	OutletNOx	6/28/2009	724	726A	
500	Unit 2	OutletCO2	6/28/2009	724	726A	
510	Unit 2	SO2	1800	Bituminous	19-7, Carbon Dioxide-Based F Factor, Wet Basis	
510	Unit 2	SO2	1800	Bituminous	19-23, Control Device Removal Efficiency	
510	Unit 2	SO2	1800	Bituminous	19-24, Compute average Inlet rate, Formula used as required.	
510	Unit 2	NOx	1800	Bituminous	19-7, Carbon Dioxide-Based F Factor, Wet Basis	
600	Unit 2	YES	YES	YES	YES	
700		701	Startup/Shutdown			
700		702	Control Equipment Problems			
700		703	Process Problems			
700		704	Other Know Causes			
700		705	Unknown Causes			
700		706	Soot Blowing			
700		707	Fuel Problems			
720		721	Monitor Equipment Malfunction			
720		722	Non-monitor Equipment Malfunction			
720		723	QA Calibrations			
720		724	Other Known Causes			
720		725	Unknown Causes			
730		701	701A	Unit One began start-up activities after a scheduled outage. The baghouse was placed in service when temperature and fuel oil ratio permits were met.		
730		701	701B	Unit One came off-line due to an operational fault of the generator protection circuit.The baghouse was placed in service when temperature and fuel oil ratio permits were met.		
730		701	701C	Unit Two began start-up activities after a scheduled outage. The baghouse was placed in service when temperature and fuel oil ratio permits were met.		
730		701	701D	Unit One began shut down activities for a scheduled outage.		
730		701	701E	Unit One began start-up activities after repair of a boiler tube leak. The baghouse was placed in service when temperature and fuel oil ratio permits were met.		
730		701	701F	Unit Two came off-line to repair a boiler tube leak.		
730		701	701G	Unit Two began start-up activities after repair of a boiler tube leak. The baghouse was placed in service when temperature and fuel oil ratio permits were met.		
730		701	701H	Unit Two began start-up activities after a trip caused by a faulty transmitter associated with the B-boiler feed pump turbine. The baghouse was placed in service when temperature and fuel oil ratio permits were met.		
730		701	701I	Unit Two came offline due to a generator ground fault.		
730		701	701J	Unit Two began start-up activities after repair was completed to the generator breaker. The baghouse was placed in service when temperature and fuel oil ratio permits were met.		
730		702	702A	Baghouse casing bypassed due to a false LOW outlet temperature alarm. The problem corrected itself and the casing was returned to service.		
730		702	702B	Baghouse casing bypassed due to a PC-CPU failure. A loose communication wire connection was found and tightened. Baghouse casing was returned to service.		
730		702	702C	Baghouse casing bypassed due to bad communication tap and cable. The parts were replaced and the baghouse casing was returned to service.		
730		702	702D	Baghouse casing bypassed due to a blown fuse. The fuse was replaced and the casing returned to service.		
730		702	702E	Baghouse casing bypassed due to a false PC-CPU failure (glitch). The casing was returned to sevice.		
730		702	702F	Baghouse casings A,B and C bypassed on loss of plant air pressure. Air pressure was restored and casings returned to service.		
730		702	702G	Baghouse casing bypassed due to a high differential pressure alarm. The casing was returned to service.		
730		702	702H	Baghouse casing bypassed due to a bypass damper limit switch problem. The was problem fixed. The casing was returned to service.		
730		704	704A	A Baghouse casing was bypassed for particulate testing. A variance was granted by the Utah Air Quality Board to conduct testing for CAM plan. The baghouse was returned to normal after testing was completed.		
730		704	704B	The excess opacity was due to another ID fan being started. During the start-up ash had settled in the off-line ID fan duct and was disturbed when the fan was started.		
730		704	704C	Baghouse casings B & C bypassed on High Temperature due to a failure of 1B Secondary Air Heater. The air heater was repaired and the casings were returned to service.		
730		704	704D	Baghouse casings A & B & C bypassed due to low temperature and fuel oil ratio >10%, low load conditions, transmission line trouble. The baghouse casing was returned to service when temperature and fuel oil ratio permits were met.		

730	705	705A	Baghouse casing bypassed due to unknown reasons. The casing was placed back in service.
730	705	705B	The cause of the excess opacity is unknown.
730	706	706A	
730	707	707A	
730	721	721A	The system did not perform a daily opacity calibration because of an i/o malfunction data collected but invalid for 24 hours.
730	721	721B	U1 stack part 75 flow monitor calibration ooc. System repaired calibrated and returned to service.
730	721	721C	The system daily calibration was out of control due to the zero range valve staying on during mid and high range span checks. Corrected problem and recalibrated no adjustments made.
730	721	721D	System down due to the calibration out of control. The performance NOX analyzer was calibrated SO2 and CO2 not out of control.
730	721	721E	System down due to calibration out of control. Partial pluggage of the dilution orifice or the eductor. The pluggage was cleared and the system was calibrated. Found that filters needed to be installed in the dilution air supply.
730	722	722A	U1 system went into timeshare mode due to U2 part 75 flow monitor malfuntion . The sytem was repaired and calibrated and returned to service.
730	722	722B	U1 stack part 75 flow monitor calibration ooc. System repaired calibrated and returned to service.
730	723	723A	Quarterly Linearity/CGA testing.
730	723	723B	Opacity monitor annual audit with UDAQ.
730	723	723C	Daily Opacity Calibration Check.
730	723	723D	Opacity monitor off stack. Maintenance and calibration. Field audit.
730	723	723E	System calibration.
730	724	724A	CO2 analyzer replaced with Thermo Environmental Instruments TECO 410i.
730	724	724B	Emissions data excluded from the calculation of averaged emissions due to NBOD.
730	724	724C	Routine Maintenance.
730	724	724D	The probe sample conditioning system replaced.
730	725	725A	S2 opacity data not collected for period cause unknown rest of monitoring system was in maintenance possible computer glitch.
730	724	726A	Partial boiler operating day less than 18 hours of operation less than 18 hours of data collection.