
HP Turbine efficiency upgrade step
02/27/01
988.7 MW
7574.9 NTCHR
6900000# Throttle Flow
92.20 HP Efficiency
91.53 IP Efficiency

IP7010471