TESTING

Steady State conditions - 1 hour prior to test
pressure 0.25% / temp 7F

60 minute test

Instrumentation calibrated w/ NBS
(calc measurement uncertainty)
Agree upon all correction factors
for variations in specified terminal conditions

Steam Tables - 1997 IFC

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS
AMPAD