11/10/89

dc

Outer

Unit 1 Register Handles

A4 handle assembly will not engage

D4 handle assembly keeps slipping out notch and goes full open

C3 can only open register 1 notch from B&W setting

C4 can only open register 1 notch from B&W setting

C2 two marks on outer register. need to verify which notch is B&W setting. (note: one of the ~~not~~ settings is @ closed position)

C5, F3 & A3 only left 3 notches on closed side of setpoint.