11/10/89

gc

Unit 2 Outer Register Handles

H3 handle assembly does not engage notches (wired e this time)

H6 slipped open and can not move to B&W setting

F2 Cannot close on outer register past B&W setting

B4 Can only close 1 notch from B&W setting

B3 + A3 can only close 3 notches from original setting.