June 10, 2003

BPI/TRI Meeting.
- Darrell, Tink, Dan Coates, Tom Martinko, Larry Boucher, Barry Bright
James M, Ken M, Stumph,
June 23 - BPI to provide a man for air-balancing.

O_2 is balanced (accrossed the burners); air flow still high.

OFA O_2 penetration into the heater is a concern.
Side-to-side bias on CO. More balancing of O_2 may be needed.

Open Discussion.
Mobilization - No main issues.
Office Trailers to the West.
Scaffolding
Heavy Iron should be here sooner. I-Beams
Power supplies in the same locations.

IP7_039473