Ruston Paving Company, Inc.
6216 Thompson Road • Syracuse, NY 13206

(315) 437-2533
(315) 437-1775
www.rustonpaving.com

June 18, 2014

Metalico Aluminum Recovery, Inc.
C/O: Dennis Flanagan
6223 Thompson Road
Syracuse, New York 13206

Dear Mr. Flanagan:

Re: CAMU Cover Repairs

I have completed the inspection of the asphalt cover on the CAMU area. I have found a few areas where the existing asphalt patches and concrete pads needed to be crack sealed again. There were also additional areas within the cover area that required crack sealing. There were also a few spots of vegetation growing along the edge of the asphalt slope. The vegetation along the slopes of the pavement have been removed and are not entering the CAMU cap area. I have included (4) photos of the work areas showing the repairs.

Repair Procedures:

Crack seal edges and existing asphalt patches.
Remove vegetation
Power sweep entire pad

All repairs were completed by June 18, 2014.

Should you have any questions or concerns, please contact me at (315) 437-2533.

Sincerely,
Ruston Paving Co., Inc.

Chris Laurin
Project Manager