From: Gorin, Jonathan
To: Carrie McGowan; "jmhoffman@ashland.com"; Cardiello, Frank
Subject: FW: Another Pipe Break at the LCP Superfund Site - Linden NJ
Date: Tuesday, October 06, 2015 4:27:00 PM

Carrie, John and Frank, FYI it looks like the break was repaired.

Jon

From: Charles.Gunther@amwater.com [mailto:Charles.Gunther@amwater.com]
Sent: Tuesday, October 06, 2015 4:24 PM
To: Michael.Bange@amwater.com
Cc: Gorin, Jonathan <Gorin.Jonathan@epa.gov>; Michael.Bange@amwater.com; Oconnell, Kimberly <OConnell.Kim@epa.gov>; Scott.Schreiber@amwater.com; Michael.Bormann@amwater.com
Subject: Re: Another Pipe Break at the LCP Superfund Site - Linden NJ

Mike,
Be advised this was a 16" main break which was dispatched to Creamer. A section approx. 5LF was replaced and main is back in service.

–Charlie

Charles S. Gunther
Operations Supervisor
New Jersey American Water
1341 North Avenue
Plainfield, New Jersey
Office: (908)-7913419
Cell: (908)413-7955

From: "Gorin, Jonathan" <Gorin.Jonathan@epa.gov>
To: "Michael.Bange@amwater.com" <Michael.Bange@amwater.com>.
Cc: "Oconnell, Kimberly" <OConnell.Kim@epa.gov>, "Scott.Schreiber@amwater.com" <Scott.Schreiber@amwater.com>, "Charles.Gunther@amwater.com" <Charles.Gunther@amwater.com>
Date: 10/06/2015 12:58 PM
Subject: Another Pipe Break at the LCP Superfund Site - Linden NJ

~~~
~~~

As I mentioned, the LCP property is about to undergo a “remedial action,” I believe the existing pipeline could interfere with that work. Also, the site will eventually be capped, which will make access to those pipes extremely difficult. If American Water could find another location for those pipes - at least until the cap is in place - that would be ideal.

From our discussion, I understand that you’ve been trying to divert the water from the pipe under the LCP property to new/existing pipes on adjacent properties. If I can be of any assistance on that effort, please let me know.

Jon
212 637-4361

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of American Water Works Company Inc. or its affiliates. The recipient should check this email and any attachments for the presence of viruses. American Water accepts no liability for any damage caused by any virus transmitted by this email.

American Water Works Company Inc., 1025 Laurel Oak Road, Voorhees, NJ 08043 www.amwater.com

---

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of American Water Works Company Inc. or its affiliates. The recipient should check this email and any attachments for the presence of viruses. American Water accepts no liability for any damage caused by any virus transmitted by this email.

American Water Works Company Inc., 1025 Laurel Oak Road, Voorhees, NJ 08043 www.amwater.com