From: Gorin, Jonathan
To: Charles.Gunther@amwater.com
Cc: dbove@gaf.com; Michael.Bange@amwater.com; Michael.Bormann@amwater.com; Oconnell, Kimberly; Scott.Schreiber@amwater.com; "jmhoffman@ashland.com"; Carrie McGowan
Subject: RE: Another Pipe Break at the LCP Superfund Site - Linden NJ
Date: Wednesday, October 14, 2015 10:22:00 AM

Thanks

From: Charles.Gunther@amwater.com [mailto:Charles.Gunther@amwater.com]
Sent: Wednesday, October 14, 2015 10:19 AM
To: Gorin, Jonathan <Gorin.Jonathan@epa.gov>
Cc: dbove@gaf.com; Michael.Bange@amwater.com; Michael.Bormann@amwater.com; Oconnell, Kimberly <OConnell.Kim@epa.gov>; Scott.Schreiber@amwater.com
Subject: RE: Another Pipe Break at the LCP Superfund Site - Linden NJ

Another leak on the 16" was identified in close proximity to the break earlier this month. J Fletcher Creamer is currently assembled on location.

~Charlie

____
Charles S. Gunther
Operations Supervisor
New Jersey American Water
1341 North Avenue
Plainfield, New Jersey
Office: (908)-7913419
Cell: (908)413-7955

From: "Gorin, Jonathan" <Gorin.Jonathan@epa.gov>
To: "Charles.Gunther@amwater.com" <Charles.Gunther@amwater.com>, "Michael.Bange@amwater.com" <Michael.Bange@amwater.com>,
Cc: "Michael.Bange@amwater.com" <Michael.Bange@amwater.com>, "Oconnell, Kimberly" <OConnell.Kim@epa.gov>, "Scott.Schreiber@amwater.com" <Scott.Schreiber@amwater.com>, "Michael.Bormann@amwater.com" <Michael.Bormann@amwater.com>, "dbove@gaf.com" <dbove@gaf.com>
Date: 10/14/2015 08:19 AM
Subject: RE: Another Pipe Break at the LCP Superfund Site - Linden NJ

This email was sent from outside the company. Please use caution and verify the sender before opening attachments or clicking links.

All, I understand there is another (or perhaps the same) leak this morning at the LCP site.

Please let me know what's going on.

Thanks, Jon

From: Charles.Gunther@amwater.com [mailto:Charles.Gunther@amwater.com]
Sent: Tuesday, October 06, 2015 4:24 PM
To: Michael.Bange@amwater.com
Cc: Gorin, Jonathan <Gorin.Jonathan@epa.gov>; Michael.Bange@amwater.com; Oconnell, Kimberly <OConnell.Kim@epa.gov>; Scott.Schreiber@amwater.com; Michael.Bormann@amwater.com
Subject: Re: Another Pipe Break at the LCP Superfund Site - Linden NJ

Mike,
Be advised this was a 16" main break which was dispatched to Creamer. A section approx. 5LF was replaced and main is back in service.

~Charlie

____
Charles S. Gunther
Operations Supervisor
New Jersey American Water
1341 North Avenue
Plainfield, New Jersey
Office: (908)-7913419
Cell: (908)413-7955

From: "Gorin, Jonathan" <Gorin.Jonathan@epa.gov>
To: "Michael.Bange@amwater.com" <Michael.Bange@amwater.com>,
Cc: "Oconnell, Kimberly" <OConnell.Kim@epa.gov>, "Scott.Schreiber@amwater.com" <Scott.Schreiber@amwater.com>, "Charles.Gunther@amwater.com" <Charles.Gunther@amwater.com>
Date: 10/06/2015 12:58 PM
Subject: Another Pipe Break at the LCP Superfund Site - Linden NJ

~~~~~~
~~~~~~

THIS EMAIL WAS SENT FROM OUTSIDE THE COMPANY. PLEASE USE CAUTION AND VERIFY THE SENDER BEFORE OPENING ATTACHMENTS OR CLICKING LINKS.

~~~
~~~