CONTENTS

PAGE	REFERENCE	DATE
	10 employees	
	Jane Gosh - Mgr	
1	Don Cassmy - Reg	
	Tim Ross - V.P.	
	Jerry - ~~maintenance~~ plant manager	
	Ken - mnt	

Sales — not
repackage —
as sold from [illegible]

Repackage [illegible]
C/ [illegible] → 150

5 state supplies

11 facilities —

E.A. — [illegible]
[illegible] —

monthly safety
training

Prince G. Harmel —

need 4 to respond
so response depends
on — who is [illegible]

auto-dialer —

[illegible] (4)
to 5 pm

Jury — plant manager —
[illegible] —

No Lerc –

visit from Tacoma
Fire + Pierce Co

Train to be familiar
with process

Cl – 1 ppm
intermittent alarm

2 ppm – total
shutdown
railcars / all process
autodialer –
Emergency call out –

Contamess truck on
– deliver to OR –

Brass fitting valves
replaced regularly –
Tanks rel[illegible]

Emergency
shutoff at
every exit

monthly inspec
of full face
respiratory

fit test Dec

replace cartridge
annually —

fit test
on SBIA &
fill

Tacoma rail
deliver within 48 hours
180,000 # Cl / tank
2 ~~tanks on site~~
use 1 – 3 days

30-40 gal / non-bleach