Veolia Energy North America
Kendall Green Steam LLC
265 First Street
Cambridge, MA 02142
T 617 679 4800 F 617 354 1301

April 15, 2014

Water Enforcement, OES4-SMR
United States Environmental Protection Agency
5 Post Office Square, Suite 100
Boston, MA 02109-3912

Re: National Pollutant Discharge Elimination System (NPDES)
Discharge Monitoring Report (DMR)
Permit Number: MA0004898
Reporting Period: March 1 to 31, 2014 Delivery by NetDMR

Dear Sir/Madam:

Enclosed is the NPDES Discharge Monitoring Report (DMR) from Kendall Green Energy LLC located at 265 First Street in Cambridge, Massachusetts. This report covers the March 1 to 31, 2014 reporting period.

On December 17, 2010, the United States Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection Agency (MassDEP) issued to GenOn Kendall a new NPDES permit that became effective on February 1, 2011. On January 31, 2011, the EPA issued a Findings and Order for Compliance (Docket No. 11-005) and MassDEP issued a Unilateral Administrative Order (File No. UAO-BO-11-1N001) establishing interim permit limits until other projects are completed to comply with the permit.

If you have any questions, or require additional information, please contact me at (617) 679-4818.

Sincerely,

Robert H. Richards
Environmental Engineer

Copies: Mr. Scott McBurney
MADEP, 205B Lowell Street, Wilmington MA 01887
MADEP, NPDES-DMRs
Division of Watershed Mgmt, 627 Main Street – 2nd floor, Worcester, MA 01608

Kendall Green Energy LLC NPDES DMR Data

Outfall SUM T --Condenser Cooling Water

Reporting Period -- March 2014

Date	Chlorine Pumps 1	2	3	Sample Time	Time of Analysis	Temp F (Influent)	TRC, mg/l Influent (only when above 50 F)	Outfall 001 TRC, mg/l Effluent (0.1)(0.1)	Outfall 002 TRC, mg/l Effluent (0.1)(0.1)	pH, Influent	Outfall 001 pH, Effluent (6.5)(9.0)	Outfall 002 pH, Effluent (6.5)(9.0)	Name of Sampler	Name of Analyst
3/1/2014	Off	Off	Off	0630	0640	33	- -	- -	- -	7.26	7.68	7.22	RA	RA
3/2/2014	Off	Off	Off	0645	0655	33	- -	- -	- -	7.27	7.25	7.28	TR	TR
3/3/2014	Off	Off	Off	0700	0710	33	- -	- -	- -	7.37	7.29	7.32	GF	GF
3/4/2014	Off	Off	Off	0645	0655	33	- -	- -	- -	7.24	7.28	7.31	RA	RA
3/5/2014	Off	Off	Off	1430	1440	33	- -	- -	- -	7.21	7.19	7.23	TR	TR
3/6/2014	Off	Off	Off	0700	0710	33	- -	- -	- -	7.19	7.21	7.23	RA	RA
3/7/2014	Off	Off	Off	0730	0740	34	- -	- -	- -	7.23	7.26	7.31	FP	FP
3/8/2014	Off	Off	Off	0600	0610	34	- -	- -	- -	7.21	7.28	7.32	RA	RA
3/9/2014	Off	Off	Off	0715	0730	35	- -	- -	- -	7.19	7.24	7.28	MP	MP
3/10/2014	Off	Off	Off	0950	1000	35	- -	- -	- -	7.16	7.20	7.30	TD	TD
3/11/2014	Off	Off	Off	0700	0715	36	- -	- -	- -	7.11	7.24	7.18	MP	MP
3/12/2014	Off	Off	Off	0700	0715	36	- -	- -	- -	7.10	7.20	7.10	TD	TD
3/13/2014	Off	Off	Off	0715	0720	36	- -	- -	- -	7.18	7.23	7.18	MP	MP
3/14/2014	Off	Off	Off	0900	0915	35	- -	- -	- -	7.10	7.19	7.08	TD	TD
3/15/2014	Off	Off	Off	0700	0715	36	- -	- -	- -	7.05	7.10	7.07	MP	MP
3/16/2014	Off	Off	Off	1100	1120	36	- -	- -	- -	6.82	6.82	6.80	MP	MP
3/17/2014	Off	Off	Off	1020	1030	36	- -	- -	- -	7.11	7.05	7.01	SH	SH
3/18/2014	Off	Off	Off	0945	0955	36	- -	- -	- -	7.06	7.01	7.05	JR	JR
3/19/2014	Off	Off	Off	1000	1005	36	- -	- -	- -	7.16	7.00	7.00	SH	SH
3/20/2014	Off	Off	Off	0955	1005	37	- -	- -	- -	7.28	7.22	7.02	JR	JR
3/21/2014	Off	Off	Off	1030	1050	37	- -	- -	- -	6.98	6.98	6.98	JR	JR
3/22/2014	Off	Off	Off	0650	0700	37	- -	- -	- -	7.42	7.37	7.36	TR	TR
3/23/2014	Off	Off	Off	0610	0620	38	- -	- -	- -	7.42	7.37	7.39	TR	TR
3/24/2014	Off	Off	Off	0620	0630	38	- -	- -	- -	7.42	7.39	7.35	TR	TR
3/25/2014	Off	Off	Off	0630	0640	38	- -	- -	- -	7.43	7.39	7.38	TR	TR
3/26/2014	Off	Off	Off	0640	0650	38	- -	- -	- -	7.41	7.39	7.34	TR	TR
3/27/2014	Off	Off	Off	0630	0640	38	- -	- -	- -	7.62	7.60	7.57	TR	TR
3/28/2014	Off	Off	Off	0645	0655	38	- -	- -	- -	7.59	7.58	7.06	TR	TR
3/29/2014	Off	Off	Off	1500	1510	38	- -	- -	- -	7.41	7.30	7.25	SH	SH
3/30/2014	Off	Off	Off	0705	0715	40	- -	- -	- -	7.59	7.60	7.62	TR	TR
3/31/2014	Off	Off	Off	0700	0710	41	- -	- -	- -	7.52	7.49	7.57	FP	FP

Mo Avg	NA	NA	NA	7.3	7.3	7.2
MAX	NA	NA	NA	7.6	7.7	7.6
MIN	NA	NA	NA	6.8	6.8	6.8

DMR Data for Outfall SUM-T		
	Actual	**Limit**
Min pH	6.8	6.5
Max pH	7.7	9.0
Daily Avg. Temp.	48	NA
Daily Max Temp.	56	105
Inst. Max Delta T	18	20
Flow, Mo Avg	54	70
Flow, Daily Max	71	80
Chlorine, Mo Avg	NA	0.1
Chlorine, Daily Max	NA	0.1

Kendall Green Energy LLC
265 First Street
Cambridge, MA 02142
T 617 679 4800 F 617 354 1301

NPDES Permit No. MA0004898
Kendall Green Energy LLC
265 First Street, Cambridge, MA
Daily Flow and Temperature Summary
Outfall 001 through 004

	Max Flow Rate (MGD)	Min Flow Rate (MGD)	Total Flow (MGD)	Maximum Delta T (F)	Average Delta T (F)	Maximum Outfall Temp. (F)	Average Outfall Temp. (F)
3/1/2014	45	45	45	15	12	49	46
3/2/2014	57	45	53	15	14	52	47
3/3/2014	57	45	52	13	11	48	45
3/4/2014	71	32	56	13	6	47	39
3/5/2014	71	71	71	7	3	43	36
3/6/2014	71	71	71	4	3	40	36
3/7/2014	71	45	47	15	7	50	41
3/8/2014	71	45	60	18	13	52	48
3/9/2014	71	45	69	11	9	50	44
3/10/2014	45	45	45	17	14	52	49
3/11/2014	57	45	53	17	15	54	51
3/12/2014	57	57	57	16	14	54	51
3/13/2014	57	57	57	14	10	51	45
3/14/2014	57	57	57	14	12	50	47
3/15/2014	57	57	57	15	14	52	50
3/16/2014	57	57	57	14	12	51	48
3/17/2014	57	45	50	13	11	49	46
3/18/2014	45	45	45	17	13	54	49
3/19/2014	71	45	58	15	12	53	49
3/20/2014	58	45	52	16	14	56	51
3/21/2014	58	45	53	16	12	54	50
3/22/2014	58	45	50	18	14	56	51
3/23/2014	58	45	52	13	11	53	49
3/24/2014	45	45	45	14	9	52	47
3/25/2014	45	45	45	16	12	55	50
3/26/2014	45	45	45	16	13	53	50
3/27/2014	45	45	45	17	14	54	51
3/28/2014	71	45	53	16	14	56	52
3/29/2014	71	71	70	16	13	56	52
3/30/2014	71	57	57	15	14	56	54
3/31/2014	57	57	57	14	12	56	53
Monthly	71	32	54	18	11	56	48

Kendall Green Energy LLC
265 First Street
Cambridge, MA 02142
T 617 679 4800 F 617 354 1301

NPDES Permit No. MA0004898
Kendall Green Energy LLC
265 First Street, Cambridge, MA
Daily Flow Summary
Outfall 005 through 007

	Total Flow (MGD) Outfall 005 Screenhouse No. 1	Total Flow (MGD) Outfall 006 Screenhouse No. 2	Total Flow (MGD) Outfall 007 Screenhouse No. 3
3/1/2014	0.001	0.001	0.000
3/2/2014	0.001	0.001	0.000
3/3/2014	0.001	0.001	0.000
3/4/2014	0.001	0.001	0.000
3/5/2014	0.002	0.002	0.001
3/6/2014	0.002	0.002	0.001
3/7/2014	0.002	0.002	0.001
3/8/2014	0.002	0.002	0.001
3/9/2014	0.002	0.002	0.001
3/10/2014	0.002	0.002	0.001
3/11/2014	0.002	0.002	0.001
3/12/2014	0.002	0.002	0.001
3/13/2014	0.001	0.001	0.001
3/14/2014	0.001	0.001	0.001
3/15/2014	0.001	0.001	0.001
3/16/2014	0.002	0.001	0.001
3/17/2014	0.002	0.001	0.001
3/18/2014	0.002	0.001	0.000
3/19/2014	0.002	0.001	0.000
3/20/2014	0.002	0.001	0.001
3/21/2014	0.002	0.001	0.001
3/22/2014	0.001	0.001	0.001
3/23/2014	0.002	0.002	0.001
3/24/2014	0.002	0.002	0.001
3/25/2014	0.002	0.002	0.001
3/26/2014	0.002	0.002	0.001
3/27/2014	0.001	0.001	0.001
3/28/2014	0.002	0.002	0.001
3/29/2014	0.001	0.001	0.001
3/30/2014	0.001	0.001	0.001
3/31/2014	0.002	0.002	0.001
Monthly	0.002	0.002	0.001

Kendall Green Energy LLC
265 First Street
Cambridge, MA 02142
T 617 679 4800 F 617 354 1301

NPDES Permit No. MA0004898
Kendall Green Energy LLC
265 First Street, Cambridge, MA
Daily Heat Load Calculation
Outfall 001 through 004

	Monthly Average (mBTU/d)	Daily Max (mBTU/d)
April 2013	6,045	10,308
May 2013	0	0
June 2013	79	996
July 2013	287	2,092
August 2013	1,812	6,805
September 2013	3,709	8,961
October 2013	3,059	9,036
November 2013	6,088	9,075
December 2013	4,390	8,456
January 2014	3,417	6,538
February 2014	5,286	7,390
March 2014	5,058	7,826
12 Month Avg.	3,269	

NPDES Permit No. MA0004898
Hourly flow rates and Delta T
March 2014

Kendall Green Energy LLC
265 First Street
Cambridge, MA 02142

March 2014			0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	Daily Avg	Daily Max	Total
3/1/2014	Delta T.	F°	10.5	10.6	10.5	10.2	10.1	9.7	10.1	10.4	11.6	11.9	12.3	12.4	12.3	13.2	13.9	14.2	14.3	14.3	14.4	14.6	14.7	15.1	15.3	13.7	13	15	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9		
	Heat Rate	mmBTU	162	165	163	159	157	151	156	162	179	184	191	193	191	205	216	220	222	222	224	226	228	235	238	213	194.3		4664.0
3/2/2014	Delta T.	F°	12.4	14.6	13.8	14.1	14.7	14.7	10.9	13.9	14.4	13.8	13.4	13.8	14.4	14.4	13.7	13.4	10.8	13.3	14.2	14.0	13.7	13.2	13.3	9.3	13	15	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.2		
	Heat Rate	mmBTU	193	226	214	219	229	228	169	218	286	274	264	274	285	285	271	265	215	263	282	277	271	262	264	184	246.5		5916.7
3/3/2014	Delta T.	F°	13.0	13.0	13.0	12.2	11.3	10.8	10.8	10.7	10.7	10.5	9.8	9.4	10.0	9.1	11.7	11.5	11.7	12.3	12.9	12.5	12.5	11.4	11.3	10.6	11	13	
	Total flow	MGH	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.2		
	Heat Rate	mmBTU	258	258	258	241	224	214	213	211	212	207	193	185	198	181	182	179	182	190	200	194	194	177	176	165	203.9		4892.6
3/4/2014	Delta T.	F°	10.6	11.0	10.7	10.3	9.6	10.6	11.2	12.1	12.5	12.7	11.5	1.6	0.8	0.2	0.5	3.3	0.1	0.1	0.4	0.4	0.2	0.1	0.1	0.2	5	13	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.1	2.8	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.3		
	Heat Rate	mmBTU	164	171	167	160	149	165	174	189	194	197	179	26	12	3	10	80	1	3	9	11	5	3	3	4	86.6		2079.2
3/5/2014	Delta T.	F°	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.5	3.9	4.9	4.9	5.4	5.5	4.6	4.6	4.5	4.4	6.5	7.4	4.3	2.4	2.1	2.3	3	7	
	Total flow	MGH	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9		
	Heat Rate	mmBTU	2	0	0	0	0	0	0	2	11	96	121	119	133	135	113	113	111	107	158	182	104	59	53	57	70.0		1678.8
3/6/2014	Delta T.	F°	2.2	2.4	3.4	2.4	1.9	1.9	2.2	3.2	3.6	3.7	3.9	3.8	4.3	4.2	4.1	4.1	3.9	4.1	1.5	0.0	0.0	0.0	0.0	0.0	3	4	
	Total flow	MGH	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9		
	Heat Rate	mmBTU	53	59	84	59	47	48	53	79	87	91	95	93	105	104	101	100	96	99	37	1	0	0	0	1	62.2		1492.5
3/7/2014	Delta T.	F°	0.1	0.2	0.2	0.3	1.6	5.9	5.7	6.3	7.7	7.6	7.9	7.1	5.7	7.8	10.2	9.6	9.2	11.1	10.9	10.4	10.6	10.4	14.6	12.3	7	15	
	Total flow	MGH	2.9	2.7	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9		
	Heat Rate	mmBTU	3	4	4	5	25	92	89	97	120	119	123	110	88	121	159	149	143	173	170	161	164	161	227	192	112.5		2698.9
3/8/2014	Delta T.	F°	13.9	12.7	9.9	8.4	9.0	9.3	8.9	10.0	11.6	14.8	16.4	17.1	17.2	17.6	17.7	17.6	16.8	16.6	16.5	12.8	10.6	10.5	10.6	10.6	13	18	
	Total flow	MGH	1.9	2.4	2.9	2.9	2.9	2.9	2.9	2.6	2.4	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.5	2.8	2.9	2.9	2.9	2.5		
	Heat Rate	mmBTU	216	254	243	206	220	228	219	219	236	266	295	306	309	316	318	316	301	298	297	263	249	257	261	259	264.8		6354.1
3/9/2014	Delta T.	F°	10.8	10.8	9.8	7.8	7.8	7.9	7.7	7.5	7.6	7.5	8.0	8.4	8.7	8.9	9.3	9.6	9.7	9.7	9.4	8.7	8.6	8.7	9.0	13.6	9	14	
	Total flow	MGH	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	1.9	2.9		
	Heat Rate	mmBTU	265	265	240	191	192	194	189	185	186	183	196	206	214	217	229	236	238	238	231	214	211	212	221	215	215.4		5168.6
3/10/2014	Delta T.	F°	14.0	13.3	14.0	13.8	13.3	11.5	10.7	11.0	11.6	12.0	12.2	12.6	13.1	13.4	12.9	14.6	15.3	15.1	15.6	15.8	16.1	16.6	16.3	16.3	14	17	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9		
	Heat Rate	mmBTU	217	207	217	214	207	179	166	170	181	186	189	196	203	208	201	228	238	235	242	245	249	258	253	253	214.2		5141.6
3/11/2014	Delta T.	F°	16.5	16.9	16.9	16.9	16.3	15.1	17.2	16.3	17.3	15.5	14.6	12.8	13.7	14.3	14.7	14.2	14.1	13.9	13.9	13.8	13.9	13.8	14.3	14.0	15	17	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.2	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.2		
	Heat Rate	mmBTU	257	263	263	263	253	235	268	253	268	283	288	253	272	283	291	281	279	274	275	274	274	273	283	276	270.1		6482.4
3/12/2014	Delta T.	F°	13.9	13.9	14.2	14.3	14.0	13.4	13.9	14.9	15.1	16.5	14.8	15.4	15.8	15.3	15.2	13.8	13.6	13.6	13.9	14.4	14.9	14.8	13.7	14.1	14	16	
	Total flow	MGH	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4		
	Heat Rate	mmBTU	274	274	280	282	277	265	275	294	298	326	292	304	312	303	302	273	268	269	275	285	294	294	271	280	286.2		6867.8
3/13/2014	Delta T.	F°	13.9	13.5	13.1	13.3	13.1	12.1	10.3	9.3	8.7	8.5	8.4	8.4	8.1	8.1	8.4	8.6	8.4	8.6	8.5	8.4	8.1	8.3	8.5	9.2	10	14	
	Total flow	MGH	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4		
	Heat Rate	mmBTU	275	267	259	263	259	239	203	184	171	168	167	166	159	161	166	169	166	169	168	166	161	164	168	182	192.5		4620.1
3/14/2014	Delta T.	F°	10.8	10.8	10.6	10.7	10.2	10.0	9.8	10.0	11.4	12.1	11.7	12.8	13.6	13.5	13.1	12.7	12.2	11.5	12.4	12.5	12.9	14.2	14.1	13.7	12	14	
	Total flow	MGH	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4		
	Heat Rate	mmBTU	214	214	210	212	201	197	194	198	225	240	231	254	269	268	260	251	242	228	246	248	255	280	280	271	237.0		5688.9
3/15/2014	Delta T.	F°	13.3	13.6	13.6	12.9	13.4	13.2	13.0	13.1	13.9	14.6	14.5	13.9	14.9	15.2	15.5	14.8	14.4	14.5	14.3	14.2	14.2	14.0	14.2	14.2	14	15	
	Total flow	MGH	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4		
	Heat Rate	mmBTU	262	269	269	256	265	261	257	259	275	289	286	275	295	300	306	294	285	287	283	282	281	277	280	281	278.2		6676.6
3/16/2014	Delta T.	F°	13.2	12.8	12.3	12.3	12.6	12.3	12.5	11.9	11.9	12.4	12.5	12.5	12.8	12.4	12.5	12.5	12.5	12.1	12.1	12.0	11.5	11.6	11.2	10.7	12	13	
	Total flow	MGH	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4		
	Heat Rate	mmBTU	261	253	243	243	249	243	247	236	235	245	247	247	253	244	248	248	247	239	240	237	227	230	223	211	241.5		5795.0
3/17/2014	Delta T.	F°	10.6	10.4	10.1	9.1	7.9	7.9	11.1	10.7	11.1	10.5	10.0	12.2	12.2	11.6	10.6	9.5	11.9	12.0	12.6	12.5	12.8	13.2	12.9	12.8	11	13	
	Total flow	MGH	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.1		
	Heat Rate	mmBTU	210	205	201	181	156	156	219	213	219	207	197	197	190	180	165	147	184	187	195	195	199	205	201	199	191.9		4606.0
3/18/2014	Delta T.	F°	12.4	12.1	11.9	11.5	10.7	11.5	10.8	10.9	12.0	13.3	14.5	16.4	16.9	15.1	13.9	13.5	13.7	12.9	13.6	13.5	14.4	14.4	14.6	14.7	13	17	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9		
	Heat Rate	mmBTU	192	188	185	178	166	179	168	169	187	206	225	255	262	235	216	210	213	201	211	210	223	223	227	228	206.5		4956.0
3/19/2014	Delta T.	F°	14.7	14.3	13.5	12.6	12.1	10.8	9.3	13.6	14.8	12.2	12.2	12.4	12.3	12.2	12.1	9.5	9.0	9.4	9.7	9.7	10.5	15.3	15.4	15.6	12	16	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.4	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.8	1.9	1.9	1.9	2.4		
	Heat Rate	mmBTU	229	222	210	195	188	167	144	212	293	300	298	305	302	300	297	233	222	232	239	238	246	238	239	243	241.3		5790.9
3/20/2014	Delta T.	F°	15.5	16.0	15.9	15.7	15.7	13.5	12.7	12.7	13.7	14.1	14.7	15.5	13.5	12.4	12.3	13.1	13.1	13.2	12.9	12.8	13.2	13.5	13.5	13.5	14	16	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.1		
	Heat Rate	mmBTU	241	248	247	244	244	210	197	197	212	220	228	241	264	252	249	266	265	269	261	260	268	274	274	274	246.0		5904.9
3/21/2014	Delta T.	F°	13.5	13.3	12.8	12.0	11.7	11.0	9.0	9.0	9.5	8.5	8.7	9.6	10.1	9.4	10.1	13.1	13.8	13.5	14.9	15.0	15.1	15.2	15.6	15.3	12	16	
	Total flow	MGH	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.0	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.2		
	Heat Rate	mmBTU	273	270	259	243	237	222	184	183	193	173	177	195	204	190	205	217	215	210	231	232	234	236	243	238	219.3		5263.9
3/22/2014	Delta T.	F°	13.2	13.3	13.1	12.5	12.6	12.8	13.2	12.5	12.8	13.2	13.4	13.7	14.7	16.3	17.0	17.6	14.8	12.9	12.9	13.0	12.7	12.4	11.7	11.4	13	18	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.2	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.0		
	Heat Rate	mmBTU	204	207	203	194	196	199	206	195	199	204	208	212	229	253.0	263.8	273.9	277.3	261.7	261	265	258	252	236	232	228.8		5490.6
3/23/2014	Delta T.	F°	11.0	10.2	10.0	10.1	9.8	9.6	9.3	9.0	8.9	9.4	9.1	9.2	9.0	11.1	12.8	12.7	12.4	12.1	12.0	11.6	11.8	10.6	10.0	9.4	10	13	
	Total flow	MGH	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.1	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.2		
	Heat Rate	mmBTU	223	206	204	205	198	196	188	183	181	192	185	187	183	198	198	197	193	189	187	180	183	165	155	146	188.4		4521.4
3/24/2014	Delta T.	F°	7.6	7.0	7.7	7.5	7.6	7.0	8.9	10.7	11.9	13.6	9.5	10.5	11.1	8.7	7.8	8.1	7.8	8.2	8.5	8.3	8.5	8.9	8.9	8.6	9	14	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9		
	Heat Rate	mmBTU	118	108	119	116	118	109	139	166	184	211	147	162	173	135	122	126	121	127	131	129	133	137.5	138.0	133.4	137.8		3306.4
3/25/2014	Delta T.	F°	8.6	8.4	8.2	8.3	8.0	8.0	8.5	8.7	11.5	10.4	12.6	13.2	12.6	13.5	14.1	14.0	14.6	14.8	15.5	15.3	15.4	15.5	15.9	14.9	12	16	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9		
	Heat Rate	mmBTU	133	131	127	129	124	125	132	135	179	162	196	205	196	210	219	217	227	230	241	237	239	241	246	232	188.1		4513.2
3/26/2014	Delta T.	F°	14.6	14.6	14.4	14.4	13.5	12.5	11.0	11.1	11.2	11.2	11.3	11.4	12.4	11.9	12.1	12.1	12.1	12.5	13.0	12.2	13.0	14.2	13.6	13.4	13	15	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9		
	Heat Rate	mmBTU	226	226	224	223	210	194	171	172	174	174	175	178	193	184	188	188	188	194	202	189	202	220	211	208	196.4		4713.0
3/27/2014	Delta T.	F°	13.6	12.8	10.9	10.6	10.8	9.5	8.9	12.5	14.7	14.8	14.6	14.9	14.8	14.7	15.7	16.5	16.6	16.3	15.0	14.6	14.6	14.9	14.4	14.0	14	17	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9		
	Heat Rate	mmBTU	212	199	169	165	168	147	138	194	228	230	227	231	230	228	243	256	258	254	233	226	227	232	224	218	214.1		5138.8
3/28/2014	Delta T.	F°	14.7	14.0	14.3	14.2	13.7	12.5	11.6	12.5	13.8	14.5	15.5	16.2	16.1	14.8	14.4	14.2	14.1	14.1	14.3	14.2	14.5	14.0	11.9	13.8	14	16	
	Total flow	MGH	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.1	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.9	2.9	2.2		
	Heat Rate	mmBTU	228	218	221	221	212	194	180	193	214	225	241	252	287	292	285	282	279	280	283	282	288	281	292	338	252.8		6067.7
3/29/2014	Delta T.	F°	15.9	15.9	15.9	16.3	15.1	14.6	14.2	13.9	13.4	13.5	13.5	13.0	13.1	12.6	12.4	12.2	12.2	12.0	11.6	11.6	11.8	11.8	11.6	10.9	13	16	
	Total flow	MGH	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9		
	Heat Rate	mmBTU	390	391	390	399	370	359	347	341	330	330	330	318	321	310	305	300	298	294	285	286	290	289	284	268	326.1		7825.7
3/30/2014	Delta T.	F°	12.4	14.6	14.7	14.5	14.5	14.4	14.3	13.9	14.1	14.1	14.0	13.9	13.5	13.7	13.7	13.8	13.9	13.9	14.1	14.1	13.7	14.0	12.8	12.6	14	15	
	Total flow	MGH	2.7	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4		
	Heat Rate	mmBTU	280	288	290	288	286	285	282	275	279	279	278	275	267	271	272	273	274	275	278	279	272	278	252	250	276.1		6625.5