TestAmerica Analytical Testing Corporation

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. Havens St.
Kokomo, IN 46901-3188

Job Number: 03.11991
Report Date: 06/18/2003

Enclosed is the Analytical Report for the following samples submitted to TestAmerica for analysis:

Project: MONTHLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
850511	MONTHLY COMP	06/06/2003	06/06/2003
850512	MONTHLY GRAB	06/05/2003	06/06/2003

TestAmerica, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this report is permitted only in its entirety.

Enclosure

Project Management Approval

Kim Sandrick

Dayton - 3601 South Dixie Drive, Dayton, OH 45439 937-294-6856/FAX:937-294-7816
Dundee (Chicago) - 1090 Rock Road Lane, Unit 11, Dundee, IL 60118 847-783-4960/FAX:847-783-4969
Indianapolis - 6964 Hillsdale Court, Indianapolis, IN 46250 317-842-4261/FAX:317-842-4286
Pontiac - 341 W. Walton Blvd, Pontiac, MI 48340 248-332-1940/FAX:248-332-5450

TestAmerica Analytical Testing Corporation
Analytical Report

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. Havens St.
Kokomo, IN 46901-3188

Job Number: 03.11991
Report Date: 06/18/2003

SAMPLE NO. 850511 **SAMPLE DESCRIPTION** MONTHLY COMP **DATE/TIME TAKEN** 06/06/2003 09:30

	Result	Units	Reporting Limit	Flag	Run Date	Run Time	Prep Batch	Run Batch	Anal. Init.	Lab ID	Method Reference
CBOD Prep	Complete		Complete		06/07/2003		2502		apc	DT	
CBOD - Five Day	16	mg/L	<4	a	06/18/2003		2502	2813	apc	DT	SM 5210
COD	73	mg/L	<20.	A	06/10/2003	08:55		1212	tpd	IN	EPA 410.4
Nitrogen, Ammonia Dist.	3.7	mg/L	<0.10		06/12/2003	13:23	140	1274	jss	IN	EPA 350.1
Solids, Suspended	110	mg/L	<5.		06/09/2003	16:07		2066	mhl	IN	EPA 160.2
Distillation, Ammonia	Complete		Complete		06/12/2003	11:00	140		mhl	IN	
ICPMS TOTAL METALS	Complete		Complete		06/10/2003	16:33		3900	ekh	DT	EPA 200.8
Cadmium, ICPMS	<0.0040	mg/L	<0.0010		06/10/2003	16:33	2614	5146	ekh	DT	EPA 200.8
Chromium, ICPMS	<0.0200	mg/L	<0.0020		06/10/2003	16:33	2614	5759	ekh	DT	EPA 200.8
Copper, ICPMS	0.0679	mg/L	<0.0050		06/10/2003	16:33	2614	5308	ekh	DT	EPA 200.8
Lead, ICPMS	<0.004	mg/L	<0.0010		06/10/2003	16:33	2614	5227	ekh	DT	EPA 200.8
Molybdenum, ICPMS	0.0323	mg/L	<0.0010		06/10/2003	16:33	2614	5527	ekh	DT	EPA 200.8
Nickel, ICPMS	0.146	mg/L	<0.0050		06/10/2003	16:33	2614	5274	ekh	DT	EPA 200.8
Silver, ICPMS	<0.002	mg/L	<0.0005		06/10/2003	16:33	2614	5503	ekh	DT	EPA 200.8
Zinc, ICPMS	0.061	mg/L	<0.050		06/10/2003	16:33	2614	5109	ekh	DT	EPA 200.8
Digestion, ICPMS	Complete		Complete		06/09/2003	10:00	2614		kmb	DT	EPA 200.2

SAMPLE NO. 850512 **SAMPLE DESCRIPTION** MONTHLY GRAB **DATE/TIME TAKEN** 06/05/2003 09:30

	Result	Units	Reporting Limit	Flag	Run Date	Run Time	Prep Batch	Run Batch	Anal. Init.	Lab ID	Method Reference
Cyanide - Prep	Complete		Complete		06/12/2003	10:30	842		sld	IN	
Cyanide, Total	<0.005	mg/L	<0.005		06/13/2003	14:19	842	1131	jss	IN	EPA 335.4

A - Sample was not sufficiently preserved at time of collection.
a - See Notes and Comments Section for detailed explanation.

Lab ID: CH = Chicago (Dundee), DT = Dayton, IN = Indianapolis, PT = Pontiac, SUB = Subcontracted, CLT = Client Data

TestAmerica Analytical Testing Corporation
Notes and Comments

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. Havens St.
Kokomo, IN 46901-3188

Job Number: 03.11991
Report Date: 06/18/2003

Sample Number: 850511

Analysis: BOD

Due to a lab accident where the samples were analyzed after the incubation of five days per the method, the results are therefore biased high and should be reported and considered as estimates only.

TestAmerica INCORPORATED Division/Laboratory Name: Indianapolis Division

To assist us in using the proper analytical methods, is this work being conducted for regulatory purposes?
Compliance Monitoring Yes No
Enforcement Action Yes No

Client Name: Milbank Client #:
Address: 1400 East Havens Street
City/State/Zip Code: Kokomo, IN 56901-3188
Project Manager: Mr. Richard Tyler
Telephone Number: 765-452-5694 Fax:
Sampler Name: (Print Name) Nate Beckman
Sampler Signature: [signature]

Report To: Mr. Richard Tyler
Invoice To:
Quote #: 98.0060 PO#:
Project Name: Monthly Wastewater
Project #:
Site/Location ID: State: IN

___ Standard
___ Rush (surcharges may apply) ___ Other:
Date Needed:
Fax Results: Y N

QC Deliverables
___ None
___ Level 2 (Batch QC)
___ Level 3
___ Level 4
Other: _____

SAMPLE ID	Date Sampled	Time Sampled	G = Grab, C = Composite	Field Filtered	Matrix: SL - Sludge DW - Drinking Water GW - Groundwater S - Soil/Solid WW - Wastewater Specify Other	Preservation & # of Containers: HNO_3 (Red Label)	HCl (Blue Label)	NaOH (Orange Label)	H_2SO_4 Plastic (Yellow Label)	H_2SO_4 Glass(Yellow Label)	None (Black Label)	Other (Specify)	Analyze For: CBOD, COD, TSS,	Ammonia, Mo, Zn		Cd,Cr,Cu,Pb,Ni,Ag							REMARKS
Monthly - Comp	6/6/03	9:30	C	N	WW						17		X	X		X							
Monthly - Grab	6/5/03	930	G	N	WW			1							X								

Special Instructions:
********PLEASE COMPOSITE USING FLOW READINGS ATTACHED********

	Date:	Time:		Date:	Time:
Relinquished By: [signature]	6/6/03	1240	Received By: [signature]	6/6/03	1240
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

LABORATORY COMMENTS:
Init Lab Temp: 2.3°C
Rec Lab Temp:
Custody Seals: Y N N/A
Bottles Supplied by TestAmerica: Y N
Method of Shipment:

MIL0002186

DATE: 6-5-03

MILBANK MANUFACTURING COMPANY

BEGINNING READING @ 7:00 AM 779730

TIME	METER READING	INITIAL
7:30	779740	SLH
8:00	779910	SLH
8:30	780120	SLH
9:00	780340	SLH
9:30	780500	SLH
10:00	780700	SLH
10:30	780900	SLH
11:00	781090	SLH
11:30	781290	SLH
12:00	781480	SLH
12:30	781670	SLH
1:00	781860	SLH
1:30	782090	SLH
2:00	782240	SLH
2:30	782430	SLH
3:00	782570	SLH
3:30	782770	SLH

Regulated Parameters	Notes	Local Discharge Limitations		Categorical Discharge Limitations [8]		Monitoring Requirements	
		Daily Maximum (mg / L)	Monthly Average (mg / L)	Daily Maximum (mg / L)	Monthly Average (mg / L)	Frequency	Sample Type
Cadmium	2, 5, 6, 9, 10	0.02	-	0.69	0.26	1 X Month	Composite
Total Chromium	2, 5, 6, 9, 10	2.0	-	2.77	1.71	1 X Month	Composite
Copper	2, 5, 6, 9	0.6	-	3.38	2.07	1 X Month	Composite
Cyanide	5, 6, 9	0.5	-	1.20	0.65	1 X Month	Grab
Lead	2, 5, 6, 9, 10	0.1	-	0.69	0.43	1 X Month	Composite
Nickel	2, 5, 6, 9, 10	0.8	-	3.98	2.38	1 X Month	Composite
Silver	2, 5, 6, 9, 10	0.24	-	0.43	0.24	1 X Month	Composite
Zinc	2, 5, 6, 9	1.25	-	2.61	1.48	1 X Month	Composite
Molybdenum	2, 5, 6, 9	Monitor & Report		-	-	1 X Month	Composite
pH	9	6-10 (Std. Units)	-	-	-	Daily	Grab
CBOD5	2, 4, 9	Monitor & Report		-	-	1 X Month	Composite
COD	2, 4, 9	Monitor & Report		-	-	1 X Month	Composite
TSS	2, 4, 9	Monitor & Report		-	-	1 X Month	Composite
Ammonia-N	2, 4, 9	Monitor & Report		-	-	1 X Month	Composite
TPH	6, 9	Monitor & Report		-	-	Semi-Annual	Grab
Fats, Oils and Grease	6, 7, 9	100	-	-	-	Semi-Annual	Grab
Flow	1, 9	-	-	-	-	Daily [3]	
TTO	6, 9	2.13	-	2.13	-	Semi-Annual	Grab
Phenol	6, 9	0.50	-	-	-	Semi-Annual	Grab

- The above listed discharge limitations and monitoring requirements are minimum requirements necessary to achieve compliance. Nothing in this permit shall prevent MMCI from achieving discharge concentrations that are more protective/restrictive than the requirements of this table

MIL0002188

6/5/03

BOTTLE #	METER READING	DIFFERENCE	VOLUME NEEDED (mL)
INITIAL METER READING	[illegible]		
1	[illegible]	10	7
2		170	112
3		210	138
4	[illegible]	220	145
5	[illegible]	160	105
6	[illegible]	200	132
7	[illegible]	200	132
8	[illegible]	190	125
9	[illegible]	200	132
10	781480	190	125
11	781670	190	125
12	781860	190	125
13	[illegible]	230	151
14	[illegible]	150	99
15	[illegible]	190	125
16	[illegible]	140	92
17	[illegible]	200	132
Total flow during composite sampling:			**TOTAL COMPOSITE VOLUME:**
3040			2000

340050001470000000000000032081003

INDIANA-AMERICAN WATER CO.INC.
KOKOMO
P. O. BOX 907
RICHMOND, IN 47375-0907

ACCOUNT NUMBER	340050001470(
AMOUNT DUE	$320.81
DUE DATE	07-28-2003

Please return this portion with check
Payable to the address below

000008391 01 AB 0.301
MILBANK MFG CO INC
P O BOX 754
KOKOMO IN 46903-0754

INDIANA-AMERICAN WATER CC
P. O. BOX 2555
DECATUR IL 62525-2555

Service address:
1005 RANK PY

Customer Account Information

Service to: 340-05000147-00 8
MILBANK MFG CO INC
1005 RANK PY

BILLING PERIOD
Jun.05,2003 TO Jul.07,2003
Date Billed 07-10-2003
Service for 32 Days
Next Reading on/about Aug. 05

METER READING INFORMATION

* - Meter number -	031697349
Current-Actual	0412800
Prior	0401000
Cubic Feet Usage	11800
* - Meter number -	037146496
Current-Actual	000000
Prior	000000
Cubic Feet Usage	0
Total cu.ft. Usage	11800
GAL.	88500

Billing Summary

Prior Billing	341.25
Payments, Jul.02,2003,Thank You	341.25CR
Prior Balance Jul.09,2003	.00
Current Charges	
Water Charge	302.65
Indiana Gross Retail Tax	18.16
AMOUNT DUE	**$320.81**

DATE: 6-5-03

MILBANK MANUFACTURING COMPANY

BEGINNING READING @ 7:00 AM 779730

TIME	METER READING	INITIAL
7:30	779740	SLH
8:00	779910	SLH
8:30	780120	SLH
9:00	780340	SLH
9:30	780500	SLH
10:00	780700	SLH
10:30	780900	SLH
11:00	781090	SLH
11:30	781290	SLH
12:00	781480	SLH
12:30	781670	SLH
1:00	781860	SLH
1:30	782090	SLH
2:00	782240	SLH
2:30	782430	SLH
3:00	782570	SLH
3:30	782770	SLH

Fifth Stage

Chemical Specialties

Marcus Bryant
913-661-0767

Date 2003	Initial	Pressure	PH Stage 5	Addition of Rinse 50 1 pint/4 hours of run time		Conductivity of Stage 5		Conductivity of Stage 2		Conductivity of Stage 4		Clean Screens	Clean Nozzles	Comments
Ranges		15 - 25	4.0 – 5.5	AM	PM	< 2000uS		< 1500uS		< 1500uS		Daily	Weekly	
						AM	PM	AM	PM	AM	PM			
6-2	DKK	10	5.0	8:00	1:10	2.37	2.38	2.21	2.28	1.01	1.05			
6-3	DKK	10	5.0	7:45	1:00	2.36	2.37	2.31	2.36	1.24	1.33			
6-4	DKK	10	5.1	8:30	2:00	2.38	2.38	2.40	2.51	1.39	1.45			
6-5	DKK	10	5.1	7:35	2:30	2.40	2.41	73	.86	.63	.64			
6-6	DKK	10	4.9	7:30		2.44		93		.73				
6-9	DKK	10	5.0	8:00		2.45	2.46	1.31		.80				
6-10	DKK	10	5.0	7:45	1:15	2.47	2.49	1.71	1.77	.84	.86			
6-11	DKK	10	5.0	7:30	1:00	2.47	2.48	1.85	1.97	.89	.96			
6-12	DKK	10	4.9	7:45	1:30	2.46	2.47	2.19	2.31	1.10	1.30			
6-13	DKK	10	4.8	7:09		2.36						Paint Line Shut Down		
6-16	DKK											6-13 – 6/7		
6-17	DKK													
6-18	DKK	10	5.1	7:35	1:30	2.17	2.21	2.82	2.86	1.64				
6-19	DKK							Vacation Day.						
6-20	DKK	10	5.1	7:40	12:30	2.16	2.19	2.91	2.99	1.68	1.71			
6-23	DKK	10	5.0	7:15	12:45	2.19	2.21	3.07	3.21	1.74	1.87			
6-24	DKK	10	5.1	7:30	1:30	2.18	2.19	3.32	3.41	1.88	1.91			
6-25	DKK	10	5.1	7:35	1:00	2.02	2.05	3.54	3.61	1.93	1.95			
6-26	DKK	10	5.0	7:15	12:30	2.11	2.15	.78	.84	.67	.74			
6-27	DKK	10	5.0	7:45	12:45	2.20	2.25	.91	1.12	.79	.83			
6-30	DKK	10	5.0	7:50	1240	2.19	2.22	1.31	1.40	1.30	1.34			

MIL0002192

Chemical Specialties

Third Stage

Marcus Bryant
913-661-0767

Date 2003	Initial	Concentration	Pressure	Temperature	pH	Replacements of drums	Clean Screens	Clean Nozzles	Comments
Ranges		1.65 – 2.31	15 – 25	120°–130°	4.0 – 5.5	Paint Lok 595	Daily	Weekly	
6-2	DKK	1.65	15	129	5.93				
6-3	DKK	1.65	15	130	5.95				
6-4	DKK	1.65	15	128	5.97				
6-5	DKK	1.32	15	130	6.00				
6-6	DKK	1.32	15	130	6.03				
6-9	DKK	1.65	15	128	5.67				
6-10	DKK	1.98	15	130	5.31				
6-11	DKK	1.98	15	130	5.29				
6-12	DKK	1.98	15	129	5.33				
6-13									Paint Line shut down
6-16									New tank in stage 1
6-17									6-13 - 6-17
6-18	DKK								
6-19	DKK	Vacation		Day					
6-20	DKK	2.64	15	130	5.27				
6-23	DKK	2.97	15	130	5.13				
6-24	DKK	2.97	15	131	5.17				
6-25	DKK	2.97	15	130	5.21				
6-26	DKK	2.31	15	130	5.24				
6-27	DKK	2.31	15	130	5.27				
6-30	DKK	2.31	15	130	5.34				

MIL0002193

Chemical Specialties

Marcus Bryant
913-661-0767

First Stage

Date 2003	Initial	Concentration	Pressure	Temperature	pH	Replacements of drums	Clean Screens	Clean Nozzles	Comments
Ranges		1.40 – 1.80	15 – 25	120°–130°	9.5 – 11.0	Cleaner 419C	Daily	Weekly	
6-2	DKK	1.80	15	130	9.81				
6-3	DKK	1.80	15	131	9.84				
6-4	DKK	1.80	15	131	9.87				
6-5	DKK	1.80	15	131	9.90				
6-6	DKK	1.60	15	131	9.93				
6-9	DKK	1.60	15	129	9.87				
6-10	DKK	1.60	15	130	9.85				
6-11	DKK	1.60	15	131	9.84				
6-12	DKK	1.60	15	130	9.82				
6-13									Paint line shut down
6-16									New tank in stage 1
6-17									6-13 - 6-17
6-18	DKK		15	130	9.67				
6-19	DKK	Vacation		Day					
6-20	DKK	1.60	15	130	9.64				
6-23	DKK	1.40	15	130	9.69				
6-24	DKK	1.40	15	131	9.74				
6-25	DKK	1.40	15	131	9.82				
6-26	DKK	1.40	15	131	9.86				
6-27	DKK	1.60	15	131	9.89				
6-30	DKK	1.60	15	131	9.87				

MIL0002194

MIL0002195

MILBANK MANUFACTURING
WASTEWATER TREATMENT PLANT
CHEMICAL LOG

DATE	FERRIC CHLORIDE (XXXX)		CALCIUM CHLORIDE FLAKES (XXXX)		CAUSTIC SODA (XXXX)		SULFURIC ACID (XXXX)		WATER		COMMENTS
	GALS USED	GALS REC.	GALS USED	GALS REC.	GALS USED	GALS REC.	GALS USED	GALS REC.	GALS USED	GALS REC.	
6-3	46AL		150#								Filled AT 8:10
6-3	46AL		150#								Filled At 3:20
6-4									46AL		Filled AT 8:40
6-4					20GAL						Filled AT 1:00
6-5	46AL		150#								Filled AT 7:45
6-5	46AL		150#								Filled AT 2:40
6-13							46AL				Filled AT 9:20
6-13									46AL		Filled AT 10:10
6-17	46AL		150#								Filled AT 11:10
6-17					20GAL						Filled AT 4:10
6-20	46AL		150#								Filled AT 11:20
6-26									46AL		Filled AT 7:20
6-26	46AL		150#								Filled At 9:20

MILBANK MFG. WASTEWATER TREATMENT PLANT
PH CALIBRATION/READING LOG SHEET

2003

TIME	DATE	SURFACE CLEANED? PER PRO	SURFACE CLEANED? PER TOOL	PROBE LOCATION	PROBE CLEANED	PH READING	PH CALIBRATION
7:20	6-3	Y	Y	NEUT 1	Y	4 + 10	3.98 4.00/9.97-9.99
7.20	6-3	Y	Y	NEUT 2	Y	4 + 10	3.99-4.00/9.98 10.00
2:10	6-3	Y	Y	FINAL	Y	9.13	4.00 + 10.00
7:10	6-4	Y	Y	NEUT 1	Y	4 + 10	3.99 4.00/9.97/9.99
7:10	6-4	Y	Y	NEUT 2	Y	4 + 10	4.00 4.02/9.98-10.00
3:00	6-4	Y	Y	FINAL	Y	9.40	4.00 + 10.00
7:15	6-5	Y	Y	NEUT 1	Y	4 + 10	3.97 4.01/9.98 9.99
7:15	6-5	Y	Y	NEUT 2	Y	4 + 10	4.00/4.03/10.00 10.02
2:45	6-5	Y	Y	FINAL	Y	9.07	4.00 + 10.00
7:30	6-13	Y	Y	NEUT 1	Y	4 + 10	3.99 4.00/9.98-9.99
7:30	6-13	Y	Y	NEUT 2	Y	4 + 10	4.00/4.02/9.97 10.00
1:30	6-13	Y	Y	FINAL	Y	9.15	4.00 + 10.00
10:45	6-17	Y	Y	NEUT 1	Y	4 + 10	4.00 4.02/9.98-9.99
10:45	6-17	Y	Y	NEUT 2	Y	4 + 10	4.00 4.01/9.97 10.00
2:00	6-17	Y	Y	FINAL	Y	9.01	4.00 + 10.00
7:00	6-20	Y	Y	NEUT 1	Y	4 + 10	3.99-4.01/9.99-10.00
7:00	6-20	Y	Y	NEUT 2	Y	4 + 10	4.00 4.02/9.97-10.00
1:30	6-20	Y	Y	FINAL	Y	9.09	4.00 + 10.00
8:00	6-26	Y	Y	NEUT 1	Y	4 + 10	4.00-4.02/9.98-9.99
8:00	6-26	Y	Y	NEUT 2	Y	4 + 10	4.00 4.01/9.97-10.00
1:45	6-26	Y	Y	FINAL	Y	8.83	4.00 + 10.00
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		

MILBANK MFG DISCHARGE LOG

SAMPLING POINT #2

2003

DATE	START TIME	METER READING	STOP TIME	METER READING	COMMENTS/MAINTENANCE
6-3	10:40	775060	3:25	776800	System
6-4	7:20	776840	3:15	779730	System
6-5	7:25	779730	3:30	782770	System Testing
6-10	7:00	782770	3:30	782770	Filter Press
6-11	7:00	782770	3:30	782770	Filter Press
6-13	11:30	782770	3:00	783610	System
6-17	11:00	783610	2:45	784950	System
6-20	7:15	784950	3:00	791240	System
6-26	8:25	791240	2:30	793410	System
6-27	7:00	793410	3:00	793410	Filter Press
6-30	7:00	793410	3:00	793410	Filter Press

REGULATED PARAMETERS (6)	Local Discharge Limitations (7)		Monitoring Requirements	
	Daily Maximum (mg / L)	Monthly Average (mg / L)	Frequency	Sample Type
Cadmium (5)	0.02	0.015	Semi-Annual	Composite {2}
Total Chromium (5)	2.0	1.2	Semi-Annual	Composite {2}
Copper (5)	0.6	0.4	Semi-Annual	Composite {2}
Cyanide (5)	0.5	0.3	Semi-Annual	Grab
Lead (5)	0.1	0.06	Semi-Annual	Composite {2}
Nickel (5)	0.8	0.5	Semi-Annual	Composite {2}
Silver (5)	0.24	0.15	Semi-Annual	Composite {2}
Zinc (5)	1.25	0.75	1 X Month	Composite {2}
Molybdenum (5)	Monitor and Report		1 X Month	Composite {2}
PH	6-10 (Std. Units)	---------	Daily	Grab
CBOD5 (4)	Monitor and Report		1 X Month	Composite {2}
COD (4)	Monitor and Report		1 X Month	Composite {2}
TSS (4)	Monitor and Report		1 X Month	Composite {2}
Ammonia-N (4)(1)	Monitor and Report		1 X Month	Composite {2}
TPH	Monitor and Report		Semi-Annual	Grab
Fats, Oils & Grease (8)	100		Semi-Annual	Grab
Flow	----------	---------	Daily (3)	
TTO	2.13	---------	Semi-Annual	Grab
Phenol	0.50	---------	Semi-Annual	Grab

DATE:

PLEASE TEST FOR THE FOLLOWING ITEMS HIGHTLIGHTED ABOVE……

Industrial Wastewater Pretreatment Monitoring Report
Sampling Point #2 (Part 1, A&B)

Milbank Mfg

Year 03 Month JUNE

Date	Flow	pH	Cd	Cr	Cu	Ni	Ag	Pb	Zn	Mo	TTO	Phenol	CN	TPH	FOG	NH3	CBOD	COD	TSS
1																			
2																			
3	1740	9.13																	
4	2930	9.40																	
5	3040	9.07	<.0040	<.020	.0679	.146	<.002	<.004	.061	.0323			<.005			3.7	16	73	110
6																			
7																			
8																			
9																			
10																			
11																			
12																			
13	840	9.15																	
14																			
15																			
16																			
17	1340	9.01																	
18																			
19																			
20	6290	9.09																	
21																			
22																			
23																			
24																			
25																			
26	2170	8.83																	
27																			
28																			
29																			
30																			
31																			
Daily LIMIT	N/A	N/A	.02	2.0	.6	.8	.24	.1	1.25	N/A	2.13	.5	.5	N/A	100	N/A	N/A	N/A	N/A
Average	2621	9.09	<.004	<.020	.0679	.146	<.002	<.004	.061	.0323			<.005			3.7	16	73	110
Maximum	6290	9.40	<.004	<.020	.0679	.146	<.002	<.004	.061	.0323			<.005			3.7	16	73	110
Minimum	840	8.83	<.004	<.020	.0679	.146	<.002	<.004	.061	.0323			<.005			3.7	16	73	110

TOTAL FLOW 88500 GAL

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is, true, accurate and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

_____ DATE_____

Authorized Company Representative