NATIONAL ENVIRONMENTAL TESTING, INC.

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

NOV 20 1998

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

11/16/1998

NET Job Number: 98.07683

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
223577	OUTFALL 001	11/05/1998	11/06/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Lou Barnett
Project Representative

NATIONAL ENVIRONMENTAL TESTING, INC.

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

NOV 20 1998

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

11/16/1998

Job No.: 98.07683

Date Received: 11/06/1998
Job Description: TWICE WEEKLY WASTEWATER

Sample Number / Sample I.D. Parameters	Result	Flag	Sample Date/ Units	Analyst & Date Analyzed	Method	Reporting Limit
223577 OUTFALL 001			11/05/1998			
Iron, ICP	2.7		mg/L	psc / 11/11/1998	EPA 200.7	<0.10
Lead, ICP	<0.080		mg/L	psc / 11/11/1998	EPA 200.7	<0.080
Silver, ICP	<0.020		mg/L	psc / 11/11/1998	EPA 200.7	<0.020
Zinc, ICP	0.10		mg/L	psc / 11/11/1998	EPA 200.7	<0.020

NET® NATIONAL ENVIRONMENTAL TESTING, INC.

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

NOV 20 1998

FIELD REPORT

JOB #: 98.07683
CLIENT: MILBANK MFG.
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 11/11/98
SAMPLER(S): MEM/CAB

An ISCO model 3710 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, ice, and strainer.

All reusable equipment is decontaminated with alconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 8 hours.

Monitoring start 7:30 on 11/05/98
Monitoring end 15:00 on 11/05/98

The composite sample was clear with a gray tint.

Notes: Samples were preserved, in the field, in the appropriate containers with any required preservative.

NATIONAL ENVIRONMENTAL TESTING, INC.

CHAIN OF CUSTODY RECORD

COMPANY Milliken Mfg.
ADDRESS 1400 E. Havens St.
PHONE 765.452.5694 FAX
PROJECT NAME/LOCATION Twice Weekly Wastewater
PROJECT NUMBER
PROJECT MANAGER Mr. Richard Tyler

REPORT TO:
INVOICE TO:
P.O. NO.
NET QUOTE NO. 98.0060

NOV 2 2 1998

SAMPLED BY

(PRINT NAME) SIGNATURE
(PRINT NAME) SIGNATURE

To assist us in selecting the proper method

Is this work being conducted for regulatory compliance monitoring? Yes ___ No ___

Is this work being conducted for regulatory enforcement action? Yes ___ No ___

Which regulations apply: RCRA ___ NPDES Wastewater ___ UST ___ Drinking Water ___ Other ___ None ___

DATE	TIME	SAMPLE ID/DESCRIPTION	MATRIX	GRAB	COMP	# and Type of Containers: HCl	NaOH	HNO_3	H_2SO_4	OTHER	ANALYSES: Iron	Lead	Silver	Zinc	Field Rpt					COMMENTS
11/5		Outfall 001	WW		1			1			✓	✓	✓	✓	✓					

CONDITION OF SAMPLE: BOTTLES INTACT? YES / NO
FIELD FILTERED? ~~YES / NO~~
COC SEALS PRESENT AND INTACT? ~~YES / NO~~
VOLATILES FREE OF HEADSPACE? ~~YES / NO~~
TEMPERATURE UPON RECEIPT: 5.2°C
Bottles supplied by NET? YES / NO

SAMPLE REMAINDER DISPOSAL: RETURN SAMPLE REMAINDER TO CLIENT VIA ___
I REQUEST NET TO DISPOSE OF ALL SAMPLE REMAINDERS ___ DATE ___

RELINQUISHED BY:	DATE	TIME	RECEIVED BY:	RELINQUISHED BY:	DATE	TIME	RECEIVED FOR NET BY:
[signature]	11/6	1300			11/6/98	13:00	[signature]

METHOD OF SHIPMENT

REMARKS:

PT 1 - ORIGINAL - WHITE PT 2 - NET PROJECT MANAGER - YELLOW PT 3 - CUSTOMER COPY - PINK

MIL0003025

MILBANK
MANUFACTURING CO. INC.
P.O. BOX 754
KOKOMO, IN 46903-0754
Phone: 3[redacted]-452-5694
765

DATE 11-19-98

TO RON BARNETT
NET LABS-

ATTN ROV

PAGE 1 OF 2

FROM R Tyler

FAX NO:
~~317~~-452-8361
765

This is a copy of our new sampling requirements and the frequency.

Discharge Limitations		Monitoring Requirements	
Regulated Parameter	**Maximum for Any one Day mg/L**	**Monitoring Frequency**	**Sample Type**
Zinc[4]	**1.25**	**2 X Month**	**Composite[1]**
Oil and Grease	**100**	**2 X Month**	**Grab**
pH	**6-10**	**Daily**	**Grab**
CBOD [3]	**(Monitor and report)**	**1 X Month**	**Composite[1]**
COD [3]	**(Monitor and report)**	**1 X Month**	**Composite[1]**
TSS [3]	**(Monitor and report)**	**1 X Month**	**Composite[1]**
Flow	**N/A**	**Daily [2]**	
TTO	**2.13**	**Semi-Annual**	**Grab**

[1] Composite samples will be flow- proportioned. The date of collection shall be the date on which sample collection was completed.

[2] All flow shall be monitored and recorded daily (gallons/day), not estimated, by a non-resettable flow-measurement device.

[3] Excess strength surcharges apply for amounts in excess of the Sewer Use Ordinance.

[4] All metals shall be analyzed as Total Metals. This analytical procedure will be reviewed if or when the State or Federal Government modifies the procedure.