NATIONAL ENVIRONMENTAL TESTING, INC.

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

JUN 22 1998

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTORING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

06/17/1998

NET Job Number: 98.03928

P.O #208205

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
210136	OUTFALL 001	06/12/1998	06/12/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Lou Barnett

Project Representative

NATIONAL ENVIRONMENTAL TESTING, INC.

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

JUN 22 1998

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTORING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

06/17/1998

Job No.: 98.03928

Date Received: 06/12/1998
Job Description: TWICE WEEKLY WASTEWATER

Sample Number / Sample I.D. Parameters	Result	Flag	Sample Date/ Units	Analyst & Date Analyzed	Method	Reporting Limit
210136 OUTFALL 001			06/12/1998			
Iron, ICP	<0.10		mg/L	tjg / 06/16/1998	EPA 200.7	<0.10
Lead, ICP	<0.080		mg/L	tjg / 06/16/1998	EPA 200.7	<0.080
Silver, ICP	<0.020		mg/L	tjg / 06/16/1998	EPA 200.7	<0.020
Zinc, ICP	1.0		mg/L	tjg / 06/17/1998	EPA 200.7	<0.020

NET® NATIONAL ENVIRONMENTAL TESTING, INC.

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

JUN 22 1998

FIELD REPORT

JOB #: 98.03928
CLIENT: MILBANK MFG.
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 6/12/98
SAMPLER(S): MTM

An ISCO model 2910 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, ice, and strainer.

All reusable equipment is decontaminated with alconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 24 hours.

Monitoring start 08:00 on 6/11/98
Monitoring end 08:00 on 6/12/98

The composite sample was clear.

Notes: Samples were preserved, in the field, in the appropriate containers with any required preservative.

NATIONAL ENVIRONMENTAL TESTING, INC.

CHAIN OF CUSTODY RECORD

COMPANY: MILBANK MFG.
ADDRESS: 1400 E. HAVENS ST. KOKOMO, IN
PHONE: (765) 452-5694 FAX:
PROJECT NAME/LOCATION: TWICE WEEKLY WASTEWATER
PROJECT NUMBER:
PROJECT MANAGER:

REPORT TO: RICHARD TYLER
INVOICE TO:
P.O. NO.
NET QUOTE NO.

SAMPLED BY: Michael Meyer (PRINT NAME) — Michael Meyer (SIGNATURE)
(PRINT NAME) — (SIGNATURE)

To assist us in selecting the proper method
Is this work being conducted for regulatory compliance monitoring? Yes ____ No ____
Is this work being conducted for regulatory enforcement action? Yes ____ No ____
Which regulations apply: RCRA ____ NPDES Wastewater ____ UST ____ Drinking Water ____ Other ____ None ____

DATE 1998	TIME	SAMPLE ID/DESCRIPTION	MATRIX	GRAB	COMP	# and Type of Containers: HCl	NaOH	HNO_3	H_2SO_4	OTHER	ANALYSES: METALS: Fe, Pb,	Ag, Zn	FIELD REPORT							COMMENTS
6/11-6/12		OUTFALL 001	W		X			1			X	X	X							

CONDITION OF SAMPLE: BOTTLES INTACT? YES / NO — FIELD FILTERED? ~~YES / NO~~
COC SEALS PRESENT AND INTACT? ~~YES~~ / NO — VOLATILES FREE OF HEADSPACE? ~~YES~~ / NO
TEMPERATURE UPON RECEIPT: 1.3°C — Bottles supplied by NET? YES / NO

SAMPLE REMAINDER DISPOSAL: RETURN SAMPLE REMAINDER TO CLIENT VIA ____
I REQUEST NET TO DISPOSE OF ALL SAMPLE REMAINDERS ____ DATE ____

RELINQUISHED BY:	DATE	TIME	RECEIVED BY:	RELINQUISHED BY:	DATE	TIME	RECEIVED FOR ~~NET BY:~~
Michael Meyer	6/12/98	14:20			6/12/98	1420	RB

METHOD OF SHIPMENT:

REMARKS:

PT 1 - ORIGINAL - WHITE PT 2 - NET PROJECT MANAGER - YELLOW PT 3 - CUSTOMER COPY - PINK

MIL0003189