NATIONAL ENVIRONMENTAL TESTING, INC.

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

MAR 23 1998

Mr. Richard Tyler
MILBANK MANUFACTORING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

03/17/1998

NET Job Number: 98.01637

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
201130	OUTFALL 001	03/06/1998	03/06/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Theresa L Sheingold
Project Representative

NATIONAL ENVIRONMENTAL TESTING, INC.

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTORING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

03/17/1998

MAR 23 1998

Sample No.: 201130
Job No.: 98.01637
P.O. NO.:

Sample Description: OUTFALL 001
Job Description: TWICE WEEKLY WASTEWATER

Date Taken: 03/06/1998 Date Received: 03/06/1998

Parameter	Result	Flag	Units	Analyst/ Date of Analysis	Method Number	Reporting Limit
Iron, ICP	0.21		mg/L	tjg / 03/16/1998	E-200.7	<0.10
Lead, ICP	<0.080		mg/L	tjg / 03/16/1998	E-200.7	<0.080
Silver, ICP	<0.010		mg/L	tjg / 03/16/1998	E-200.7	<0.010
Zinc, ICP	1.6		mg/L	tjg / 03/16/1998	E-200.7	<0.020

NET® NATIONAL ENVIRONMENTAL TESTING, INC.

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

FIELD REPORT

MAR 23 1998

JOB #: 98.01637
CLIENT: MILBANK MFG.
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 3/05/98
SAMPLER(S): MTM

An ISCO model 2910 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, ice, and strainer.

All reusable equipment is decontaminated with alconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 24 hours.

Monitoring start 15:00 on 3/05/98
Monitoring end 15:00 on 3/06/98

The composite sample was cloudy.

Notes: Samples were preserved, in the field, in the appropriate containers with any required preservative.

NATIONAL ENVIRONMENTAL TESTING, INC.

CHAIN OF CUSTODY RECORD

COMPANY: Milbank
ADDRESS: Kokomo
PHONE: _____ FAX: _____
PROJECT NAME/LOCATION: 2x weekly Wastewater
PROJECT NUMBER: _____
PROJECT MANAGER: _____

REPORT TO: Ric Tyler
INVOICE TO: _____
P.O. NO. _____
NET QUOTE NO. _____

SAMPLED BY: Andrew Sargent (PRINT NAME) — SIGNATURE
(PRINT NAME) — SIGNATURE

ANALYSES

To assist us in selecting the proper method
Is this work being conducted for regulatory compliance monitoring? Yes ____ No ____
Is this work being conducted for regulatory enforcement action? Yes ____ No ____
Which regulations apply: RCRA ____ NPDES Wastewater ____ UST ____ Drinking Water ____ Other ____ None ____

DATE	TIME	SAMPLE ID/DESCRIPTION	MATRIX	GRAB	COMP	# and Type of Containers: HCl	NaOH	HNO_3	H_2SO_4	OTHER	Fe, Pb, Ag, Zn (All ICP)									COMMENTS
3/4-3/10		Outfall 001	W		X			1			X									

MAR 23 1998

CONDITION OF SAMPLE: BOTTLES INTACT? YES / NO — FIELD FILTERED? YES / NO
COC SEALS PRESENT AND INTACT? ~~YES / NO~~ — VOLATILES FREE OF HEADSPACE? ~~YES / NO~~
TEMPERATURE UPON RECEIPT: Ambient — Bottles supplied by NET? YES / NO — Metals

SAMPLE REMAINDER DISPOSAL: RETURN SAMPLE REMAINDER TO CLIENT VIA _____
I REQUEST NET TO DISPOSE OF ALL SAMPLE REMAINDERS _____ DATE _____

RELINQUISHED BY:	DATE	TIME	RECEIVED BY:	RELINQUISHED BY:	DATE	TIME	RECEIVED FOR NET BY:
	3/10/98	1041			3/10/98	1041	C Walsh

METHOD OF SHIPMENT:

REMARKS:

PT 1 - ORIGINAL - WHITE PT 2 - NET PROJECT MANAGER - YELLOW PT 3 - CUSTOMER COPY - PINK

MIL0003322