INDUSTRIAL WASTEWATER PRETREATMENT MONITORING REPORT (IWPMR)

Permittee: Milbank Manufacturing Company, Incorporated **Discharge Period (Month):** November **Discharge Point:** 1

Regulated Parameter:		pH	As	Cd	Cr	Cu	Pb	Hg	Ni	Se	Ag	Zn	Mo	TTO	Phenol	Cn	O&G	TPH	PO_4	CBOD	COD	TSS	NH_3-N
Sample Type:		Grab	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Grab	Grab	Grab	Grab	Grab	Comp	Comp	Comp	Comp	Comp
Local Discharge Limit:		6 — 10	0.03	0.02	2.0	0.6	0.1	0.003	0.8	0.10	0.24	1.25	M & R	2.13	0.5	0.5	100	M & R	M & R	M & R	M & R	M & R	M & R
Analytical Method ID:																							
Method Detection Limit (LLOD):																							
Date	Flow (GPD)	s.u.'s	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
1	2398	7.48																					
2	2472	8.33																					
3	2014	7.85																					
4	1632	7.77																					
5	3435	8.04																					
6																							
7	1660	8.05																					
8	2421	7.5																					
9	1931	8.01																					
10	2647	7.54																					
11	2090	7.85																					
12	2064	8.25																					
13																							
14	1815	8.28																					
15	2173	8.06																					
16	3196	7.86																					
17	2300	8.1																					
18	2927	7.26																					
19	1882	8.15																					
20																							
21	18130	7.57																					
22	2504	8.09																					
23	2140	7.71																					
24	Holiday																						
25	Holiday																						
26																							
27																							
28	2666	7.81																					
29	2369	7.84																					
30	2336	7.71																					
31																							
Mo. Average:	3008.782609																						
High Value:	18130	8.33																					
Low Value:	1632	7.26																					
Total Flow:	69202																						

WATER bill 84,000 GAL.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personell properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware there are significant penalities for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Larry Sterling
Signature of Responsible Party

Technical Service Manager
Title/Position

12/19/05
Date

MIL0004182

INDUSTRIAL WASTEWATER PRETREATMENT MONITORING REPORT (IWPMR)

Permittee: Milbank Manufacturing Company, Incorporated **Discharge Period (Month):** November **Discharge Point:** 2

Regulated Parameter:		pH	As	Cd	Cr	Cu	Pb	Hg	Ni	Se	Ag	Zn	Mo	TTO	Phenol	Cn	O&G	TPH	PO_4	CBOD	COD	TSS	NH_3-N
Sample Type:		Grab	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Comp	Grab	Grab	Grab	Grab	Grab	Comp	Comp	Comp	Comp	Comp
Local Discharge Limit:		6 — 10	0.03	0.02	2.0	0.6	0.1	0.003	0.8	0.10	0.24	1.25	M & R	2.13	0.5	0.5	100	M & R	M & R	M & R	M & R	M & R	M & R
Analytical Method ID:																							
Method Detection Limit (LLOD):																							
Date	Flow (GPD)	s.u.'s	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
1	1880	9.27																					
2	2210	9.26																					
3	2730	9.33		<0.0020	<0.010	0.0428	0.0454		0.0720		<0.001	0.181	0.0237			<0.005	<5.	<5.	0.056	7.53	63.8	49	3.39
4																							
5																							
6																							
7																							
8																							
9	620	9.07																					
10	2170	9.27																					
11																							
12																							
13																							
14																							
15																							
16																							
17																							
18																							
19																							
20																							
21	1310	9.36																					
22	1490	9.32																					
23																							
24																							
25																							
26																							
27																							
28																							
29	880	9.27																					
30	2260	9.32																					
31																							
Mo. Average:	1727.777778			<0.0020	<0.010	0.0428	0.0454		0.0720		<0.001	0.181				<0.005	<5.	<5.	0.056	7.53	63.8	49	3.39
High Value:	2730	9.36		<0.0020	<0.010	0.0428	0.0454		0.0720		<0.001	0.181				<0.005	<5.	<5.	0.056	7.53	63.8	49	3.39
Low Value:	620	9.07		<0.0020	<0.010	0.0428	0.0454		0.0720		<0.001	0.181				<0.005	<5.	<5.	0.056	7.53	63.8	49	3.39
Total Flow:	15550																						

WATER bill 84,000 GAL

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personell properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware there are significant penalities for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Larry Stahney
Signature of Responsible Party

Technical Service Manager
Title/Position

12/19/05
Date

MIL0004183

0001000000297000000000070548012

Indiana American Water
PO BOX 578
ALTON, IL 62002-0578

For Service To: 1005 RANK PKY

ACCOUNT NUMBER	10-0000029-7
AMOUNT DUE	$705.48
DUE DATE	Dec 27, 2005

Please return this portion with check
Payable to the address below

00011753 01 AB 0.301 B 00048 64 FC004

MILBANK MFG CO INC
PO BOX 754
KOKOMO IN 46903-0754

Indiana American Water
PO Box 5127
Carol Stream, IL 60197-5127

Customer Account Information

For Service To: MILBANK MFG CO INC
1005 RANK PKY
Account Number: 10-0000029-7
Premise Number: 10-0000018

Billing Period & Meter Information

Billing Date: Dec 08, 2005
Billing Period: Nov 04 to Dec 06 (32 days)
Next reading on/about: Jan 06, 2006
Rate Type: Industrial

Meter readings in current billing period:
Meter Number 031697349A is a 2-inch meter.
Present-actual 8246
Last-actual 8134
Meter Number 037146496A is a 5/8-inch meter.
Present-actual 0
Last-actual 0
100 Cubic Feet used 112
1 cu. ft. equals 7.50 gallons
Gallons used 84000

Billing Summary

Prior Balance		
Balance from last bill		$355.59
Payments as of Dec 08, 2005. Thanks!		.00
Total prior balance, Dec 08, 2005		355.59
Current Water Charges		
Customer Service Charge		92.01
Water Charge	*($2.451100 x 20.00)*	49.02
	($1.775800 x 92.00)	163.37
Total Use Billed	*112.00*	304.40
Other Current Charges		
Pub F/S Surchg Mtr Kokomo		23.57
Distrib System Improv Charge		2.12
Total other charges, Dec 08, 2005		25.69
Taxes		
Indiana Gross Retail Tax		19.80
Total taxes, Dec 08, 2005		19.80
Total Current Charges		$349.89
TOTAL AMOUNT DUE		$705.48

01-6360-02500

TAXED
12-12-05
RJ

MIL0004184

TestAmerica
ANALYTICAL TESTING CORPORATION
6964 Hillsdale Court • Indianapolis, IN 46250 • 317-842-4261 • Fax: 317-842-4286

Mr. David Krantz
MILBANK MANUFACTURING INC
1400 E. Havens St.
Kokomo, IN 46901-3188

Job Number: 05.22423
Report Date: 11/14/2005

Enclosed is the Analytical Report for the following samples submitted to TestAmerica for analysis:

Project: MONTHLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
158779	MONTHLY COMP	11/04/2005	11/04/2005
158780	MONTHLY GRAB	11/03/2005	11/04/2005

TestAmerica certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this report is permitted only in its entirety.

Enclosure

Project Management Approval

Dayton - 3601 South Dixie Drive, Dayton, OH 45439 937-294-6856/FAX:937-294-7816
Dundee (Chicago) - 1090 Rock Road Lane, Unit 11, Dundee, IL 60118 847-783-4960/FAX:847-783-4969
Indianapolis - 6964 Hillsdale Court, Indianapolis, IN 46250 317-842-4261/FAX:317-842-4286
Pontiac - 341 W. Walton Blvd, Pontiac, MI 48340 248-332-1940/FAX:248-332-5450
www.testamericainc.com

TestAmerica
ANALYTICAL TESTING CORPORATION
6964 Hillsdale Court • Indianapolis, IN 46250 • 317-842-4261 • Fax: 317-842-4286

Analytical Report

Mr. David Krantz
MILBANK MANUFACTURING INC
1400 E. Havens St.
Kokomo, IN 46901-3188

Job Number: 05.22423
Report Date: 11/14/2005

SAMPLE NO. 158779 **SAMPLE DESCRIPTION** MONTHLY COMP **DATE/TIME TAKEN** 11/04/2005 13:00

	Result	Units	Reporting Limit	Flag	Run Date	Run Time	Prep Batch	Run Batch	Anal. Init.	Lab ID	Method Reference
CBOD - Five Day	7.53	mg/L	<4		11/09/2005	14:21	2169	2575	slb	IN	SM18 5210B
CBOD - Five Day (PREP)	Complete		Complete		11/04/2005	16:00	2169		dsp	IN	SM18 5210B
COD	63.8	mg/L	<20.0		11/07/2005	08:43		1483	tpd	IN	HACH 8000
Nitrogen, Ammonia Dist.	3.39	mg/L	<0.10		11/14/2005	10:16	410	1514	slb	IN	EPA 350.1
Phosphorus, Total	0.056	mg/L	<0.05		11/07/2005	09:08	576	1184	tpd	IN	EPA 365.2
Phosphorus, Total - Prep	Complete		Complete		11/07/2005	09:08	576		tpd	IN	EPA 365.2
Solids, Suspended	49	mg/L	<5.		11/08/2005	11:07		2410	mhl	IN	EPA 160.2
Distillation, Ammonia	Complete		Complete		11/08/2005	13:10	410		mhl	IN	EPA 350.1
ICPMS TOTAL METALS	Complete		Complete		11/09/2005	13:58		5599	ekh	DT	EPA 200.8
Cadmium, ICPMS	<0.0020	mg/L	<0.0020	O	11/09/2005	13:58	3660	7388	ekh	DT	EPA 200.8
Chromium, ICPMS	<0.010	mg/L	<0.010	O	11/09/2005	13:58	3660	8222	ekh	DT	EPA 200.8
Copper, ICPMS	0.0428	mg/L	<0.0050		11/09/2005	13:58	3660	7517	ekh	DT	EPA 200.8
Lead, ICPMS	0.0454	mg/L	<0.0010		11/09/2005	13:58	3660	7456	ekh	DT	EPA 200.8
Molybdenum, ICPMS	0.0237	mg/L	<0.0010		11/09/2005	13:58	3660	7752	ekh	DT	EPA 200.8
Nickel, ICPMS	0.0720	mg/L	<0.0050		11/09/2005	13:58	3660	7481	ekh	DT	EPA 200.8
Silver, ICPMS	<0.001	mg/L	<0.001	O	11/09/2005	13:58	3660	7766	ekh	DT	EPA 200.8
Zinc, ICPMS	0.181	mg/L	<0.050		11/09/2005	13:58	3660	7325	ekh	DT	EPA 200.8
Digestion, ICPMS	Complete		Complete		11/08/2005		3660		mja	DT	EPA 200.2

SAMPLE NO. 158780 **SAMPLE DESCRIPTION** MONTHLY GRAB **DATE/TIME TAKEN** 11/03/2005 07:30

	Result	Units	Reporting Limit	Flag	Run Date	Run Time	Prep Batch	Run Batch	Anal. Init.	Lab ID	Method Reference
Cyanide Prep	Complete		Complete		11/08/2005		2801		rlm	DT	EPA 335.2 (CLP-M)
Cyanide, Total	<0.005	mg/L	<0.005		11/09/2005		2801	3275	kkh	DT	EPA 335.2 Mod
Oil & Grease (HEM)	<5.	mg/L	<5.		11/07/2005	08:30		2059	mhl	IN	EPA 1664A
Non-Polar Material (SGT-HEM)	<5.	mg/L	<5.		11/07/2005	08:30		765	mhl	IN	EPA 1664A

O - Elevated value due to sample matrix.

Lab ID: CH = Chicago (Dundee), DT = Dayton, IN = Indianapolis, PT = Pontiac, SUB = Subcontracted, CLT = Client Data

TestAmerica INCORPORATED

Indianapolis Division
6964 Hillsdale Court
Indianapolis, IN 46250

Phone: 317-842-4261
Fax: 317-842-4286

To assist us in using the proper analytical methods, is this work being conducted for regulatory purposes?
Compliance Monitoring _____

Client Name: Milbank Client #: 64972
Address: 1400 E. Havens St.
City/State/Zip Code: Kokomo, IN 46901-3188
Project Manager: David Krantz
Telephone Number: 765-452-5694 Fax: 765-452-8361
Sampler Name: (Print Name) _____
Sampler Signature: _____

Project Name: Monthly wastewater
Project #: _____
Site/Location ID: _____ State: IN
Report To: David Krantz
Invoice To: _____
Quote # _____ PO# _____

TAT
___ Standard
___ Rush (surcharges may apply)
Date Needed: _____
Fax Results: Y N

QC Deliverables
___ None
___ Level 2 (Batch QC)
___ Level 3
___ Level 4
Other: _____

SAMPLE ID	Date Sampled	Time Sampled	G=Grab, C=Composite	Field Filtered	Matrix (SL-Sludge DW-Drinking Water GW-Groundwater S-Soil/Solid WW-Wastewater Specify Other)	HNO_3	HCl	NaOH	H_2SO_4	Methanol	None	Other (Specify)	Cd, Cr, Cu, Pb, Ni, As, Zn, Mo	T. Phosphorus, Ammonia, COD	CBOD, TSS	Cyanide	O+G, O+G Hydrocarbon						REMARKS
	2005																						
Composite	11/4	1300											X	X	X								
Grab	11/3	0730						1	1							X	X						

Special Instructions:

LABORATORY COMMENTS:
Init Lab Temp:
Rec Lab Temp: 22.7
Custody Seals: Y (N) N/A
Bottles Supplied by Test America: (Y) N
Method of Shipment: TA

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
			Stacy Zahn	11-4-05	1250
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

MIL0004187

MILBANK MFG. WASTEWATER TREATMENT PLANT
PH CALIBRATION/READING LOG SHEET

TIME	DATE	BUFFER CHANGED? PH 4.00	BUFFER CHANGED? PH 10.00	PROBE LOCATION	PROBE CLEANED	PH READING	PH CALIBRATION
8:00	11-1	Y	Y	NEUT 1	Y	4 + 10	3.98 - 10.01
8:00	11-1	Y	Y	NEUT 2	Y	4 + 10	4.00 - 10.00
3:30	11-1	Y	Y	FINAL	Y	9.27	4.00 + 10.00
7:00	11-2	Y	Y	NEUT 1	Y	4 + 10	4.03 10.00
7:00	11-2	Y	Y	NEUT 2	Y	4 + 10	4.02 10.00
2:20	11-2	Y	Y	FINAL	Y	9.26	4.00 + 10.00
6:30	11-3	Y	Y	NEUT 1	Y	4 + 10	4.03 - 10.01
6:30	11-3	Y	Y	NEUT 2	Y	4 + 10	4.02 10.03
1:30	11-3	Y	Y	FINAL	Y	9.33	4.00 + 10.00
7:00	11-9	Y	Y	NEUT 1	Y	4 + 10	4.03 10.02
7:00	11-9	Y	Y	NEUT 2	Y	4 + 10	4.01 10.02
1:40	11-9	Y	Y	FINAL	Y	9.07	4.00 + 10.00
7:00	11-10	Y	Y	NEUT 1	Y	4 + 10	4.00 - 10.02
7:00	11-10	Y	Y	NEUT 2	Y	4 + 10	4.00 - 10.00
3:15	11-10	Y	Y	FINAL	Y	9.27	4.00 + 10.00
7:00	11-21	Y	Y	NEUT 1	Y	4 + 10	4.03 - 10.01
7:00	11-21	Y	Y	NEUT 2	Y	4 + 10	4.01 - 10.01
2:55	11-21	Y	Y	FINAL	Y	9.36	4.00 + 10.00
7:00	11-22	Y	Y	NEUT 1	Y	4 + 10	4.00 10.00
7:00	11-22	Y	Y	NEUT 2	Y	4 + 10	3.98 10.00
11:25	11-22	Y	Y	FINAL	Y	9.32	4.00 + 10.00
7:00	11-29	Y	Y	NEUT 1	Y	4 + 10	4.02 - 10.00
7:00	11-29	Y	Y	NEUT 2	Y	4 + 10	4.00 - 9.98
3:00	11-29	Y	Y	FINAL	Y	9.27	4.00 + 10.00
7:00	11-30	Y	Y	NEUT 1	Y	4 + 10	4.00 - 9.98
7:00	11-30	Y	Y	NEUT 2	Y	4 + 10	3.99 - 9.97
1:00	11-30	Y	Y	FINAL	Y	9.32	4.00 + 10.00
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		
		Y	Y	NEUT 1	Y	4 + 10	
		Y	Y	NEUT 2	Y	4 + 10	
		Y	Y	FINAL	Y		

MILBANK MFG. DISCHARGE LOG
SAMPLE POINT # 2

DATE	START TIME	METER READING	STOP TIME	METER READING	COMMENTS/ MAINTENANCE
11-1	10:15	1223670	3:30	1225550	System
11-2	7:30	1225550	2:45	1227760	System
11-3	7:00	1227760	3:30	1230490	System (Testing)
11-4	7:00	1230490	1:30	1230490	Filter Press
11-7	7:30	1230490	10:30	1230490	Filter Press
11-8	7:45	1230490	12:30	1230490	Filter Press
11-9	11:30	1230490	2:00	1231110	System
11-10	7:30	1231110	3:00	1233280	System
11-11	7:00	1233280	11:00	1233280	Filter Press
11-14	7:00	1233280	8:00	1233280	Filter Press Shut Down Pump Rebuil
11-15	7:00	1233280	12:45	1233280	Filter Press
11-21	11:30	1233280	3:00	1234590	System
11-22	7:15	1234590	11:30	1236080	System
11-23	7:30	1236080	11:30	1236080	Filter Press
11-28	7:15	1236080	2:30	1236080	Filter Press
11-29	11:15	1236080	3:00	1236960	System
11-30	7:20	1236960	1:30	1239220	System

Number 1 Station Flow meter and PH reading

Month

November-05

	Previous Meter Reading	Current Meter Reading	Gallons Per Day	PH Reading
1	1171597	1173995	2398	7.48
2	1173995	1176467	2472	8.33
3	1176467	1178481	2014	7.85
4	1178481	1180113	1632	7.77
5	1180113	1183548	3435	8.04
6			0	
7	1183548	1185208	1660	8.05
8	1185208	1187629	2421	7.50
9	1187629	1189560	1931	8.01
10	1189560	1192207	2647	7.54
11	1192207	1194297	2090	7.85
12	1194297	1196361	2064	8.25
13			0	
14	1196361	1198176	1815	8.28
15	1198176	1200349	2173	8.06
16	1200349	1203545	3196	7.86
17	1203545	1205845	2300	8.10
18	1205845	1208772	2927	7.26
19	1208772	1210654	1882	8.15
20			0	
21	1210654	1228784	18130	7.57
22	1228784	1231288	2504	8.09
23	1231288	1233428	2140	7.71
24	Holiday	Holiday	Holiday	Holiday
25	Holiday	Holiday	Holiday	Holiday
26			0	
27			0	
28	1233428	1236094	2666	7.81
29	1236094	1238463	2369	7.84
30	1238463	1240799	2336	7.71
31			0	

69202 Total Gallons

Number 1 Station Flow meter and PH reading

Month

November-05

	Previous Meter Reading	Current Meter Reading	Gallons Per Day	PH Reading
1	1171597	1173995	2398 0	7.48
2	1173995	1176467	2572 0	8.33
3	1176467	1178481	2014 0	7.85
4	1178481	1180113	1732 0	7.77
5	1180113	1183548	3435 0	8.04
6			0	
7	1183548	1185208	1660 0	8.05
8	1185208	1187629	2421 0	7.50
9	1187629	1189560	1931 0	8.01
10	1189560	1192207	2647 0	7.54
11	1192207	1194297	2090 0	7.85
12	1194297	1196361	2064 0	8.25
13			0	
14	1196361	1198176	1815 0	8.28
15	1198176	1200349	2173 0	8.06
16	1200349	1203545	2196 0	7.86
17	1203545	1205845	2300 0	8.10
18	1205845	1208772	2927 0	7.26
19	1208772	1210654	1882 0	8.15
20			0	
*21	1210654	1228784	18130 0	7.57
22	1228784	1231288	2504 0	8.09
23	1231288	1233428	2140 0	7.71
24	1233428		0	
25		HOLIDAY	0	
26			0	
27			0	
28	1233428	1236094	2666 0	7.81
29	1236094	1238463	2369 0	7.84
30	1238463	1240799	2336 0	7.71
31	1240799		0	

* NO WATER USED SUNDAY

0 Total Gallons

TABLE 1									
Regulated Parameters	**Notes**	**Most Protective Discharge Limitations Enforceable at Sampling Point #02**		**Alternative Categorical Discharge Limitations Enforceable at Sampling Point #02**		**Ordinance #6064 Discharge Limitations Enforceable at Sampling Point #01**		**Monitoring Requirements**	
		Daily Maximum (mg / L)	**Monthly Average (mg / L)**	**Daily Maximum (mg / L)**	**Monthly Average (mg / L)**	**Daily Maximum (mg / L)**	**Monthly Average (mg / L)**	**Frequency**	**Sample Type**
Arsenic	10	0.03	-	-	-	0.03	-	N/A	N/A
Cadmium	2, 5, 6, 7, 9	0.02	0.26	0.69	0.26	0.02	-	1 X Month	Composite
Chromium	2, 5, 6, 7, 9	2.0	1.71	2.77	1.71	2.0	-	1 X Month	Composite
Copper	2, 5, 6, 7, 9	0.6	2.07	3.38	2.07	0.6	-	1 X Month	Composite
Cyanide	5, 6, 7, 9	0.5	0.65	1.20	0.65	0.5	-	1 X Month	Grab
Lead	2, 5, 6, 7, 9	0.1	0.43	0.69	0.43	0.1	-	1 X Month	Composite
Mercury	10	0.003	-	-	-	0.003	-	N/A	N/A
Nickel	2, 5, 6, 7, 9	0.8	2.38	3.98	2.38	0.8	-	1 X Month	Composite
Selenium	10	0.10	-	-	-	0.10	-	N/A	N/A
Silver	2, 5, 6, 7, 9	0.24	0.24	0.43	0.24	0.24	-	1 X Month	Composite
Zinc	2, 5, 6, 7, 9	1.25	1.48	2.61	1.48	1.25	-	1 X Month	Composite
Molybdenum	2, 5, 7, 9	Monitor & Report		-	-	Monitor & Report		1 X Month	Composite
Phosphorus	2, 7, 9, 14	Monitor & Report		-	-	Monitor & Report		1 X Month	Composite
TTO	6, 7, 9	2.13	-	2.13	-	2.13	-	Semi-Annual	Grab
Phenols	7, 9, 13	0.50	-	-	-	0.50	-	Semi-Annual	Grab
pH	7, 8, 9	6-10 SUs	-	-	-	6-10 SUs	-	Daily	Grab
O&G, Polar	7, 9, 11, 12	100	-	-	-	100	-	1 X Month	Grab
O&G, Nonpolar	7, 9, 11, 12	Monitor & Report		-	-	Monitor & Report		1 X Month	Grab
Flow	1, 3, 7, 8, 9	Monitor & Report		-	-	Monitor & Report		Daily	
$CBOD_5$	2, 4, 7, 9	Monitor & Report		-	-	Monitor & Report		1 X Month	Composite
COD	2, 4, 7, 9	Monitor & Report		-	-	Monitor & Report		1 X Month	Composite
TSS	2, 4, 7, 9	Monitor & Report		-	-	Monitor & Report		1 X Month	Composite
Ammonia-N	2, 4, 7, 9	Monitor & Report		-	-	Monitor & Report		1 X Month	Composite

- The above listed discharge limitations and monitoring requirements are minimum requirements necessary to achieve compliance. Nothing in this permit shall prevent MMCI from achieving discharge concentrations that are more protective/restrictive than the requirements of this table.

DATE: November 3rd 2005

MILBANK MANUFACTURING COMPANY

BEGINNING READING @ 7:00 AM 1227760

TIME	METER READING	INITIAL
7:30	1227920	SLH
8:00	1228110	SLH
8:30	1228280	SLH
9:00	1228450	SLH
9:30	1228620	SLH
10:00	1228810	SLH
10:30	1228950	SLH
11:00	1229130	SLH
11:30	1229300	SLH
12:00	1229470	SLH
12:30	1229640	SLH
1:00	1229810	SLH
1:30	1229970	SLH
2:00	1230140	SLH
2:30	1230320	SLH
3:00	1230460	SLH
3:30	1230480	SLH

Chemical Specialties

Marcus Bryant
913-661-0767

First Stage

Date	Initial	Concentration	Pressure	Temperature	pH	Replacements of drums	Clean Screens	Clean Nozzles	Comments
Ranges		1.60 –2.00	15 – 25	115°–130°	9.5 – 11.0	Cleaner 419-C	Daily	Weekly	
11-1	DK	2.20	15	118	10.14				
11-2	DK	2.20	15	119	10.14				
11-3	DK	2.20	15	117	10.13				
11-4	DK	2.20	15	119	10.15				
11-7	DK	2.20	15	120	10.17				
11-8	DK	2.20	15	118	10.26				
11-9	DK	2.20	15	116	10.28				
11-10	DK	2.20	15	115	10.29				
11-11	DK	2.20	15	117	10.22				
11-14	DK	2.20	15	115	10.21				
11-15	DK	2.20	15	119	10.18				
11-21	DK	2.20	15	116	10.15				
11-22	DK	2.00	15	119	9.90				
11-23	DK	2.00	15	117	9.87				
11-28	DK	2.00	15	115	9.85				
11-29	DK	2.00	15	116	9.86				
11-30	DK	2.00	15	118	9.89				

Chemical Specialties

Marcus Bryant
913-661-0767

Third Stage

Date	Initial	Concentration	Pressure	Temperature	pH	Replacements of drums	Clean Screens	Clean Nozzles	Comments
Ranges		1.65 – 2.31	15 – 25	110°–130°	4.0 – 5.5	Paint Lok 595	Daily	Weekly	
11-1	DK	2.64	15	116	5.34				
11-2	DK	2.64	15	118	5.15				
11-3	DK	2.64	15	115	5.16				
11-4	DK	2.64	15	117	5.14				
11-7	DK	2.64	15	118	5.37				
11-8	DK	2.64	15	116	5.40				
11-9	DK	2.64	15	116	5.45				
11-10	DK	2.64	15	112	5.47				
11-11	DK	2.64	15	119	5.74				
11-14	DK	2.64	15	120	5.73				
11-15	DK	2.64	15	117	5.71				
11-21	DK	2.64	15	119	5.67				
11-22	DK	2.64	15	117	5.09				
11-23	DK	2.64	15	115	5.10				
11-28	DK	2.64	15	116	5.12				
11-29	DK	2.64	15	117	5.14				
11-30	DK	2.64	15	119	5.10				

Chemical Specialties

Marcus Bryant
913-661-0767

Fifth Stage

Date	Initial	Pressure	PH Stage 5	Addition of Rinse 50 1 pint/4 hours of run time		Conductivity of Stage 5		Conductivity of Stage 2		Conductivity of Stage 4		Clean Screens	Clean Nozzles	Comments
Ranges		15 - 25	4.0 – 5.5	AM	PM	< 2000uS		< 1500uS		< 1500uS		Daily	Weekly	
						AM	PM	AM	PM	AM	PM			
11-1	DK	15	4.7	10:30	3:30	1885	1845	1138	1589	1205	1279			
11-2	DK	15	5.1	9:00	3:30	1920	1871	984	1157	653	679			

MILBANK MANUFACTURING
WASTEWATER TREATMENT PLANT
CHEMICAL LOG

ATE	FERRIC CHLORIDE (42be)		CALCIUM CHLORIDE FLAKES (77%)		CAUSTIC SODA (50%)		SULFURIC ACID (66be)		WT-11		COMMENTS
	GALS USED	GALS REC.	GALS USED	GALS REC.	GALS USED	GALS REC.	GALS USED	GALS REC.	GALS USED	GALS REC.	
11-1	46AL		150#								Filled At 8:15
11-2									46AL		Filled At 11:15
11-2	46AL		150#								Filled At 11:35
11-9	46AL		150#								Filled At 7:15
11-10					206AL						Filled At 7:30
11-10									46AL		Filled At 9:50
11-21	46AL		150#								Filled At 7:50
11-29	46AL		150#								Filled At 7:15
11-29									46AL		Filled At 7:30
11-29							46AL				Filled At 10:00
11-29					206AL						Filled At 12:30
11-30	46AL		150#								Filled At 1:30