MPU Daily Fugitive Dust Control Log

Day	Limestone unloading < 7%	Coke Pile storage <20%	Fuel loading to crusher <20%	Emissions Evaluated by:	Comments
1	✓	✓	✓	BM	Snowy
2					
3					
4	✓	✓	✓	GS	38° Breezy
5	✓	✓	✓	[illegible]	calm
6	✓	✓	✓	[illegible]	-12° windy / Cold
7	✓	✓	✓	[illegible]	
8	✓	✓	✓	[illegible]	cold / calm
9	✓	✓	✓	[illegible]	Calm
10	✓	✓	✓	JA	25°F
11					
12					
13					
14	✓	✓	✓	BM	Snowy / windy
15	✓	✓	✓	[illegible]	Light Snow / calm
16	✓	✓	✓	GS	" " Calm
17					
18	✓	✓	✓	BM	Light wind
19					
20	✓	✓	✓	JA	Cold again !
21	✓	✓	✓	GS	
22					
23	✓	✓	✓	[illegible]	
24					
25					
26					
M 27	✓	✓	✓	JA	Very Cold
T 28	✓	✓	✓	~~JA~~	Very Cold / Breezy
W 29	✓	✓	✓	~~JA~~	Cold, Breezy, SUNNY
Th 30	✓	✓	✓	JO	Cold, [illegible]
Fri 31	✓	✓	✓	MS	

Form: E0013-daily log form.rev2

Month: Jan Year: 2014

Note: Please make an entry for every day on this form, "NA" or "off" should be used when applicable.
Return completed form to the Energy Supply and Production Supervisor, Jerry Ahlswede

Daily Log Form for Coke Pile Stacking

MONTH: January YEAR: 2014

DAY	Water Meter	BT-415 (gallons)	Comments
1	N/A	N/A	No train
2			
3	N/A	N/A	No Train
4	N/A	N/A	No Train
5	NA	NA	NO TRAIN
6	N/A	NA	NO TRAIN
7	NA	NA	N.T.
8	NA	NA	NT
9	NA	NA	NT
10	✓	✓	NO TRAIN UNLOADING
11	✓	✓	No train
12			
13			
14	✓	✓	No train
15	N/A	N/A	NO Train
16	NA	NA	NT
17			
18	NA	NA	No train
19	—	—	NO TRAIN ULOADING
20	—	—	NO TRAIN
21	—	—	NT
22			NO TRAIN UNLOADING
23	NA	NA	
24			
25			
26			
27	NA	NA	NO TRAIN
28	N/A	N/A	NO UNLOADING TRAIN
29	N/A	N/A	NO TRAIN UNLOADING
30	N/A	N/A	No Train
31	NA	NA	NO TRAIN

Please return completed form to the Mechanical Maintenance Foreman, Steve Zimmer

Form No. E0010 daily log form

MPU04857

MPU Daily Coal Handling Dust Collector Log (units are inches of water)				
Day	MAC Pressure Drop Range: 0.2-10 (inches)	B9 Coal Bin Pressure Drop Range: 1.0-7.0	Crusher baghouse Pressure Drop Range: 0.2-10	Data Collected by:
1	1.6	—	—	BN
2	1.8		/	WS
3	1.8			WS
4	~~2~~	6.6	7.63	GS
5	2	6.2	6.05	GS
6				
7				
8	2	6	6.70	JS
9	1.8	6.1		JS
FRI 10	1.5	6.3	5.67	JA
11				
12				
13	1.6	—		
14	1.8	—	7.06	B.N.
15	1.75	—	6.57	[illegible]
16	1.5	—	7.2	GS
17	1.7	—	6.30	JW
18	1.5	6.2	7.0	BN.
19				
20	1.6	6.6	7.08 0955	JA
21	1.8	6.2	7.6	[illegible]
22	1.0	6.3	7.1	
23				
24	1.7	6.1	6.2	JW
25				
26				
M 27	2.0	7.0	6.72	JA
T 28	2.1	7.1	7.25	JA
W 29	2.0	7.0	7.3	GS/JA
T 30	2.1	7.1	7.01	JD/BN
F 31	2.2	6.9	6.30	GS

Form: E0014.rev.2

Month: January Year: 2014

Note: 1. Please make an entry every day on this form, "NA" or "off" should be used when applicable.
2. Permit requires data to be recorded every 8-hours, record second time for extended shift operation.
3. Return completed form to the Mechanical Maintenance Supervisor, Steve Zimmer.