From: Malone, Edward
To: Gaito, Danielle
Subject: Re: Updated hatchery flow diagram?
Date: Friday, November 15, 2019 3:55:38 PM

Hi Danielle,

As far as floor drains are concerned they were plugged in the main building and all other buildings back in 2002(ish) when there were concerns about oil or chemicals leaching into septic's or ground water. (Except the hatch house.)

The flow diagram has not changed since the last permit and did not need an update as far as I know.

If you need more information let me know.

Thanks

E.J. Malone
Powder Mill Fish Hatchery
New Hampshire Fish and Game Department
288 Merrymeeting Rd
New Durham NH 03855-2219
(603)859-2041

_____
From: Gaito, Danielle <Gaito.Danielle@epa.gov>
Sent: Friday, November 15, 2019 11:34:18 AM
To: Malone, Edward
Subject: Updated hatchery flow diagram?

EXTERNAL: Do not open attachments or click on links unless you recognize and trust the sender.

Hi EJ -

Two quick questions:

1) the BMP plan says "All floor drains have been plugged" - is this all over the hatchery or specific to the office building?

2) Do you know if you have an updated flow diagram? I am looking for something similar to Attachment B in the Fact Sheet for the 2011 permit (link here: https://urldefense.com/v3/__https://www3.epa.gov/region1/npdes/permits/2011/finalnh0000710permit.pdf__;!eeWmBe9sc1cuNw!BZ7MdImiYjHorScn3pcNzhmZftiWDAe4-__RC5n-ALsy5xZ60stfjJIgYJY0gv9l61id2hspsH0$

Thanks!
Danielle