From:	Bhuiyan, Kamrul@CDPR
To:	CDPR-Priority Closing; County Ag Commissioner, San Diego@CDPR
Cc:	Arriaga, Jose@CDPR; Tim.Holbrook@sdcounty.ca.gov
Subject:	Priority Closing 81-SD-15, Chlorine vapors drifted to an Elementary School.
Date:	Friday, May 20, 2016 1:01:55 PM
Attachments:	Signed Priority Closing 81-SD-15.pdf

Hello all,

Please see the attachment, the Priority Closing for 81-SD-15 for your review. A YMCA maintenance employee discovered a sodium hypochlorite spill had originated from a faulty feeding pump and applied sodium thiosulfate over the spill and added water in an attempt to mitigate which formed chlorine vapors that drifted west to the Rio Seco Elementary School. Please contact me if you have any questions regarding this investigation.

Thank you,

Kamrul H. Bhuiyan

Environmental Scientist

CA Dept. of Pesticide Regulation

Enforcement Branch

Tel: 714 279 7032

Fax: 714 279 7692