ER BWQ-32 REV
NOTE: SEE CO
BEFORE SIGNING

DEPARTMENT OF EN NMENTAL RESOURCES
BUREAU OF WATER QUALITY MANAGEMENT
WASTE DISCHARGE INSPECTION REPORT

DATE
TIME 9:00 A.M.

ESTABLISHMENT	CASE	LOCATION (STREET/STATE ROUTE)	COUNTY	MUNICIPALITY	PROGRAM
NATIONAL VULCANIZED FIBER		WEST MULBERRY ST.	CHESTER	KENNETT SQUARE	IW

OPERATOR NAME	VALID ~~CERTIFICATE POSTED~~ YES ☐ NO ☐	TELEPHONE NO.	POP SERVED	ACRES UNDER PERMIT	ACRES ALREADY MINED
—		—	/	/	/

RESPONSIBLE OFFICIAL	ADDRESS	TELEPHONE NO.	INDUSTRIAL PRODUCTS	
STEPHEN KOVACH, V.P. DIVISION MANAGER	BOX 160 KENNETT SQUARE, PA. 19348	4442800	1. PHENOLYTIC PRODUCTS	2. /

PERSON INTERVIEWED	ADDRESS	TELEPHONE NO.
ED McDERMOTT, MAINTENANCE SUPT.		

~~TREATMENT PROCESS~~	~~NUMBER OF UNITS~~ ~~TOT~~	~~IN OP~~	REMARKS	VIOLATIONS
(7) WILL BE DISCHARGING NON-CONTACT COOLING WATER FROM ONE AIR COMPRESSOR AND COOLING ROLLERS FROM TREATER IN NEW BLDG.			(1) HAVE INSTALLED COOLING TOWER TO RECYCLE COMPRESSOR COOLING WATER, NEED TO CONNECT PUMPS AND PIPING SHOULD HAVE CLOSED LOOP RECYCLING SYSTEM OPERATING BY LATE MAY, EARLY JUNE 1983.	- NOT SUBMITTING DMRs ON A REGULAR MONTHLY BASIS.
(8) SAMPLED RAW WATER AT #109 SHOOT PRESSES			(2) STILL DISCHARGING NON-CONTACT COOLING WATER OUT OLD #001 OUTFALL FROM AIR COMPRESSORS WILL ELIMINATE LATE MAY, EARLY JUNE 1983	
			(3) NON-CONTACT COOLING WATER FROM LAMINATING PRESSES AND COOLING ROLLS FOR TREATERS BEING DISCHARGED THRU STORMWATER BASIN AND OUT THRU NEW OUTFALL #001.	
			(4) ALGAE BUILDUP IN BASIN WORKMAN REMOVING RISER DURING INSPECTION WILL DRILL LARGER HOLES IN RISER TO ALLOW MORE RAPID FLOW THRU BASIN.	LAWS, REGULATIONS OR PERMIT NO. & COND. NPRES PA0050679
			(5) McDERMOTT WILL SUBMIT DMRs FROM 9-82 TO 4-83 AND SUBMIT FUTURE DMRs ON A REGULAR MONTHLY BASIS AS REQUIRED BY PERMIT	
			(6) STILL WORKING ON NEW BLDG CONSTRUCTION	

SAMPLING POINT	W&W QUALITY REPORT NUMBER	pH	CHLOR RES	COLOR	ODOR	TEMP	D.O.	SPEC COND.	AVG. DAILY FLOW (MGD)
RAW WATER	0107175	7.0		CLEAR	SLIGHT	18°C			
EFFLUENT NEW #001	0107176	8.0		CLEAR	SLIGHT	23°C			TOTAL 0.2
EFFLUENT OLD #001	0107178	8.0		CLEAR	SLIGHT	26°C			
EFFLUENT ORGANICS	0107177								

RECEIVING STREAM APPEARANCE

NAME	ABOVE DIS APP	BELOW DIS APP
TRIBUTARY TO WEST BRANCH RED CLAY CREEK	—	CLEAR + ALGAE

IDENTIFICATION

	CO	MUN	T	EST	CASE	FAC NO. 1	FAC NO. 2	FAC NO. 3	FAC NO. 4	DATE OF INSPECTION	INSPECTING AGENCY
1											
2	4-5	6-8	9	10-11	12-13	14-16	14-16	14-16	14-16	17-22	23-25
3										050983	701

	FACILITY NAME	DIS. VOL. (MGD)	COMPLIANCE FED	INT	FAC	OP	PERMIT COMP	OPER STAT
		49-52	66	67	68	69	70	71-72
1	00071240 #001				/	/	/	76
2	00071237 PLANT				/	3	/	80
3								

PERSON INTERVIEWED (SIGNATURE) Ed McDermott

TITLE AND DATE MAINT SUPT. 5/9/83

INVESTIGATOR (SIGNATURE) Michael C Hassett

TITLE AND DATE WQS 5-9-83

ORIGINAL

164338

AR 000001