UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION II
EDISON, NEW JERSEY 08837

SPCC FIELD INSPECTION FORM

NAME OF FACILITY: Northport Facility

TELEPHONE:

FACILITY CONTACT: Robert Arelt

P.E. CERTIFICATION/DATE: 053335 / 5-1-89

TITLE: Chief Engineer

FACILITY ADDRESS: Waterside Ave @ Eaton Neck Rd, Northport N.Y.

PLAN STATUS (C or N): N

NAVIGABLE WATER AFFECTED: Long Island Sound

UNDER 40 CFR 112 (Y or N): Y

PROBABLE FLOW PATH: Overland to Sound

NPDES #

CAPACITY - (TYPE OF OIL/ABOVE OR BELOW):

#6 Fuel	#2 Fuel
4 - 322,000 bbl	4 - 42,000 g
1 - 650,000 "	1 - 100,000 g
4 - 630,000 g	1 - 10,000 bbl
3 - 210,000 g	

COMMENTS/NON-COMPLIANCE:

A. SPCC PLAN:

1. Indication of Age of tanks & inspection dates. THIS SHOULD BE INCLUDED IN THE PLAN.

B. FIELD INSPECTION:

1. #6 OIL TANKS ARE CONTAINED BY EARTHEN DIKES. DIKES APPEAR TO BE ADEQUATE IN HEIGHT HOWEVER SHOULD BE SURVEYED. ALSO PERMEABILITY OF THE DIKES AND FLOOR SHOULD BE EVALUATED.
2. TRUCK UNLOADING RACK NEW CONTAINMENT MATTING TO BE CONSTRUCTED NEXT YEAR. - "ENVIROMAT"

SCHEDULE FOR IMPLEMENTATION OF ITEMS DUE: 11-30-89

INSPECTOR SIGNATURE/DATE/PHONE: 9-21-89 C.E. [illegible]

FACILITY CONTACT SIGNATURE/DATE: K.M. Hellman 9-21-89

ADDRESS CORRESPONDENCE TO: CHIEF, RESPONSE & PREVENTION BRANCH

333582

CENTRAL FILE

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION II
EDISON, NEW JERSEY 08837

SPCC FIELD INSPECTION FORM

NAME OF FACILITY: Northport Facility

TELEPHONE: _____

FACILITY CONTACT: Robert Avelt

P.E. CERTIFICATION/DATE: 053335 / 5-1-89

TITLE: Chief Engineer

FACILITY ADDRESS: Waterside Ave @ Fort Neck Rd, Northport NY.

PLAN STATUS (C or N): _____

NAVIGABLE WATER AFFECTED: Long Island Sound

UNDER 40 CFR 112 (Y or N): Y

PROBABLE FLOW PATH: Overland to Sound

NPDES # _____

CAPACITY - (TYPE OF OIL/ABOVE OR BELOW):

[illegible] Fuel	#2 Fuel
4 - 22,000 bbl	4 - 42,000
1 - [illegible]	1 - [illegible]
4 - [illegible]	1 - [illegible] bbl
3 - [illegible]	

COMMENTS/NON-COMPLIANCE:

A. SPCC PLAN:

1. [illegible] Any of tanks & inspection dates. [illegible] revised [illegible] SPCC PLAN.

B. FIELD INSPECTION:

1. Fuel tanks are contained by earthen dikes. Dikes appear to be in good condition but should be surveyed. Most [illegible] of the dikes and floor should be surveyed.
2. Tank unloading rack needs containment. Mitigating to be considered next year - "Environmental"

SCHEDULE FOR IMPLEMENTATION OF ITEMS DUE: 11-30-89

INSPECTOR SIGNATURE/DATE/PHONE: 9-21-89 [illegible]

FACILITY CONTACT SIGNATURE/DATE: [illegible] 9-21-89

ADDRESS CORRESPONDENCE TO: CHIEF, RESPONSE & PREVENTION BRANCH

FACILITY COPY