1.2

Olympia D.O.E.

Georgia Pacific
300 W. Laurel

operates independently
chlorine/alkali plant - 1963
pulp mill has been before that

No Date

K071/K106 - brine purification & wastewater treatment sludge from mercury cell process in chlorine production

goes to lined dumpsters & is carted to Arlington (???) what happened to this sludge before it was carted off to Arlington.

USEPA SF
1560761

Scott Paper Co., Everett - Ted Therien says some concern w/ fly ash - Zn content & nothing at D.O.E., Olympia in RCRA files concerning this

NPDES permited - latest one expired June 30, 1981

May 9, 1984 - violation of permit ph in excess of 9.0 due to caustic spill; Scot plans to make piping changes to ensure that all recovery area sump are pumped to treatment system

Jan 4, 1984 - leak in NaOH line caused high pH

Bioassay - reports ~~Apr~~ April 0% survival in ~~001 &~~ 001 + 003 ~~at~~ outlets of waste water; unknow why Mack fish died too; & in Dec 1983; since then 100% of fish survived

in 1982 & 81 Water Cons. file many fines were levied because of pH / both acidic & alkaline

[??] Could not find current permit on file.

[??] rubber burning its it still done on hog pile said cause ↑ Zn in 1981 & were discontinuing it ash clarifier; ash alley → log pond fill "Zinc slag from ash