Tuesday, January 4, 1972

4th Day—362 days to follow

- [ ] CLEAR
- [x] CLOUDY
- [ ] RAIN
- [ ] SNOW

0900 - 0945 - Cleaning Station - adjusted Water + Air level in C2 Water System
Lea Hall

1100

Sump pump	(.2)	227.0
C2-1	(3.0)	4985.4
AC-2	(.2)	1186.5
AC-1	(.1)	1042.8
Grinder	–	75.6
Pump #2	(.9)	27099.0
#1	(18.9)	274551
IAC	(2.9)	5215.3
C2-2	–	235.6

Dredged bar screen - Washed wet well

Wednesday, J

5th Day—36

0750 [illegible]

0155 [illegible]

1500

Sump pump	
C2-1	
AC-2	
AC-1	
Grinder	
Pump #2	
#1	
IAC	
C2-2	

Checked Station - Washed wet well filter pads -

ber 20, 1972

rs to follow

- 0.2 -	301.8
	5307.3
	1229.7
- 0.1 -	1081.0
	75.6
23.1 -	29,805.3
23.1 -	33,047.8
3.1 -	6412.9
10.3 -	920.7

- deraged bar
d wet well area
two pumps on

Lea Hall

0815 Thursday, December 21, 1972

356th Day—10 days to follow

CLEAR / CLOUDY / RAIN / SNOW

Sump pump	(0.2)	302.0
C2-1		5307.3
AC-2	(0.3)	1230.0
AC-1	(0.[illegible])	1081.1
Grinder		75.6
Pump #2	(19.3)	29,824.6
#1	(19.3)	33,067.1
[illegible]	(1.8)	6414.7
C2-2	(10.4)	931.1

Checked station - washed pump room - High Flows two pumps on

Lea Hall

1515 - Checking Station - Flow high

2150 [illegible] gate closed pumps off - gate operator float had stick in it - removed stick opened gate - Station back in operation

Moe Cyll Hall

KCSlip4 61622

SEA429987