AY

1976 250th day – 116 days follow

TUESDAY 7 SEPTEMBER

1976 251st day – 115 days follow

Power outage 0710 due to jack kicked out on pole outside station. due too. Crow shorting out 1 leg causing the fuse too blow. Power restored 0855. No overflow. EwR JH. GH.

Checked Station – Derag barscreen – Hosed Wetwell Recharged Hydro tank.
Hansen – Hale

1500
working on wet well chain hoist.
EwR JH GH.

Close Electric and E.M. Swapping #1 motor & drive and #2 motor & drive. #2 in place of #1 – #1 in place of #2.
EwR.

KCSlip4 61641

SEA430006

ATURDAY

1976 360th day — 6 days follow

SUNDAY 26 DECEMBER

1976 361st day — 5 days follow

1200

CALLED OUT FROM W.P. POWER SYSTEMS ALARM ON CATAD - STATION OK - DEBAGGED BAR - SCREEN - RECHARGED HYDRO. TANK

JONES

KCSlip4 61642

SEA430007