E. MARGINAL

BRANDON OF

BRANDON

KCSlip4 63445

SEA431536

West Point Treatment Plant 689-3801

Metro Industrial Waste

(Monday - Friday, 8 a.m. - 5 p.m.) **689-3000**

Fire Department: For emergency human health and safety concerns **9-1-1**

Company and Local Utility Contact(s)

_____

_____

_____

_____

METRO

KCSlip4 63446

SEA431537

BRANDON O.T.

KCSlip4 63447

SEA431538

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Alist	C Hansen
1-5-96	Send alarms	
TIME IN		
1055		
TIME OUT		
1100		

DATE	Station Alist	Hansen
1-11-96	Send alarms	Durbin
TIME IN	Test Generator - Started on second try	
12:10		
TIME OUT		
12:15		

DATE	sampler maint	Patten
1/12/96		
TIME IN		
1255		
TIME OUT		
1310		

DATE	Station Alist	Durbin
1-18-96	Sent alarm	Hansen
TIME IN	called [illegible] to [illegible]	
0900		
TIME OUT		

KCSlip4 63448

SEA431539

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Performed el. P.M.	Kyal
1/19/96		
TIME IN		
6:35		
TIME OUT		
9:20		

DATE	Station ✓ list	Hansen
1-23-96	Send alarms	Durbin
TIME IN	Trailers w/ trash, Van + car still	
1235	parked in "No Parking" area + blocking	
TIME OUT	access.	

DATE	Station ✓ list	C Hansen
1-31-96	Send Alarms. — Trailer etc +	
TIME IN	vehicles blocking access.	
1245		
TIME OUT		

DATE		
2/1/96	Checked and washed station	Kyal
TIME IN		
7:30	battery.	
TIME OUT		
7:50		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check list, Send Alarms	FAUCHALD
2-7-96	to W.P. Run gen on Sim	
TIME IN	OUTAGE	
13:40		
TIME OUT		

DATE	Rest generator	L.T.
2-8-96	out Fall set at 80% open	
TIME IN		
08:55		
TIME OUT		
09:00		

DATE	Station check list, Send	FAUCHALD
2-14-96	Alarms to W.P. Add water	
TIME IN	to Start batteries	
13:35		
TIME OUT		

DATE	Station check list, Send Alarms	L.T.
2-21-96	to W.P.	B.F.
TIME IN		
14:25		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	area checklist sent Alarms	BF
2-28-96		LT
TIME IN		
1505		
TIME OUT		

DATE	Auto Sampler Setup	Aubert
3-7-96		
TIME IN		
1215		
TIME OUT		
1445		

DATE	Auto-sampler installation	Patten
3/8/96		
TIME IN		
1115		
TIME OUT		
1235		

DATE	Check Stations, Send Alarms, run generator.	B.F.
3/12/96		
TIME IN		
0830		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Sampler cabled-up + on	Patten
3/13		Power
TIME IN		
1115		
TIME OUT		
1130		
DATE	Area Checklist	T.T
3-21-96	Sent Alarm's	B.F
TIME IN	Gen Oil Level - OK	
1200		
TIME OUT		
1230		
DATE	Station checklist, Send Alarms	T.T
3-27-96	to WP	B.F
TIME IN		
1315		
TIME OUT		
DATE	Sampler ✓ + maint	Patten
3/28/96		Ochoa
TIME IN		
1220		
TIME OUT		
1240		

KCSlip4 63452

SEA431543

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Sample P/u + maint	Patten
4/1/96		
TIME IN		
0805		
TIME OUT		
0830		

DATE	Area check list	Tullio
4-5-96	Test Alarms	
TIME IN	Gen - Oil and Fuel - OK	
0920		
TIME OUT		
0930		

DATE	STATION CHECKLIST	Rick S
4.10.96	FAN GENERATOR * TOOK 5 TRIES	TIM T.
TIME IN	(CRANKS) TO START	
1520		
TIME OUT		
1535		

DATE	Sampler ✓ + maint	Patten
4/11/96		Power
TIME IN		
1120		
TIME OUT		
1135		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	INSTALL NEW PRI FUEL	
4-15		
TIME IN		
1030	Pump & Test Run	[illegible]
TIME OUT		
1100		
	[illegible]	

DATE	Sample P/U & re-set	Patten
4/16/96		
TIME IN		
0825		
TIME OUT		
0850		

DATE	SENDING INST AIR ALARM TO SCADA	J BALL
4/17/96		
TIME IN		
0903		
TIME OUT		
0922		

DATE	STATION CHECKLIST	Rick S
4-17-96	SENT ALARMS	T.M.T.
TIME IN		
1225		
TIME OUT		
1300		

KCSlip4 63454

SEA431545

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Sample P/u + re-set	Patten
4/23/96		Haberman
TIME IN		
1030		
TIME OUT		
1055		

DATE	CHECKING INST AIR ALARM TO	BALL
4/23/96	SCADA	
TIME IN		
1430		
TIME OUT		
1435		

DATE	sample P/u + turn off	Patten
4/23/96		Budka
TIME IN		
1605		
TIME OUT		
1625		

DATE	DOING INSTRUMENT PM's	J BALL
4-25-96		
TIME IN		
0711		
TIME OUT		
0725		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	STATION CHECK LIST	Rick S
5-2-96	RAN GENERATOR - DID NOT START UP	TIM T
TIME IN	UNTILL 3RD TRY (RESET ONCE)	
1000	SENT ALARMS	
TIME OUT		
1030		

DATE	STATION CHECKLIST	Rick S.
5-9-96	SENT ALARMS	
TIME IN		
1345		
TIME OUT		
1400		

DATE	INSTATION	BLAIR
5-14-96	SEND ALARMS	OLIVEROS
TIME IN	CHECKLIST	
13:13		
TIME OUT		

DATE		
5-14	TEST LOAD BANK (1/2)	
TIME IN		Raymond
TIME OUT	1/2 HR @ 15 AMP	

KCSlip4 63456

SEA431547

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Sampler re-set & start	Patten
5/14		
TIME IN		
1450		
TIME OUT		
1505		
DATE	Inspect with Superior Fire	Blair
5-15-96	Extinguisher Co.	L&I F
TIME IN		
11:21		
TIME OUT		
DATE	re-set samplers	Patten
5/20		
TIME IN		
1025		
TIME OUT		
1050		
DATE	Sample f/u & re-set	Patten
5/22		Oehs
TIME IN		
0815		
TIME OUT		
0840		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checked station Send Alarms	Ophus
5/22/96		Salsbury
TIME IN		
1510		
TIME OUT		

DATE	- CHECKLIST - SENT ALARM	[illegible]
6 4 96	- CHANGED OUTSIDE LIGHT	L.T.
TIME IN		
TIME OUT		

DATE	area check list	Lt.
6-13-96	area clean up out side.	
TIME IN	changed Filter	
TIME OUT		

DATE	- CHECK LIST	
6 19 96	- SENT ALARMS	
TIME IN		
TIME OUT		

KCSlip4 63458

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	- CHECKLIST - SENT ALARM	
6-25-96	- FILLED OIL ON GATE.	
TIME IN		
1000		L.T.
TIME OUT		

DATE	area check list sent Alarms	
7-3-96	test generator	
TIME IN		
TIME OUT		

DATE		
7/8/96	Inspection for CAMPS project	M. D'Ambrosio
TIME IN		
6 30		
TIME OUT		
640		

DATE		
7-9-	CLEAN, ~~[illegible]~~, PREP, & PAINTED	Eyleil
TIME IN		
13:00	NO PARKING SIGNS & STRIPING	
TIME OUT	IN AREA.	

KCSlip4 63459

SEA431550

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist, Send Alarm	L.T.
7.11.96	to W.P. / Cars parked on	B.F.
TIME IN	No Parking Area.	
10:30		
TIME OUT		

DATE	Station checklist, Send Alarms	L.T.
7.16.96	to W.P. House Keeping.	B.F.
TIME IN		
12:25		
TIME OUT		

DATE	Orca checklist Sent Alarms	LT.
7-27-96		
TIME IN		
TIME OUT		

DATE		
7.29	Serviced Gas & Load Test	Raymond
TIME IN		
TIME OUT		

KCSlip4 63460

SEA431551

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	sample P/U	Patten
8/2		Mickelson
TIME IN		
0825		
TIME OUT		
0840		
DATE		
8-6	Mech PM	Green
TIME IN		
TIME OUT		
DATE		
8/13/96	Checked and washed emer. gen	Stynt
TIME IN	battery.	
8:05		
TIME OUT		
8:25		
DATE	Station checklist, Send Alarms to	T.T.
8-14-96	W.S.	B.F.
TIME IN		
14:00		
TIME OUT		

KCSlip4 63461

SEA431552

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area Check list	T=T
8-21-96	Sent Alarms	
TIME IN		
1000		
TIME OUT		
1010		

DATE	Station Check list	T=T.
8-27-96	Sent Alarms	
TIME IN		
0805		
TIME OUT		
0815		

DATE	INSTATION — INSTALL SIGNS	Blair
8/27/96		
TIME IN		
1416		
TIME OUT		

DATE	Station check list . Monthly Generator test.	Oliver &
9/5/96	Sent alarms	Trimble
TIME IN		
1817		
TIME OUT		

KCSlip4 63462

SEA431553

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	sampler ✓ + maint	Patten
9/6/96		
TIME IN		
1025		
TIME OUT		
1045		

DATE	Station checklist. Sent alarms	Olivers
9/9/96		
TIME IN		
1005		
TIME OUT		

DATE	station checklist. Sent alarms	Olivers.
9/16/96		
TIME IN		
0840		
TIME OUT		

DATE	sample P/U + re-set	Patten
9/16		
TIME IN		
1035		
TIME OUT		
1105		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
9-18	install lockout station	Green
TIME IN		
TIME OUT		

DATE	sampler ✓ & maint	Patton
9/20		
TIME IN		
1100		
TIME OUT		
1120		

DATE	Station checklist	7-7
9-24-96	[illegible]	M.C
TIME IN	Yard work	
1315		
TIME OUT		
1325		

DATE	Station checklist. Sent alarms.	[illegible]
9/30/96		
TIME IN		
1000		
TIME OUT		

KCSlip4 63464

SEA431555

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CHECKING INST AIR ALARM OK	J BALL
13-1-96		
TIME IN		
1214		
TIME OUT		
1220		

DATE	Station checklist . Send alarms . Monthly	
10/7/96	generator test	
TIME IN		
1355		
TIME OUT		

DATE	sample P/U, re-set + maint	Patten
10/10		
TIME IN		
0900		
TIME OUT		
0925		

DATE	sample P/U + turn-off samplers	Patten
10/13		
TIME IN		
1150		
TIME OUT		
1205		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms.	Olivares
10/17/96		
TIME IN		
1425		
TIME OUT		

DATE	Station checklist. Sent alarms	Olivares
10/22/96	Cleaned station "in & out side".	
TIME IN		
1052		
TIME OUT		

DATE	DOING INST. PM'S	J BACK
10-29-96		
TIME IN		
1005		
TIME OUT		

DATE	Station checklist. Sent alarms. changed	Olivares
10/29/96	burned out light bulb in station. filled gate	Salsbery
TIME IN	oiler.	
1320		
TIME OUT		

KCSlip4 63466

SEA431557

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	sampler re-set + maint	Patten
10/31		Droker
TIME IN		
1215		
TIME OUT		
1235		

DATE	- CHECKLIST SENT ALARM.	MJ
11 6 96	- RUN GENERATOR - VERY HARD STARTING.	
TIME IN	- GENERAL CLEANING.	RS.
0950.		
TIME OUT		

DATE		
11/12/96	Checked and cleaned emer. gen	Hynt
TIME IN	battery.	
10:40		
TIME OUT		

DATE	STATION CHECK	Rick S.
11-12-96	SENT ALARMS	
TIME IN		
1330		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	sample P/u + re-set	Patten
11/13		McClain
TIME IN		
1005		
TIME OUT		
1020		

DATE	Check Station per W.P.	B.E
11.21.96		
TIME IN		
04:50		
TIME OUT		

DATE	STATION CHECK	Rich S.
11-21-96	SENT ALARM	
TIME IN		
1400		
TIME OUT	1430 CHECK ALARMS	J BALL
	1445	

DATE	STATION CHECK	Rich S.
11-26-96	SENT ALARMS	
TIME IN		
1430		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Med-Tox NW Bldg Survey	Tori Choate
11/26/96		Bill Murray
TIME IN		
14:40		
TIME OUT		
15:00		

DATE	- CHECKLIST	W.
12-3-96	- SENT ALARM	
TIME IN	- GENERATOR VERY HARD STARTING FAILED 2 TIMES.	LT
0930.	- WIPING DOWN EQUIPMENT	
TIME OUT		
	* W/O GENERATOR	

DATE	turning samplers on + maint	Patten
12/3		
TIME IN		
1120		
TIME OUT		
1145		

DATE	P/u samples	Patten
12/4		
TIME IN		
1325		
TIME OUT		
1350		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	area check list / Sent Alarms	LT
12-12-96		
TIME IN		
TIME OUT		

DATE	area check list / Sent Alarms	KB
12-19-96		LT
TIME IN		
09:00		
TIME OUT		

DATE	area check list - Sent Alarms	LT
1-3-97	test generator to 4 time to start	
TIME IN		
12:45		
TIME OUT		

DATE	Station checklist, Area Check	T.T.
1-7-97	Sent Alarms	
TIME IN		
1355		
TIME OUT		
1310		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	P.M. STATION	Tom Elwell
1-9-97		
TIME IN		
0830		
TIME OUT		

DATE	Area Check list	J.T.
1-16-97	Station Check	J.T.
TIME IN	Added Out to Outfall Note	
1000	Date	
TIME OUT	Sent Alarms	
1025		

DATE	Station Checklist	J.T.
1.23.97	Sent Alarms	J.T.
TIME IN		
0936		
TIME OUT		

DATE	turn on samplers	Patten
1/27/97		Weasel
TIME IN		
1405		
TIME OUT		
1420		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	P/u samples + re-set sampler	Patten
1/28/97		
TIME IN		
1050		
TIME OUT		
1115		

DATE	area checklist Sent Alarm	tim t.
1-30-97		L.T.
TIME IN		
12:45		
TIME OUT		
12:55		

DATE		
1-30	Load Test Gen @ 15-A	Raymous
TIME IN		
12:30	For 2 Hr's	
TIME OUT		

DATE	area check list Sent Alarms	L.T.
2-5-97	test generator	MO
TIME IN		
TIME OUT		

KCSlip4 63472

SEA431563

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	over check list sent Alarms	Lt
1-11-97		
TIME IN		
10:30		
TIME OUT		

DATE	sampler re-set	Patten
2/19		
TIME IN		
1250		
TIME OUT		
1305		

DATE	CHECKING TELEMETRY ALARMS	J BALL
2-20-97		
TIME IN		
1241		
TIME OUT		
1255		

DATE	Station Checklist sent alarms cleared	Oliver
2/20/97	Station	Tanzer
TIME IN		
1425		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE 2/25/97	checked and washed emer. gen.	Kynl
TIME IN 11:10	battery.	
TIME OUT		
DATE 2-26-97	area check list sent Alarms	Lt. M.O.
TIME IN 1340		
TIME OUT		
DATE 3/4/97	Station check	A
TIME IN 1200		
TIME OUT		
DATE 3/4	re-set + turn on samplers	Patten
TIME IN 1340		
TIME OUT 1400		

KCSlip4 63474

SEA431565

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	sample P/u + re-set	Patten
3/7		
TIME IN		
1425		
TIME OUT		
1450		

DATE	sample P/u + re-set	Patten
3/12		
TIME IN		
0930		
TIME OUT		
0950		

DATE	Sent alarms	VA
3/14/97	ran generator	
TIME IN	checklist	
0730		
TIME OUT		

DATE	P/u samples	Patten
3/15		
TIME IN		
1630		
TIME OUT		
1650		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	area check list Sent Alarms	Lt.
3-27-97	plead off Valve leeking again will Right	
TIME IN	up	
1135		
TIME OUT		

DATE	Area check	C. A
4-3-97	Station check list	T. T.
TIME IN	Sent Alarm's	
0820		
TIME OUT		
0835		

DATE	sampler re-set + ✓	Patten
4/3		
TIME IN		
1025		
TIME OUT		
1040		

DATE	Station check	T. T.
4-11-97	Sent Alarm's	
TIME IN	Area check list	
1040		
TIME OUT		
1055		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	RAN Counter	CA
4/11/97	sent alarms	
TIME IN	checklist	
1352		
TIME OUT		

DATE	sampler re-set & maint	Patten
4/18/97		Weagle
TIME IN		
1020		
TIME OUT		
1045		

DATE	Sample P/U, turn off samplers	Patten
4/20		
TIME IN		
1220		
TIME OUT		

DATE	Checklist	CA
4/24/97	sent alarms	
TIME IN		
1215		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	re-set + turn on samplers	Patten
4/26		
TIME IN		
2030		
TIME OUT		
2040		

DATE	CHECK OUTFALL Gate, Limit	B/M
4/26/97	[redacted] Switch may Need	
TIME IN	CALIBRATED; WEST POINT Receiving	
12:43	0% PERCENT But Still Shows	
TIME OUT	overflowing.	

DATE	samples / + maint	Patten
4/30/97		
TIME IN		
1045		
TIME OUT		
1100		

DATE	re-set samplers + maint, clean line	Patten
5/2/97		Weasel
TIME IN		
1025		
TIME OUT		
1050		

KCSlip4 63478

SEA431569

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check list [illegible]	T-7
5-8-97	Sent Alarm's	[illegible]
TIME IN	Area Check	
1205	Test Pan Gen	[illegible]
TIME OUT	Fuel level at "Full"	
1220	Gen New Hours → 875.0	[illegible]

DATE	sampler ✓'s	Patten
5/8		
TIME IN		
1240		
TIME OUT		
1255		

DATE	Station Check	[illegible]
5-15-97	Station Alarms sent	
TIME IN	Area checklist -	
0931		
TIME OUT		
0940		

DATE	Area checklist	T-7
5-23-97	Sent Alarms	
TIME IN		
0805		
TIME OUT		
0830		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	sampler ✓ + maint	Patten
5/27		
TIME IN		
1030		
TIME OUT		
1055		

DATE	✓ing samplers	Patten
5/31		
TIME IN		
0920		
TIME OUT		
0930		

DATE	Stat[illegible] checklist Sent alarms	Olivers
[illegible]	[illegible]	Trawbridge
TIME IN		
0900		
TIME OUT		

DATE	station checklist Sent alarms	Olivers
6/11/97	Run generator on simulated outage	
TIME IN		
1110		
TIME OUT		

KCSlip4 63480

SEA431571

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checking Flap Gate at station	Blau
6-11-97		
TIME IN		
1400		
TIME OUT		

DATE	Checked and washed emer. gen.	Hynt
6/16/97	battery.	
TIME IN		
12:55		
TIME OUT		

DATE	Station Checklist Sent alarms	[illegible]
6/19/97		[illegible]
TIME IN		
1040		
TIME OUT		

DATE	Station Check	[illegible]
6-26-97	Sent Alarms	M.O
TIME IN	Area Checklist	
0740		
TIME OUT		
0750		

KCSlip4 63481

SEA431572

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms	Olivares
7/1/97		[illegible]
TIME IN		
1235		
TIME OUT		

DATE	Checked Ex Fan	T. E[illegible]
7-9-97	Fan Ok Fan Sample	
TIME IN	[illegible]	
1240	[illegible]	
TIME OUT		

DATE	In station Grabbed sample out	Olivares
7/10/97	of outfall discharge area	
TIME IN		
1945		
TIME OUT		

DATE	Station Checklist	7-7
7-11-97	Sent Alarms	
TIME IN	Area Check	
0945		
TIME OUT		
0955		

KCSlip4 63482

SEA431573

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist	T-7
7-17-97	Sent Alarms	
TIME IN	Switch T. A load from a 1-2	
1035	to a 2-1	
TIME OUT		
1045		

DATE	Checked Station	[illegible]
7-21-97		
TIME IN		
1015		
TIME OUT		
1030		

DATE	Station Check	T-7
7-23-97	Sent Alarms	
TIME IN		
0740		
TIME OUT		
0750		

DATE	Station checklist. Sent alarms	[illegible]
7/30/97		
TIME IN		
0805		
TIME OUT		

KCSlip4 63483

SEA431574

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Inspection	Blair
8/6/97	Checklist	
TIME IN	Send Alarms	
09:16		
TIME OUT		
DATE	Station checked - Sent alarms	Oliver
8/11/97	Run generator on simulated outage.	
TIME IN	Added oil on outfall gate after	
TIME OUT		
DATE	Checked and washed emerg. gen. battery.	Sigal
8/15/97		
TIME IN		
11:20		
TIME OUT		
DATE	Station checklist - Sent alarms	Oliver
8/19/97	Cleaned station	
TIME IN		
1330		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Stat[illegible] checklist. Sent [illegible]	Ohm
8/27/97		
TIME IN		
1240		
TIME OUT		

DATE	Stat[illegible] checklist. Sent [illegible]	Ohm
9/8/97		
TIME IN		
1430		
TIME OUT		

DATE		
9/15/97	Checked [illegible]	[illegible]
TIME IN	[illegible]	[illegible]
1130		
TIME OUT		
1140		

DATE	✓ing & maint of samplers	Patten
9/17		
TIME IN		
1130		
TIME OUT		
1150		

KCSlip4 63485

SEA431576

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	[illegible] Sent alarms	Olivia
9/17/97	[illegible] on simulated Outage	
TIME IN		
1250		
TIME OUT		
DATE	Stat. checklist Sent alarms	Olivia
1/23/97		
TIME IN		
0910		
TIME OUT		
DATE	sampler ✓ & maint	Patten
7/23		
TIME IN		
1000		
TIME OUT		
1015		
DATE	P/U storm samples	Patten
10/1/97		[illegible]
TIME IN		
1355		
TIME OUT		
1430		

KCSlip4 63486

SEA431577

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
10/2/97	[illegible]	[illegible]
TIME IN		
0930		
TIME OUT		
[illegible]		

DATE	[illegible]	[illegible]
10/3/97		
TIME IN		
1100		
TIME OUT		

DATE	sampler ✓ + re-set	Patton
10/7		Budke
TIME IN		
0945		
TIME OUT		
1005		

DATE	sampler ✓ + re-set	Patten
10/8		[illegible]
TIME IN		
1005		
TIME OUT		
1030		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	[illegible]	[illegible]
10/8/09		
TIME IN		
[illegible]		
TIME OUT		

DATE	[illegible]	Pathe
10/9		
TIME IN		
0805		
TIME OUT		
0840		

DATE	[illegible]	[illegible]
[illegible]	[illegible]	
TIME IN		
[illegible]		
TIME OUT		

DATE	In station with Engineers Seth	LOSNIAK
10/27	Grube and Brian Azari on CAMPS	
TIME IN	eval of gate/generator	
TIME OUT		

KCSlip4 63488

SEA431579

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	P/u samples, re-set samplers	Patten
10/29/97		
TIME IN		
0905		
TIME OUT		
0930		
DATE		
11/3/97	Performed an inst Pm	Jack Lewis
TIME IN		
0830		
TIME OUT		
0915		
DATE	Station checklist, Sent alarms	Olivera
11/[illegible]/97		[illegible]
TIME IN		
0930		
TIME OUT		
DATE	Station checklist - Sent alarms	Olivera
11/10/97		
TIME IN		
1315		
TIME OUT		

KCSlip4 63489

SEA431580

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	[illegible]	[illegible]
[illegible]	[illegible]	
TIME IN		
[illegible]		
TIME OUT		
DATE	[illegible]	[illegible]
11/5/07	Ran generator or [illegible]	[illegible]
TIME IN		
[illegible]		
TIME OUT		
DATE	[illegible]	[illegible]
[illegible]		
TIME IN		
1115		
TIME OUT		
DATE	[illegible]	[illegible]
12/6/07	[illegible]	
TIME IN	[illegible]	
[illegible]		
TIME OUT		
1225		

KCSlip4 63490

SEA431581

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Hand T. Pkr [illegible]	Tom [illegible]
6/12		
TIME IN		
0645		
TIME OUT		
DATE	Checked station	[illegible]
[illegible]		
TIME IN		
[illegible]		
TIME OUT		
DATE	Capital Assets	Sagen
12/16		[illegible]
TIME IN		
1245		
TIME OUT		
DATE	Station checklist. Sent alarms	[illegible]
12/18/[illegible]	Filled outfall gate [illegible]	[illegible]
TIME IN		
TIME OUT		

KCSlip4 63491

SEA431582

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Sent Alarm	T-7.
12-23-97	Station checklist	
TIME IN		
0945		
TIME OUT		
1000		
DATE	Station checklist — sent alarm	T-7
12-31-97	Area check	
TIME IN	Test [illegible]	
1130	Fuel level → full	
TIME OUT	[illegible] → 876.1	
1200		
DATE	Station [illegible]	[illegible]
1/7/98		
TIME IN		
1115		
TIME OUT		
DATE	Pulling samples, line maint	Patton
1/9/98		
TIME IN		
0925		
TIME OUT		
1025		

KCSlip4 63492

SEA431583

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms	Olmo
1/13/98		[illegible]
TIME IN		
0915		
TIME OUT		

DATE	Station checklist. Sent alarms	Olmo
1/21/98		
TIME IN		
1145		
TIME OUT		

DATE	AT STATION CHECKLIST ~~Station~~ [illegible]	[illegible]
1-23-98	[illegible]	
TIME IN		
0840		
TIME OUT		
0950		

DATE	Station checklist	
2/3/98	Sent alarms	
TIME IN		
1030		
TIME OUT		

KCSlip4 63493

SEA431584

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
2/3/98	Checked and cleaned emer. gen. battery.	Hyde
TIME IN		
10:40		
TIME OUT		

DATE	Station check list	P VERRIO
2/10/98	Run gen	
TIME IN		
1100		
TIME OUT		

DATE	Weekend Station Check. Replaced lamp out.	[illegible]
2/3/98		
TIME IN		
815		
TIME OUT		

DATE	Station checklist	CD
2/19/98		DJ
TIME IN		
1135		
TIME OUT		

KCSlip4 63494

SEA431585

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist, Sent Alarms	Tim T
2-25-98	Area Check.	
TIME IN	Outfall Gate Oiler leaking	
1455	W/O	
TIME OUT		
1510	Need 16X20X2 Filter	

DATE	Area Checklist Sent Alarm's	Tim T
3-6-98	Station Check	
TIME IN		
0710		
TIME OUT		
0720		

DATE		
3/11/98		
TIME IN		
[illegible]		
TIME OUT		
[illegible]		

DATE	Station Checklist, Sent Alarm's	Tim T
3-12-98	Area Check, Test Ran Generator	
TIME IN	Fuel level - Full	
0745	New Gen Hour's → 876.1	
TIME OUT		
0810		

KCSlip4 63495

SEA431586

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	T. T
3-17-98	Sent Alarm's	
TIME IN	Area Check	
0750		
TIME OUT		
0805		
DATE		
3/17/98	Checked and cleaned emer. gen. battery.	Tdynl
TIME IN		
10:15		
TIME OUT		
DATE	Area checklist, Sent Alarm's	T. T
3-26-98	Station check.	
TIME IN		
0650		
TIME OUT		
0700		
DATE	Station checklist, Sent Alarms	T. T
4-2-98	Area Check, Area Sampling	
TIME IN		
0650		
TIME OUT		
0705		

KCSlip4 63496

SEA431587

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Test Run Generator	T-T
4-3-98	Fuel level Full	
TIME IN	New Gen Hour → 876.6	
0645		
TIME OUT		
0700		
DATE	Station Checklist	CD
4/8/98	Sent alarms	TT
TIME IN		
1045		
TIME OUT		
DATE		
4/10/98	Fix Gate oiler	Salazar
TIME IN		
1000		
TIME OUT		
DATE	Station Checklist Sent Alarms	T-T
4-16-98	Area Check	
TIME IN	Gate Oiler is Empty. Will	
0635	Talk to Lube Person.	
TIME OUT		
0650		

KCSlip4 63497

SEA431588

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	Tim T
4-23-98	Sent Alarm's	
TIME IN	Area Check.	
0950		
TIME OUT		
1000		

DATE	Area Check, Sent Alarm's	Tim T
4-30-98	Station Checklist	
TIME IN		
0945		
TIME OUT		
0955		

DATE	Station Checklist	Tim T
5-7-98	Sent Alarm's	
TIME IN	Area Check.	
0735		
TIME OUT	Test Run Generator, Fuel	
0750	level at → 5 gals	
	New Gen Hour's → 876.7	

DATE		
5-12	installed a new [illegible] in	
TIME IN	#1 position. Need to	Green
10:00	have elect. wire before	
TIME OUT	complete installation	
1130		

KCSlip4 63498

SEA431589

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
5/15/98	Mounted, connected and tested	[illegible]
TIME IN		
6:50	Inst. air compressor #1.	
TIME OUT		
	finished installation of #17 MC	[illegible]
DATE	Station Checklist, Sent Alarm's	Tim T
5-14-98	Area Check	
TIME IN		
0950		
TIME OUT		
1000		
DATE	Area Checklist	T-T
5-21-98	Sent Alarm's	
TIME IN	Station Check	
1120		
TIME OUT		
1130		
DATE	Station Checklist	T-T
5-28-98	Sent Alarm's	
TIME IN	Area Check	
1000		
TIME OUT		
1015		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	T-T
6-4-98	Sent Alarm's	
TIME IN	Area Check	
0710		
TIME OUT		
0720		
DATE		
6/4/98	Sent alarms	Jack Lewis
TIME IN		
1250		
TIME OUT		
1300		
DATE	Station Checklist, Sent Alarm's	T-T
6-10-98	Area Check	
TIME IN	Test Pam Generator	
1045	Fuel level → Full	
TIME OUT	New Gen Hours → 877.1	
1120		
DATE	IN STATION TO CHECK	GREENE
6/18/98	GEN. SET	
TIME IN		
0845		
TIME OUT		

KCSlip4 63500

SEA431591

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist, Sent Alarm	Tim T
6-19-98	Area Check	
TIME IN		
0700		
TIME OUT		
0720		

DATE	IN STATION, CHANGED OIL	S. GREENE
6/22/98	& FILTER ON GEN SET	
TIME IN	REPLACED FUEL FILTER	
0700		
TIME OUT		
0830		

DATE	Station Checklist	M. YARNO
6-24-98	Send alarm	
TIME IN		
1300		
TIME OUT		

DATE	[illegible]	[illegible]
[illegible]		
TIME IN		
[illegible]		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	Tim T
7-1-98	Sent Alarms	
TIME IN	Area Check.	
0715		
TIME OUT		
0730		

DATE	Station Checklist, Sent Alarms	Tim T
7-7-98	Area Check, Test Pan Generator	
TIME IN	Fuel level → 5+ Gals	
0715	New Gen Hour's → 877.4	
TIME OUT	Outside Lamping	
0745		

DATE	sampler ✓ + maint	Patton
7/15/98		Beauregard
TIME IN		
1050		
TIME OUT		
1105		

DATE	Station Checklist	Tim T
7-21-98	Sent Alarms	
TIME IN	Area Check.	
0650		
TIME OUT		
0710		

KCSlip4 63502

SEA431593

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check	Tim T
1-30-98	Sent Adams's	
TIME IN	Area check	
0650		
TIME OUT		
0705		
DATE	LOAD TEST GENERATOR	GREENE
8/4/98		
TIME IN		
1400		
TIME OUT		
DATE		
8-4-98		GOUCHER
TIME IN	RE CORE STATION	WILLIAMSON
1550		
TIME OUT		
1555		
DATE	Station Checklist	Tim T
8-14-98	Sent Adams's	
TIME IN	Area check	
0635		
TIME OUT		
0650		

KCSlip4 63503

SEA431594

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	MECH. PM	PAULA
8/14/98		
TIME IN		
13 40		
TIME OUT		
DATE		
8/24/98	Checked and cleaned emer. gen. battery.	Kyrt
TIME IN		
TIME OUT		
DATE	Station Checklist, Sent Alarm's	
8-27-98	Area Check,	
TIME IN		Tim T
0645		
TIME OUT		
0700		
DATE	Station Checklist	Tim T
9-2-98	Sent Alarm's	
TIME IN	Area Check	
0650		
TIME OUT		
0710		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
1/2	Cal'd tide Xmtr	Jack Lewis
TIME IN		
0950		
TIME OUT		
1030		
DATE	Station Checklist	Tim T
9-10-98	Sent Alarms	
TIME IN	Area Check	
0650		
TIME OUT		
0710		
DATE	Station Checklist	Tim T
9-18-98	Area Check	
TIME IN		
0710		
TIME OUT		
0725		
DATE	Station Checklist	Tim T
9-25-98	Sent Alarms, Area Check	
TIME IN		
0710		
TIME OUT		
0725		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	Tim T
9-29-98	Sent Alarm's, Area check.	
TIME IN	Outside Lamping	
0710		
TIME OUT		
0725		
DATE	Station Checklist	Tim T
10-9-98	Sent Alarm's	
TIME IN	Area check.	
0700		
TIME OUT		
0715		
DATE	Test Pump Generator	Tim T
10-15-98	Fuel level at 5gals	
TIME IN	New Run Hour's → 878.3	
0715	Station checklist, Sent Alarm's	
TIME OUT	Area Check	
0750		
DATE	Station Checklist	Tim T
10-23-98	Area Check	
TIME IN		
0800		
TIME OUT		
0815		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	REPACKED FUEL TRANSFER	GREENE
10/27/98	PUMP ON GENERATOR ENG.	
TIME IN		
1100	(87813 HRS)	
TIME OUT		
1200		

DATE	Station check list, Sent	T=T
10-29-98	Alarm's	
TIME IN	Area check.	
0650		
TIME OUT	Purge Bubbler	
0710		

DATE	Assess Check	Sean Wagner
11-4-98		
TIME IN		
1400		
TIME OUT		

DATE	Station Checklist	J.L
11-5-98	Sent Alarm's	
TIME IN	Area Check.	
1015		
TIME OUT		
1025		

KCSlip4 63507

SEA431598

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Starting Checklist	Tim T
11-9-98	Sort Alarms	
TIME IN	Area Check	
0700	Purge Bubbler	
TIME OUT		
0715		

DATE	In Station w/ Elcon Engineer	LESNIAK
11/24		Goldberg
TIME IN		BARNETT
TIME OUT		

DATE	STATION check	RS
11-26-98	TRUNK 107.0	
TIME IN	TIDE .5'	
0140	O.F. GATE "0" %	
TIME OUT	POWER TO OUTFALL GATE, WILL	
	NOT OPEN	

DATE		
11/30/98	Replaced OS gate -	George Kyrl
TIME IN		
0840	Adjusted "close" limit switch	Jackie Lewis
TIME OUT		
1000		

KCSlip4 63508

SEA431599

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Starting Checklist	Tri T
12-3-98	Sent Alarms	
TIME IN	Area check	
0700		
TIME OUT		
0720		
	Could Not Test Generator Due To	
	Low Battery W/O	
DATE		
12/3/98	Checked battery for emergency gen. It'll	Kyle
TIME IN	put a bigger charger on.	
11:50		
TIME OUT		
	Installed a new battery for emer. gen.	
	Tested. Starter is cranking but the	
	engine won't start. Turned over to mechanic.	
DATE		GREENE
12/3/98	STARTED ENGINE	
TIME IN	SHUT OFF — WENT	
1400	HOME	
TIME OUT		
DATE	Checked station - called to station	D. YARNO
12/7/98	outfall gate open showing at	
TIME IN	~1% gate closed to 0-0%	
12-00		
TIME OUT		
	1700 / tied sensor & bracket together	D. YARNO
	to cheap alarm at W/P for	
	outfall gate.	

KCSlip4 63509

SEA431600

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checked outfall	Tom Ehrell
12/8/98	GATE Alarm will make	
TIME IN	A ~~[illegible]~~ BRACE FOR	
0700	SWITCH on gate	
TIME OUT		
	Time in 11:45	B. Herman
	Verify Door dim.	

DATE	Station checklist	Tim T
12-9-98	Sent Alarms	
TIME IN	Purge Bubbler	
0700	Area check.	
TIME OUT		
0725		

DATE	Working on GATE +	Tom Ehrell
12/9/98	PM STATION	
TIME IN		
0950		
TIME OUT		

DATE	Called out on outfall gate Error	B.F.
12-11-98	Trunk level 106.4	
TIME IN		
1745		
TIME OUT		

KCSlip4 63510

SEA431601

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check, Purge Bubbler	Tim T
12-17-98	Sent Alarm's, Area Checklist	
TIME IN		
0700		
TIME OUT		
0715		
DATE	Station Checklist, Sent Alarm's	Tim T
12-22-98	Area check, Purge Bubbler	
TIME IN		
0900		
TIME OUT		
0915		
DATE	Station checklist	Tim T
12-31-98	Sent Alarms	
TIME IN	Area Check.	
0720		
TIME OUT		
0740	New 1999 Log Book in Station	
DATE		
TIME IN		
TIME OUT		

BRANDON REC

KCSlip4 63512

SEA431603

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station ✓ list	Hansen
1-5-96	Send alarms	
TIME IN		
1100		
TIME OUT		
1110		

DATE	STATION ✓ list	Durbin
1-11-96	Sent alarms	
TIME IN	Tested gen	
1206		
TIME OUT		

DATE	Station ✓ list	Durbin
1-18-96	Send alarms	Hansen
TIME IN	Change air filter	
0900		
TIME OUT		

DATE	STATION ✓ list	Durbin
1-23	Sent alarms	Hansen
TIME IN		
1238		
TIME OUT		

KCSlip4 63513

SEA431604

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station ✓ list	O Hansen
1-31-96	Send alarms	
TIME IN		
1300		
TIME OUT		

DATE		
2/1/96	Checked and washed station battery	Hypl
TIME IN		
7:50		
TIME OUT		
8:10		

DATE	CALIBRATE GAS DETECTOR	J LEWIS
2/1/96		J BALC
TIME IN		
840		
TIME OUT		
848		

DATE	Calibrated the ~~gas~~ regulator	J. Lewis
2-2-96	gate transmitter.	
TIME IN		
1130		
TIME OUT		
1215		

KCSlip4 63514

SEA431605

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		MILLER/MCCAN
2-6-96	CHECK BUBBLER VALVES	
TIME IN		
12:40		
TIME OUT		
12:46		

DATE	Station checklist, Send Alarms	Fauchald
2-7-96	to W.P. Will test gen.	
TIME IN	Later.	
14:00		
TIME OUT		

DATE	In Station making sure	LT.
2-8-96	gen. is in auto	
TIME IN		
08:50		
TIME OUT		
0855		

DATE	Station checklist, Send Alarms	Fauchald
2-14-96	to W.P. Run gen. on Sim.	
TIME IN	OUTAGE	
13:25		
TIME OUT		

KCSlip4 63515

SEA431606

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist, Send Alarms	L.T.
2-21-96	to W.P.	B.F.
TIME IN		
14:30		
TIME OUT		

DATE		
3/23/95	Check Telemetery	Paxton
TIME IN		
1658		
TIME OUT		
1740		

DATE	area checklist Sent Alarms	B.F.
2-28-96		L.T.
TIME IN		
15:10		
TIME OUT		

DATE	Area Checklist	B.F.
3-6-96	Sent Alarms	T.T.
TIME IN		
TIME OUT		

KCSlip4 63516

SEA431607

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Installing sampler program and	Jacla Fewit
3-11-96	wiring	John Ball
TIME IN		
0830		
TIME OUT		

DATE	Check Station, Send Alarms, Run	B.F.
3.12.96	generator. Lamping	
TIME IN		
0845		
TIME OUT		

DATE	Area Check list	T.T
3.21.96	Sent Alarm's	B.F
TIME IN	Gen - Oil Level - OK	
1245		
TIME OUT		

DATE	Sent Alarm's	T.T
3-27-96	Area Check list	B.F
TIME IN	Gen - Oil Level - OK	
1315		
TIME OUT		
1335		

KCSlip4 63517

SEA431608

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area checklist	Frank
4-5-96	Sent Alarms	
TIME IN	Exercise Reg. Gate	
0935		
TIME OUT		
0950		

DATE	STATION CHECKLIST	Rick S
4.10.96	RAN GENERATOR	Tim T.
TIME IN	SENT ALARMS	
1545		
TIME OUT		
1600		

DATE		
4/11/96	Check Gate Not Ready	Paxton
TIME IN	Alarm	
16:45		
TIME OUT		
18:00		

DATE		
4/12/96	Relaced Control Power	Paxton
TIME IN	Transfor MCR	
TIME OUT		

KCSlip4 63518

SEA431609

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	SENT INST AIR ALARM TO SCADA	BALL
4/17/96	OK	
TIME IN		
0855	CAME BACK TO CHECK IA	
TIME OUT	ALARM FROM OUTFALL	
0904	LEFT 0953	

DATE	STATION CHECKLIST	Rick S
4-17-96	SENT ALARMS	Tim T.
TIME IN		
1250		
TIME OUT		
1315		

DATE	CHECKING O.F. INST AIR ALARM	BALL
4-23-96	TO SCADA	
TIME IN		
1440		
TIME OUT		
1455		

DATE	added CR'S TO PLC programed	Jackie/Loren
4-24-96		
TIME IN		
TIME OUT		

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	DOING INSTRUMENT PM'S	J BALL
4-25-96		
TIME IN	BACK AT 1240 TO FINISH PM'S	
0640	OUT AT 1323	
TIME OUT		
0710		
DATE	adjusting the program in the PLC	J Lewis
4/25/96	so WPTP will read the alarms	
TIME IN	correctly	
1030		
TIME OUT		
1100		
DATE	Ran Generator, Exercise Reg	[illegible]
5-2-96	Gate Sent Alarms, Area Check	Rock S
TIME IN	test, Gen Oil and Fuel Levels - OK	
1030	Gen New Hours → 809.1	
TIME OUT		
1055		
DATE		
TIME IN		
TIME OUT		

KCSlip4 63520

SEA431611

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	STATION CHECKLIST	Ricks.
5-7-96	SENT ALARMS	
TIME IN	SWEPT	
1400		
TIME OUT		
1415		

DATE	instation checklist - Send ALARMS	Blair/
5/14/96		Oviedos
TIME IN		
13:06		
TIME OUT		

DATE	INSPECT with Superior	Blair
5-15-96	Fire Extinguisher Co.	Neif
TIME IN		
11:25		
TIME OUT		

DATE	Aera checklist Sent Alarm	Lt.
6-4-96	test generator full/2 foll 4gal.	Ko.
TIME IN	Cleaning	
TIME OUT		

KCSlip4 63521

SEA431612

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checked Generator Battery	T. Elwell
6-7-96	+ Adjusted Charger	
TIME IN		
1240		
TIME OUT		
DATE	Camps Project	LESMAK/SAGEN
6-12		
TIME IN		
12:15		
TIME OUT		
DATE	Aera check list - sent Alarms	Lt.
6-13-96	Cleaned up out side weed eat	
TIME IN	and weed	
TIME OUT		
DATE	making a copy of the PLC	Jack Lewis
6/19/96	program	
TIME IN		
1520		
TIME OUT		

KCSlip4 63522

SEA431613

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	area check list Sent Alarm	V.O.
6-18-96		L.T.
TIME IN		
TIME OUT		

DATE	- CHECKLIST - SENT ALARMS	[illegible]
6-25-96	- CHECKED BATTERYS	
TIME IN		L.T.
1015		
TIME OUT		

DATE		
7/2/96	Checked and tested NPA, cleaned	[illegible]
TIME IN	batteries	
12:45		
TIME OUT		

DATE	area check list Sent Alarms	L Stanzer
7-3-96	test generators	
TIME IN		
TIME OUT		

KCSlip4 63523

SEA431614

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
7/8/96		
TIME IN	Inspection For CAMPS project	M. D'Ambrosio
620		
TIME OUT		
DATE	area check list, sent Alarms	Lt./RF
7-11-96		
TIME IN		
TIME OUT		
DATE	Station checklist, Send Alarms	L.T.
7-16-96	to W.P. Exercised seq. gate.	B.F.
TIME IN		
1235		
TIME OUT		
DATE	area check list sent Alarms	Lt
7-24-96		
TIME IN		
15:30		
TIME OUT		
15:50		

KCSlip4 63524

SEA431615

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
7-29	Serviced Gen - Load Tested	
TIME IN		Raymond
TIME OUT	& Added Fuel	
DATE	area Checklist Sent Alarms	BF
7-31-96	Check Stashion and out Fell	Lt.
TIME IN		
09:43		
TIME OUT		
DATE	Station Check list	
8-7-96	Sent Alarm	
TIME IN	Test Room Gen	
1425	Fuel level → 6 t gals	
TIME OUT	New Gen Hour - 810.4	
DATE		
8/13/96	Checked and washed emer. gen.	Kyrl
TIME IN		
8:25	battery.	
TIME OUT		
8:40		

KCSlip4 63525

SEA431616

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist, Send Alarms	T.T.
8-14-96	to W.P. Exercized req. gate	B.F.
TIME IN		
14:15		
TIME OUT		

DATE	Station checklist	T.T.
8-21-96	Send Alarms	
TIME IN	Exercise Reg Gate	
0950		
TIME OUT		
1000		

DATE	SOP's	LESNIAK
8-26		
TIME IN		
0130		
TIME OUT		

DATE	Station checklist Send Alarms	T.T.
8-27-96	to W.P. Weed eat Around	B.F.
TIME IN	station Pick up trash.	
0826		
TIME OUT		

KCSlip4 63526

SEA431617

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	PAINTER INTO PRESSURE WASH	Eglin
8-27-96	BLDG. PRESSURE WOW'T START.	
TIME IN		
14:00		
TIME OUT		

DATE	PAINTER INTO HIGH PRESSURE	Eglin
8/28/96	WASH BLDG EXT.	
TIME IN		
7:30		
TIME OUT		
11:00		

DATE		
8/29/96	PAINTER INTO SCRAP, SAND, PRIME	Eglin
TIME IN	EXT.	
7:45		
TIME OUT		
16:15		

DATE		
8/30/96	PAINTER TO WORK ON EXT. PAINT	Eglin
TIME IN		
07:15		
TIME OUT		

KCSlip4 63527

SEA431618

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
7/3/96	PAINTER IN TO FINISH PAINTING EXT.	Tyler
TIME IN	PAINTED EXT POST	
07:30		
TIME OUT		
10:30		

DATE		Tyler
7/4/96	PAINTER IN TO CLEAN, SAND, PRIME,	
TIME IN	& PAINT INT & EXT OF DOOR &	
7:30	PIPING & EQUIP. INSIDE OF BLDG	
TIME OUT		
11:30		

DATE	Area check list, Sent Alarms	T.T
7-5-96	Test new item	M.O
TIME IN	Exercised Reg Start	
0830		
TIME OUT		
0845		

DATE	Station check list · Sent alarms	Olivas
7/9/96		
TIME IN		
0945		
TIME OUT		

KCSlip4 63528

SEA431619

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check	T-7
9-10-96		
TIME IN		
1245		
TIME OUT		
1255		

DATE		
9/11/96	Check Sampler Controls	Paxton
TIME IN		
TIME OUT		

DATE	Station checklist. Scan alarms. Exercised	Olivera
9/10/96	gate.	
TIME IN		
0895		
TIME OUT		

DATE		
9-19	install lockout station	Green
TIME IN		
TIME OUT		

KCSlip4 63529

SEA431620

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area checklist, Sent Alarms, Exercised	7.7
9-24-96	Reg Gate, Yard work	14.0
TIME IN		
1255		
TIME OUT		
1315		
DATE	Station checklist Sent alarms	Olivero
9/30/96		
TIME IN		
0942		
TIME OUT		
DATE	CHECKING INST AIR ALARM OK	J BALL
10-1-96		
TIME IN		
1155		
TIME OUT		
1210		
DATE	station checklist. Sent alarms. Monthly	Olivero
10/7/96	generator test. Exercised regulator gate.	
TIME IN		
1425		
TIME OUT		

KCSlip4 63530

SEA431621

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
10/10/96	Check Sampler Control	Payton
TIME IN		
TIME OUT		

DATE	Station checklist. Sent alarms	Oliver
10/15/96	Exercised regulator gate.	
TIME IN		
1430		
TIME OUT		

DATE	Station checklist. Sent alarms.	Olivros
10/22/96	Cleaned station in & out side"	
TIME IN		
1415		
TIME OUT		

DATE	DOING REG AND O.F. INST PMS	J BALL
10-29-96		
TIME IN		
1000		
TIME OUT		
1100		

KCSlip4 63531

SEA431622

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms.	Chuck
10/29/96	Exercised regulator gate.	Salsbury
TIME IN		
1340		
TIME OUT		

DATE	- CHECKLIST - SENT ALARMS.	M.F.
11 6 96	- RAN GENERATOR - STARTING HARD	
TIME IN	- CHECKED FILTER - OK	R.S.
1000	- GENERAL CLEANING INSIDE.	
TIME OUT		

DATE	STATION SOP'S	Tom Ebel
11/6/96		
TIME IN		
1445		
TIME OUT		

DATE		
11/13/96	Checked and cleaned emer. gen.	Kyle
TIME IN		
10:35	battery.	
TIME OUT		

KCSlip4 63532

SEA431623

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	DOING INST PMS' ALL DONE	J BALL
11-12-96	3 WEEKS AGO	
TIME IN		
1045		
TIME OUT		
1120		

DATE	STATION CHECK	Rick S.
11-12-96	SENT ALARMS	
TIME IN		
1400		
TIME OUT		

DATE	Check Trunk and Int. Levels.	B.E.
11-15-96	Per W.P.	
TIME IN	Trunk - 105.8 Int - 99.3	
04:45	Reg gate 96.6 Purge Bubblers.	
TIME OUT		

DATE	STATION CHECK	Rick S.
11-21-96	SENT ALARMS	
TIME IN	1410 SENDING TEL	J BALL
1410	ALARMS 1430	
TIME OUT		

KCSlip4 63533

SEA431624

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Med-Tox NW bldg survey	Tori Choate
11/26/96		Bill Murray
TIME IN		
14:06		
TIME OUT		
14:35		

DATE	STATION CHECK	Rick S.
11-26-96	SENT ALARMS	
TIME IN	CLEANING	
1450		
TIME OUT		

DATE	- STATION CHECKLIST	[illegible]
12-3-96	- SENT ALARMS	
TIME IN	- RAN GENERATOR STARTED HARD	L.T.
1000	" CLEANING EQUIPMENT	
TIME OUT	- RESET TELEMETRY ALARM.	

DATE	area check list / sent Alarms	L.T.
12-12-96		
TIME IN		
TIME OUT		

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checking IAC for air cleaner	[illegible]
12/18	replacement	
TIME IN		
TIME OUT		
DATE	- CHECKLIST - SENT ALARMS	[illegible]
12-19-96		
TIME IN		L.T.
1000		
TIME OUT		
DATE	P[illegible]	[illegible]
1-3-97		
TIME IN		
0[illegible]		
TIME OUT		
DATE	area check list Sent Alarm	LT
1-3-97	test generator	
TIME IN		
1300		
TIME OUT		

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CHECKING IA SYSTEM	J BALL
1-7-97		
TIME IN		
0846		
TIME OUT		
0850		

DATE		
1/7/97	Load tested WPS.	[illegible]
TIME IN		
10:10		
TIME OUT		

DATE	Area Check, Station Checklist	7:7.
1-7-97	Sent Alarm's	
TIME IN		
1345		
TIME OUT		

DATE	Replaced damaged air filter on	LESNIAK
1-9-7	IAC #2	
TIME IN		
12:00		
TIME OUT		

KCSlip4 63536

SEA431627

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area check list	T.T
1-16-97	Station check.	J.T
TIME IN	Sent Alarms	
1030		
TIME OUT		
1045		

DATE	Station check list	T.T
1-23-97	Area Check	J.T
TIME IN	Sent Alarms	
0935		
TIME OUT		

DATE		
1/28/97	Checking Of Gate Controls	Paxton
TIME IN		
TIME OUT		

DATE	Station Checklist	T.T
1-30-97	Sent Alarms	J.T.
TIME IN	Area check	
1330	Generator will not start in	
TIME OUT	Hand or Auto. W/O.	
135		

KCSlip4 63537

SEA431628

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
1-30	TEST RUN GEN ON TEST	Raymond
TIME IN		
1430		
TIME OUT		

DATE	Here; TO check generator	Tom Elm[illegible]
1-31-97	Tested generator in AUTO	
TIME IN	2 TIMES STARTED OK, everything	
0720	work. OK - START'S in Hand	
TIME OUT	ok ?	
0745		

DATE	Station checklist. Sent alarms. Run	Oliveros
2/5/97	generator on simulated outage.	Tanzur
TIME IN		
1400		
TIME OUT		

DATE	Station checklist. exercised regulator gate	Oliveros
2/11/97	Sent alarms.	Tanzur
TIME IN		
1050		
TIME OUT		

KCSlip4 63538

SEA431629

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
2/13/96	Reprogramed PLC for	[illegible]
TIME IN	5min Delay when Taking	
	Samples per Mark Patton	
TIME OUT		

DATE	CHECKING TELEMETRY ALARMS	J. BALL
2-20-97		
TIME IN		
1210		
TIME OUT		
1218		

DATE	area check list Sent Alarms	L.T.
2-20-97		
TIME IN		
1200		
TIME OUT		

DATE	Checked and washed emer. gen.	[illegible]
2/25/97		
TIME IN	battery.	
10:55		
TIME OUT		

KCSlip4 63539

SEA431630

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist. Sent alarms	Olivier
2/20/97		Tanger
TIME IN		
1420		
TIME OUT		

DATE	Station checklist	CA
3/4/97	Sent alarms	
TIME IN		
1141		
TIME OUT		

DATE	area check list sent Alarms	
3-19-97	test Gen	
TIME IN		
08:45		
TIME OUT		
08:45		

DATE	Check station	CA
3/21/97		
TIME IN		
1242		
TIME OUT		

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	areacheck list Sent Alarm	LT
3-27-97	~~Sa~~ Clean Floor	
TIME IN		
1155		
TIME OUT		

DATE	Sent alarms	TT/CA
4/3/97	checklist	
TIME IN		
0820		
TIME OUT		

DATE	CHANGING P.L.C. BATTERIES	J BALL
4-3-97		
TIME IN		
1320		
TIME OUT		
1330		

DATE	Mech Pm	Barney
4-4-97		
TIME IN		
1308		
TIME OUT		
1315		

KCSlip4 63541

SEA431632

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist	T.T.
4-11-97	Area check	
TIME IN	Sent Alarms	
1055		
TIME OUT		
1125	1350 - In w/ Superior Fire	ES

DATE	CHECKING RELIEF VALVE FOR AIR TANK	PAULA
4-15-97		
TIME IN	SEAT BADLY WORN WILL ORDER NEW VALVE	
0815		
TIME OUT		

DATE	Station check	T.T.
4-16-97	Sent Alarms	C.A.
TIME IN	Area checklist	
1345	Test Pen Ign.	
TIME OUT	Fuel level 1/2 Full	
1410	New Ign Flow → 812.3	
	Exercise Reg Gate	

DATE	Inspected Manhole w Reg Gate	LESNIAK
4/17	Operator	
TIME IN		
12:30		
TIME OUT		

KCSlip4 63542

SEA431633

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
7/17/97		
TIME IN	adjusted the regulator gate	
1515	transmitter.	Jacki Lewis
TIME OUT		
1525		

DATE	Station check list	7-7
3-24-97	Sent Alarm's	E.A
TIME IN		
1215		
TIME OUT		
1230		

DATE	Check outfall Gate	Blair
4/27/97	Purge Bubble for TRUNK	
TIME IN	Put maint. Switch ON	
12:49		
TIME OUT	12:49 outfale Gate closed	
	Going over AT WEIR	
	Check limit switch/Seems	
	ok-cleaned it AJUSTED TRUNK	
	Bubbler to 0.8 WAS A LITTLE	
	ABOVE, that Brought Level Down 106.6	TO 106.5-Set Point

DATE		
5/1/97	Check Sample Control	[illegible]
TIME IN		
TIME OUT		

KCSlip4 63543

SEA431634

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check list	7-7
5-8-97	Sent Alarms.	
TIME IN	Test Ran Gen.	
1145	Fuel level at 4 1/2 gals	
TIME OUT	Area check.	
1235	New Gen Hour's → 812.7	
DATE	Station checklist	[illegible]
5-8-97	Station Check	
TIME IN	Sent Alarms	
0915		
TIME OUT		
0930		
DATE	Area Checklist	7-7
5-23-97	Sent Alarms	
TIME IN	Station check	
0830		
TIME OUT		
0845		
DATE		[illegible]
5/27/97	Sent alarms to WPTP	
TIME IN		
1030		
TIME OUT		
1045		
6/4/97	Station checklist. Sent alarms.	Owens
0850	Exercised regulator gate. Yard work	Tramble
6/9	Campo Project	LESNOAK WAGEMAN

KCSlip4 63544

SEA431635

Brandon Regulator

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms.	O Irvine
6/11/97	Ran generator on simulated outage.	
TIME IN		
1040		
TIME OUT		

DATE		
6/16/97	Checked and washed emer. gen.	Wyal
TIME IN	battery.	
13:10		
TIME OUT		

DATE	REPLACING RELIEF VALVE ON AIR	PAULA
6/19/97	RECIEVER	
TIME IN		
0650		
TIME OUT		

DATE	Station check	T.T
6-19-97	Sent Alarming	M.C
TIME IN	Area checked	
1040		
TIME OUT		

KCSlip4 63545

SEA431636

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check list	M.O
6-21-97	Sent Alarms	T.T
TIME IN	Area Check	
07:50		
TIME OUT		
0800		

DATE	Area check list	T.T
7-1-97	Station Check	M.O
TIME IN	Sent Alarms	
1240		
TIME OUT		
1255		

DATE	Checked station	Office
7/10/97		
TIME IN		
2010		
TIME OUT		

DATE	Station Checklist	T.T.
7-11-97	Sent Alarms	
TIME IN		
0935		
TIME OUT		
0945		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area checklist, Sent Alarm's	T-7
7-17-97	Station Chk.	
TIME IN		
1050		
TIME OUT		
1105		

DATE	Had To Check Exhaust	Tom Elwell
7-18-97	Fan Motor is Bad	
TIME IN	Had To Remove The	
0700	Whole unit. ITS All Rusted	
TIME OUT		
0800		

DATE	Checked Station	[illegible]
7-21-97		
TIME IN		
1010		
TIME OUT		
1020		

DATE	Station Checklist	T-7
7-23-97	Sent Alarm's	
TIME IN		
0755		
TIME OUT		
0805		

KCSlip4 63547

SEA431638

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
7/23/97	Checked, cleared and load	
TIME IN		Kynt
13:30	tested UPS.	
TIME OUT		
DATE	Station checklist. Sent alarms.	Oliveros
7/30/97	Exercised regulator gates.	
TIME IN		
0756		
TIME OUT		
8-1-97	Yard work Reg. and Out Fall	Lt.
DATE	INSTATION	Blair
7/6/97	CHECKLIST	
TIME IN	Send ALARM	
09:00		
TIME OUT		
DATE	station checklist. sent alarms	Oliveros
8/11/97	Exercised regulator gate. Run generator	
TIME IN	on simulated outage.	
0700		
TIME OUT		

KCSlip4 63548

SEA431639

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checking Station for High Room Temp	LESNIAK
	reported.	
TIME IN		
	Ex. Fan is not wired in	
TIME OUT		
DATE		
8-12-97	Here to install New	
TIME IN	[illegible]	
0730		
TIME OUT		
DATE		
8/13/97	Checked and washed emer. gen.	Kyal
TIME IN		
11:05	battery.	
TIME OUT		
DATE	station checklist. Sent alarms	Owens
8/19/97		
TIME IN		
1346		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms	Oliveros
8/27/97	Exercised regulator gate. Cleaned	
TIME IN	station.	
1300		
TIME OUT		

DATE	Station checklist - Sent alarms	Oliveros
9/8/97		
TIME IN		
TIME OUT		

DATE		
9/15/97	Checked the air compressors and	Jacinto Ferrer
TIME IN	Send an inst air alarm.	
1140		
TIME OUT		
1150		

DATE	Station checklist. Sent alarms.	Oliveros
9/17/97	Ran generator on simulated outage.	
TIME IN		
1325		
TIME OUT		

KCSlip4 63550

SEA431641

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Send alarms	Olivier
9/23/09		
TIME IN		
08 40		
TIME OUT		

DATE	Station Checklist. Send alarms	Olivier
10/2/09	Exercised mightator gate.	
TIME IN		
1345		
TIME OUT		

DATE	Station Checklist Send alarms	Olivier
10/6/09		
TIME IN		
1320		
TIME OUT		

DATE	Station checklist. Send alarms	Olivier
10/14/09	Ran generator on simulated outage	
TIME IN		
1320		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
11/3/97	Performed an instrument Pm	Jacob Lewis
TIME IN		
0830		
TIME OUT		
0915		

DATE	Station Checklist	7-7
11-5-97	Sent Alarms	
TIME IN	Area Check.	
0915	Exercise Rog Water	
TIME OUT		
0930		

DATE	Station checklist. Sent alarms	
11/10/97		
TIME IN		Olivos
1300		
TIME OUT		

DATE	Area check	7-7
11-20-97	Sent Alarm's	M.G
TIME IN	5 Station Checklist	D.Y
1110		
TIME OUT		
1120		

KCSlip4 63552

SEA431643

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist Sent Alarm's	T-T
11-25-97	Area Check	M.O
TIME IN	Test Ran Gen	D.Y
0935	Gen New Hour's → 813.6	
TIME OUT		
0955		

DATE	Checked Engine Battery	T. Elwell
12/2/97	& Charger	
TIME IN		
1450		
TIME OUT		

DATE	Station Checklist	T-T
12-3-97	Sent Alarm's	M.O
TIME IN		
1120		
TIME OUT		
1130		

DATE	PM STATION	Tom Elwell
12/7/97		
TIME IN		
1020		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	station - checklist. sept alarms	Olivia
12/10/97	Exercised regulator gate.	
TIME IN		
TIME OUT		
DATE		
12/15/97	Checked and tested UPS.	Kyle
TIME IN		
7:05		
TIME OUT		
DATE	State check	7:7
12.16.97	Took like Trunk is [redacted] change	M.O
TIME IN	Full 108.1	
0700	Interceptor level at 99.6	
TIME OUT	Outfall Gate open	
0710		
	Purge Bubblers	
	Check Bubbler & Trunk Level	Paxton
	Controls	
DATE	Asset's	Sgt
12/16		Wagner
TIME IN		
1300		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check	T-T
12-18-97	Sent Alarm's	M.O
TIME IN	Area checklist	
0925		
TIME OUT		
0940		
DATE	Area checklist	T-T.
12-23-97	Sent Alarm's.	
TIME IN		
1000		
TIME OUT		
1015		
DATE	Station checklist. Sent Alarms	T-T
12-31-97	Area check	
TIME IN	Test Run Generator	
1120	Gen Niew Hours → 814.0	
TIME OUT	Fuel level → Full	
1145		
DATE	Area check. Sent Alarms	T-T.
1-7-98	Station checklist	
TIME IN	Exercised Reg Valve	
1120		
TIME OUT		
1135		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms. Exercised	Oliveros
1/15/98	regulator gate.	Yarno
TIME IN		
0900		
TIME OUT		

DATE	Station checklist. Sent alarms	Oliveros
1/21/98		
TIME IN		
1205		
TIME OUT		

DATE	At station with Jeff Coles looking at the	Fischer
1-23-98	generator	
TIME IN		
0815		
TIME OUT		
0930		

DATE	Station checklist. Sent alarms.	Oliveros
1/28/98	Cleaned station	
TIME IN		
1335		
TIME OUT		

KCSlip4 63556

SEA431647

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
2/3/98	Checked and cleaned emer. gen.	Hyd
TIME IN		
10:25	battery, adjusted charger.	
TIME OUT		

DATE	Station check list	D YAKINO
2/3/98	Send alarms	
TIME IN		
1100		
TIME OUT		

DATE	Station check list	D YAKINO
3/10/98	Send alarms	
TIME IN	Run Gen	
1130		
TIME OUT		

DATE	weekend station check - outfall too!	[illegible]
2-15-98		
TIME IN		
0810		
TIME OUT		

KCSlip4 63557

SEA431648

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	DY
2/19/98	Sent alarms	CD
TIME IN		
1130		
TIME OUT		
DATE		
2/23/98	Tested WPA.	Kyrl
TIME IN		
11:20		
TIME OUT		
DATE	Station checklist, Sent Alarm's	T-T
2-25-98	Area check.	
TIME IN		
1440		
TIME OUT		
1455		
DATE	Area checklist, Sent Alarm's	T-T
3-6-98	Station check.	
TIME IN		
0720		
TIME OUT		
0735		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
3/11/98	Sent alarms	Jack Lewis
TIME IN		
1515		
TIME OUT		
1530		

DATE	Station Checklist	Tim T
3-12-98	Sent Alarm's	
TIME IN	Area Chk. Exercised Reg Gate	
0815	Test Ran Gen. Fuel level - Full	
TIME OUT	New Gen Hour's → 814.4	
0835		

DATE	Station Checklist	CD
3/17/98	Sent alarm	TT
TIME IN		
0800		
TIME OUT		

DATE		
13/11/98	Checked and cleaned emer. gen. battery.	Kyrel
TIME IN		
10:10		
TIME OUT		

KCSlip4 63559

SEA431650

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist, Sent Alarms	Tim T
3-26-98	Area check.	
TIME IN		
0705		
TIME OUT		
0730		
	Regulator for Instrument Air	
	Pressure is Leaking Air	
	"Will call Bill"	-

DATE	Station with insurance	D. YARND
3-31-98	adjuster	
TIME IN		
TIME OUT		

DATE	Station Checklist, Sent Alarm	T-T
4-2-98	Area check	
TIME IN	Exercise Pay State	
0705		
TIME OUT		
0720		

DATE	Test Pump Generator	T-T
4-3-98	Fuel level → Full	
TIME IN	New Man Hour → 8141.6	
0700		
TIME OUT		
0718		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	T-T
4-8-98	Sent Alarms	C. D
TIME IN	Area Check	
1025		
TIME OUT		
1040		

DATE	IN STATION WORKING ON IAC	Barney
4-9-98	Replacement #1 - 5817	
TIME IN	#2 - 5042	
0905		
TIME OUT	#1 - Needs Wiring modification	

DATE		
4/15/98	Checked and tested UPS.	Kyle
TIME IN		
12:10	Connected motor for IAC #1 and	
TIME OUT		
	put on Lead.	

DATE		
4/15/98	Replaced PRV & Filter on	Rafter
TIME IN	Inst Air	
TIME OUT		

KCSlip4 63561

SEA431652

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	T=T
4-16-98	Sent Alarm	
TIME IN	Area Check.	
0650		
TIME OUT		
0705		
DATE		
4/16/98	Performed an inst. PM	Jack Lewis
TIME IN		
1215		
TIME OUT		
1315		
DATE	Area Checklist	T=T
4-23-98	Sent Alarms	
TIME IN	Station Check.	
1000		
TIME OUT		
1015		
DATE	Checked ENGINE Battery	Tom Klein
4/23/98	Adjusted Charger	
TIME IN		
1250		
TIME OUT		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		T=T
4-30-98	Station Checklist	
TIME IN	Sent Alarm's	
0925	Area Check	
TIME OUT		
0940		
DATE	Power Line Down Feeding	T=T
5-5-98	Station	
TIME IN	Station will be without Power	
1100	for about 2½-3 Hour's. So	
TIME OUT	Say City Light	
1320		
	Test Run Generator, Fuel level	
	5 gals +	
DATE	Station Checklist, Sent Alarm's	T=T
5-7-98	Area check	
TIME IN	Exercised Ray Hate.	
0710		
TIME OUT		
0735		
DATE		
5/7/98	Replaced the PLC batteries	Jack Sewis
TIME IN		
1320		
TIME OUT		
1330		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist	T-T
5-14-98	Sent Alarm's	
TIME IN	Area check	
0930		
TIME OUT		
0950		
DATE	Station check, Sent Alarm's	T-T
5-21-98	Area checklist	
TIME IN		
1100		
TIME OUT		
1140		
DATE	Station Checklist	T-T
5-28-98	Sent Alarm's	
TIME IN	Area check	
0940		
TIME OUT		
DATE	Area checklist, Sent Alarm's	T-T
6-4-98	Station Check.	
TIME IN		
0725		
TIME OUT		
0750		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist, Sent Alarm's	Tim T
6-10-98	Area Check	
TIME IN	Test Run Generator	
1100	Fuel level → 5 gals	
TIME OUT	New Gen Hours → 816.2	
1145		
DATE	IN STATION TO CHECK GEN	GREENE
6/18/98	SET	
TIME IN		
0830		
TIME OUT		
DATE		
6/18/98	Load tested UPS.	Kyed
TIME IN		
12:50		
TIME OUT		
DATE	Station Checklist	Tim T
6-19-98	Sent Alarm's	
TIME IN	Area Check.	
0725	Outside Lamping.	
TIME OUT		
0740		

KCSlip4 63565

SEA431656

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check list	O. YARKO
6-24-98	Send alarms	
TIME IN		
1100		
TIME OUT		

DATE	P.M. STATION	Tom Elwell
6-25-98		
TIME IN		
0845		
TIME OUT		

DATE	Survey needs to Replumb	Barney
6-25-98	IAC Comps and PRESSURE	
TIME IN	S/W	
0855		
TIME OUT		

DATE	Station checklist	T & T
07-1-98	Sent alarms	
TIME IN	Area check	
0730		
TIME OUT		
0745		

KCSlip4 63566

SEA431657

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist, Sent Alarms	T-T
7-7-98	Area Check, Test Pan Generator	
TIME IN	Fuel level at 5 gals	
0745	New Gen Hours → 816.5	
TIME OUT		

DATE	Station Checklist, Sent	T-T
7-21-98	Alarms	
TIME IN	Area Check.	
0710		
TIME OUT		
0730		

DATE	Checking needs for IAC	Barry
7-22-98	plumbing modification	
TIME IN		
1300		
TIME OUT		

DATE	Modifying IAC plumbing	Barry
7-23-98	to pressure S/W	
TIME IN	Plan change - require different	
1000	fittings	
TIME OUT		

KCSlip4 63567

SEA431658

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		Berry
7-24-98	Working on IAC System	
TIME IN	isolating Pressure/Alarm S/W	
1040	from Compressors	
TIME OUT		

DATE	Station checked	Tim
7-30-98	Sent Alarms	
TIME IN	Area clean	
0710	Need Yard Work	
TIME OUT		
0725		

DATE		
8/4/98	Sent alarms.	Jackie Lewis
TIME IN		
1250	The fan (ceiling) was banging	
TIME OUT	against something. I turned off	
1300	breaker #3. - Will notify B.S.	

DATE		
~~8-4-98~~	8-4-98	
TIME IN	Replace cores @ station	Williamson
3:40		Goucher
TIME OUT		
3:45		

KCSlip4 63568

SEA431659

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	Tim T
8-05-98	Sent Alarm's	
TIME IN	Area Check.	
0910		
TIME OUT		
0930		
		-

DATE	LOAD TESTING GENERATOR	GREENE
8/5/98		
TIME IN		
0935		
TIME OUT		
1040		

DATE	Station Checklist, Sent Alarms	Tim T
8-14-98	Area Check	
TIME IN		
0650		
TIME OUT		
0705		

DATE	~~Stay~~ in Station to purge	D. YARNO
8-16-98	Bubblers per W.P.	
TIME IN		
2300		
TIME OUT		

KCSlip4 63569

SEA431660

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
8-17	Removed exhaust fan to	Green
TIME IN	replace bearings	
630		
TIME OUT		
DATE		
8/19/98	Purdge Trunk Bubbler	Pugh
TIME IN		
TIME OUT		
DATE		
8/24/98	Checked and cleaned emer. gen. battery.	Hyal
TIME IN		
14:20		
TIME OUT		
DATE	Station Checklist	T=T
8-27-98	Sort Alarms	
TIME IN	Area Chk.	
0705		
TIME OUT		
0725		

KCSlip4 63570

SEA431661

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
8/28	Check Bubbler	[illegible]
TIME IN		
TIME OUT		
07:30		

DATE		
8/31/98	Watered emer. gen. battery.	[illegible]
TIME IN		
7:55		
TIME OUT		

DATE	Station Checklist	Tim T
9-2-98	Sent Alarms	
TIME IN	Area Check	
0710		
TIME OUT		
0745		

DATE	Tim Station with Supervisor	Tim T
9-3-98	Time	
TIME IN		
TIME OUT		

KCSlip4 63571

SEA431662

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	Tim T
9-10-98	Sent Alarm's	
TIME IN	Area Check	
0710		
TIME OUT		
0725		
DATE	Station Checklist	Tim T
9-18-98	Area Check.	
TIME IN		
0730		
TIME OUT		
0755		
DATE	Station Checklist	Tim T
9-25-98	Sent Alarm's	
TIME IN	Area Check	
0725		
TIME OUT		
0740		
DATE	Station Checklist, Sent	Tim T
9-29-98	Alarm's, Area Check.	
TIME IN	Outside Lamping.	
0730		
TIME OUT		
0745		

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
10-8-98	installed exhaust fan.	
TIME IN	it is somewhat noisy	Gruen
	but hopefully better than	
TIME OUT	nothing	

DATE	Station Checklist, Sent Alarms	TiT
10-9-98	Area check.	
TIME IN		
0715		
TIME OUT		
0735		

DATE		
10/13/98	Relocated the instrument air tank	jachilers
TIME IN	pressure gauge.	
1100		
TIME OUT		
1145		

DATE	Station Checklist, Sent Alarms	TiT
10-15-98	Area check. Test/Run Generator	
TIME IN	Fuel level at ½ Full	
0750	New Gen Hours → 818.0	
TIME OUT		
0840		

KCSlip4 63573

SEA431664

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	TET
10-23-98	Area Check	
TIME IN		
0815		
TIME OUT		
0835		

DATE		
10/27/98	Checked UPS, adjusted charger.	Kyal
TIME IN		
12:30		
TIME OUT		

DATE	Station Checklist, sent	TET
10-29-98	Alarms, Area Check	
TIME IN	Purge Bubblers	
0710		
TIME OUT		
0725		

DATE		
11/4/98	Sent alarms.	[illegible]
TIME IN		
1330		
TIME OUT		
1345		

KCSlip4 63574

SEA431665

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Assert check	[illegible]
11/4		[illegible]
TIME IN		
1330		
TIME OUT		
		-
DATE	Station checklist	T.T
11-5-98	Sent Alarm's	
TIME IN	Area Check.	S.L
1030	Purge Bubbler	
TIME OUT		
1045		
DATE	Area checklist Sent Alarm's	T.T
11-19-98	Station check; Purge	
TIME IN	Bubbler's	
0718		
TIME OUT	W/O UPS Low Battery	
0750	Volt's Alarm's	
DATE	In Station with Elcon Engineer	LESNIAK
		Burnett
TIME IN		Goldberg
TIME OUT		

KCSlip4 63575

SEA431666

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	~~Assets~~	~~[illegible]~~
11/4/98		~~[illegible]~~
TIME IN		
TIME OUT		
DATE	CALLED TO STATION BY W.P.	RS
11-26-98	HEAVY RAIN	
TIME IN	INT. - 101.0	
0120	REG GATE - 0%	
TIME OUT	TRUNK 107.3	
	PURGED BUBBLERS INT. ↓ 100.2	
DATE		
11/30/98	Checked and cleaned emer. gen.	Kyul
TIME IN		
12:50	battery.	
TIME OUT		
DATE	Station Checklist, Sent Alarm's	Tim T
12-3-98	Test Ran Generator, Fuel level 1/2	
TIME IN	New Gen Hour's → 818.5	
0725	Purge Bubbler's, Area Check.	
TIME OUT		
0800		

KCSlip4 63576

SEA431667

Brandon Street Outfall

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
12/3/98	Checked UPS, batteries are dead.	[illegible]
TIME IN		
10:25	Will replace.	
TIME OUT		
	Installed new batteries.	
DATE	checking outfall gate	
12/7/98	found sensor & light loose	
TIME IN	tide together so WP ~~doesn't~~	
1700	~~don~~ won't get alarm on	
TIME OUT	outfall gate	
DATE	Station checklist Sent	Tim T
12-9-98	Alarms Purge Bubbler's	
TIME IN	Area check	
0725		
TIME OUT		
0755		
DATE	Called out on Gate error	B.F.
12.11.98	Int. Level = 100.2 / ~~[illegible]~~	
TIME IN	Trunk level = 106.4 Reg. gate wants	
1755	to open but keeps kicking out.	
TIME OUT	From the way it acts. Its normal.)	
	Will ask West Point to keep eye	
	on it. Will notify M. Dawson.	

12-13-98 Called-out Gate Gate not Ready Alarm.
1025 Reg Gate (Sluice Gate) Kick-out - Reset - Reset Button.

KCSlip4 63577

SEA431668

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
12/14/98	Checked Rg. gate. Resets overload and	Kyal
TIME IN	test ran. Motor draws twice the	
6:40	normal current, also grounded	
TIME OUT		

DATE	In station to asst with Reg. gate	D. YARNO
12/14		
TIME IN		
0645		
TIME OUT		

DATE		
12/15/98	Disconnected all wires to gate operator	Elwell
TIME IN		Kyal
6:50		LESNIAK
TIME OUT	Removed Limitorque Operator for	GREEN
	rebuild.	NORMAN
		ELDRIDGE

DATE	Station Checklist	T-T
12-17-98	Sent Alarms, Area Check.	
TIME IN	Purge Bubblers	
0715		
TIME OUT		
0745		

KCSlip4 63578

SEA431669

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist Sent	Tim T
12-22-98	Alarm's, Area Check.	
TIME IN	Purge Bubbler's	
0915		
TIME OUT	Reg Gate - OOS	
0935		

DATE		
12/24/98	Connected repaired Limit Forge.	Kyml
TIME IN		
7:10	Adjusted limit switches and tested.	Elwell
TIME OUT		
	Gate is back in service.	

DATE	Station Checklist	Tim T
12-31-98	Sent Alarm's	
TIME IN	Area Check	
0745	Purge Bubbler's	
TIME OUT		
0810		
	New 1999 Log Book in Station	

DATE		
TIME IN		
TIME OUT		

KCSlip4 63579

SEA431670

E. MARGWR

KCSlip4 63580

SEA431671

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAME
DATE	1-2-96	Durbin
TIME IN	1445	
TIME OUT	1538	
	Station ✓list	
	Sent alarms	
	Exercised Pumps - switched leads 1-2	

DATE	1-2-96	NIEMAN
TIME IN	1500	
TIME OUT	1530	
	IN STATION TO TEST RP	
	DEVICE	

DATE	1-3-96	NIEMAN
TIME IN		
1100		
TIME OUT		
1315	IN STATION TO WORK ON	
	BACK FLOW PREVENTER	

DATE	CHECKING WIRING FOR NEW	J BALL
1-4-96	RECORDER	
TIME IN		
1455		
TIME OUT		
1525		

7-18-96 10:30
area walk thru L.t.
adusted # 2 pump
cleaned mess and pump

7/19/96 1326 In 1332 out T Coffey
removed sampling equipment

1/23/96 Cleaned and watered station batteries. Kyul

7/23/96 Station checklist, Send Alarms to W.P. adjust packing on #2

KCSlip4 63582

SEA431673

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station ✓	C Hansen
1-5-96	Recharge Hydro tank	
TIME IN	C-2 Break tank float is sticking causing	
1255	overfill + wasted H_2O.	
TIME OUT	#2 RSP @ 365 RPM WW 95.2	

DATE	WORKING ON VALVE TO BREAK TANK	J BALL
1-8-96	COULDN'T GET MAIN BODY APART WILL	
TIME IN	HAVE TO GET LARGER WRENCH	
1000	1200 - STILL COULDN'T REMOVE VALVE WILL	
TIME OUT	PUNT AND TRY AGAIN WHEN WE CAN	
1100	MONITOR LEVEL	
	1245	

DATE	Station ✓ list	Durbin
1-8-96	Sent alarms	
TIME IN	Hosed pump rm	
1450		
TIME OUT		
1530		

DATE	In station to check out inf gate	Eleanor
1-9-96	Mark chained open gate	Charlotte
TIME IN		Jean
0710		Mark
TIME OUT		
0830		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IN STATION TO INCREASE AIR GAP	PAULA
1-9-96	INTO C-2 BREAK TANK.	
TIME IN		
930		
TIME OUT		
1		

DATE	On station for H_2O shut off for meter	Hansen
1-9-96	replacement.	Larkin
TIME IN		
1240		
TIME OUT		
1520		

DATE	IN STATION TO PERFORM A ROUTINE	JACKI LEWIS
1-11-96	INSTRUMENT P.M.	
TIME IN		
1030		
TIME OUT		
1130		

DATE	Calibrated the manhole transmitter	Jack Lewis
1-12-96		
TIME IN		
0700		
TIME OUT		
0730		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station walk thru ✓	C Hansen
1-12-96	Recharge hydro tank.	
TIME IN		
1315		
TIME OUT		
1345		

DATE	Station ✓list	Durbin
1-16-96	Send alarms	Hansen
TIME IN	Pick up outside trash	
1340	Called to fuel spill by WP.	
TIME OUT		
1400		

DATE	Station ✓	C Hansen
1-19-96	Larry P. Changed chart.	
TIME IN	#2 RSP @ 370 RPM + # 3 RSP @ 370 RPM	
	WW 95.8	
TIME OUT	Hosed pump room	
	Stock rags - MT trash	
	Change air filters.	

DATE	Station ✓list	Durbin
1-22-96	Sent alarms	
TIME IN	Hosed parking drains - Hosed + pumped	
1047	down sump	
TIME OUT	Put soap in P.R.	

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Replaced Air Unit Filters	Durbin
1-23-96		Hansen
TIME IN		
1329		
TIME OUT		

DATE	Station ✓	Hansen
1-25-96	Clean up outside debris	Durbin
TIME IN	Hose pump room & flush RSP drains	
0940		
TIME OUT		

DATE	Station ✓	C Hansen
1-26-96	Adj. Pkg #2 RSP	
TIME IN	#2 RSP @ 380 RPM 130 amps. uw 95.4	
11:15		
TIME OUT		

DATE	Station ✓ list	Hansen
1-30-96	Send alarms	Durbin
TIME IN		
1330		
TIME OUT		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IN STATION TO LUBER RSP'S	PAULA
1-30-96		
TIME IN		
1450		
TIME OUT		

DATE	IN STATION TO WORK ON AHU	PAULA
1-31-96	UNIT NEEDS NEW SHEAVES WILL ORDER	
TIME IN		
0900	STARTED UNIT HEATER	
TIME OUT		
1530		

DATE	Calibrated the explosive gas	J Ball,
2-8-96 ~~0945~~	monitor.	J Lewis
TIME IN		
0945		
TIME OUT		
1005		

DATE	STATION ✓	C Hansen
2-2-96	#2 RSP @ 370 RPM WW 95.2	
TIME IN		
11:15		
TIME OUT		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check List. Send Alarms	Fauchald
2.5.96	to W.S. - C-2 Hydro tank site	
TIME IN	tube not showing tank level	
13:35	will report -	
TIME OUT		
14:05		
DATE		
2/6/96	Working on C2 Water	
TIME IN	cleaned valves on	
	Site Glass Checks ok	Paulter
TIME OUT		
DATE		
2-7	Working on C-2 Break Tank Valve	LESNIAK
TIME IN	need another part to completely	
1100	repair valve.	
TIME OUT		
3:25		
DATE	IN STATION TO CHECK. NOISEY AHU	PAULA
2-8-96	MOTOR END BEAR LOOSE. TIGHTENED	
TIME IN		
0840	REPLACED SHEAVES AND BELT.	
TIME OUT		

KCSlip4 63588

SEA431679

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CHECKING #2 + 3 R.S.P	STEVE
2-9-96		
TIME IN	#2 INSTRUMENT AIR COMP	
1200	SOUND BAD	
TIME OUT		

DATE	IN STATION TO LOOK AT	PAULA
2-9-96	#2 IAC. CLEANED PISTON RUNNING	
TIME IN	A LITTLE QUIETER, WORKING GOOD	
1400	BUT STILL SOUNDS BAD	
TIME OUT		

DATE	STATION CHECKLIST	Rick S.
2-12-96	SENT ALARMS	
TIME IN		
0900		
TIME OUT		
0945		

DATE	area check list Bleed of air on	L Tanner
2-16-96	Hy Dro. tank trned of air Valve	
TIME IN	Seem to Be ok.	
13:45		
TIME OUT		

KCSlip4 63589

SEA431680

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check List, exercized	Fauchald
2-20-96	R.S.P.S Send Alarms to W.P.	
TIME IN		
15:05		
TIME OUT		
15:40		

DATE	Station check List, Send Alarms	Fauchald
2-26-96	to W.P., Exercized RSPS	
TIME IN		
13:20		
TIME OUT		

DATE		
2-26	Install C-2 Float Valve	LESNIAK
TIME IN	Pressure to valve needs to	
1:00	be reset to eliminate	
TIME OUT	leak thru - 80 PSI MAX	
3:00		

DATE	Adjust pressure relief valve	medosch
2-27-96	on C-1 line to 80 PSI.	
TIME IN		
0825		
TIME OUT		

KCSlip4 63590

SEA431681

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	area checklist test pumps	Lota
3-1-96	Rest Gas Detector	
TIME IN	~~exercized~~	
8:40	adjusted Float on Brock tank Leek	
TIME OUT	out out side drain	
DATE	Area checklist	Trambe
3-5-96	Sent Alarms, adjusted #2 RSP	Fauchald
TIME IN	packing and flushed drain, clean	
1300	up the mess. Added Air to	
TIME OUT	C-2 hydro tank. Exercized All	
	RSPS, and inf. gate.	
DATE	Put up 1996 Vessel permitt	Fischer
3-7-96		
TIME IN		
1220		
TIME OUT		
1245		
DATE	Area checklist	[illegible]
3-8-96		
TIME IN		
1400		
TIME OUT		
1430		

KCSlip4 63591

SEA431682

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist, Send alarms	Fauchald
3.11.96	to WP. - Float valve to C-2	
TIME IN	break tank leaks. Tried to	
12:00	adjust it but did not work.	
TIME OUT	Exercized RSPs Adjust packing	
	on #2 RSP and flushed 1-2-3	
	drains!	
DATE	In station working on wet	Medosch
3-12-96	well crane.	
TIME IN		
1220		
TIME OUT		
DATE		
3/13/96	Check telemetery & pump	Paxton
TIME IN	controls	
TIME OUT		
~~3/13/96~~		
14:05		
DATE	Repair leak at C-2 Valve	LESNIAK
3/14		
TIME IN		
1:55		
TIME OUT		
2:45		

KCSlip4 63592

SEA431683

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area Checklist	Trombla
3-15-96	Test Influent Gate	
TIME IN	[illegible]	
1115		
TIME OUT		
1150		
DATE	Checked Station, Send Alarms to	T.T.
3-20-96 [illegible]	W.P. Exercized RSPs, recharged	B.F.
TIME IN	C-2 hydro tank, test inf. gate	
12:50	Empty trash.	
TIME OUT		
DATE	Area Checklist	T.T.
3-22-96		
TIME IN		
1225		
TIME OUT		
1240		
DATE	TRAINING	KRUSE
3-23-96		SUVEG
TIME IN		BRUER
0900		WOLVINGTON
TIME OUT		

KCSlip4 63593

SEA431684

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Check Station, Send Alarms to W.P.	T.T.
3-26-96	Change out S.F. Filters,	B.F.
TIME IN	exercised RSP. Pump down and	
14:00	hosed wet. Strange noise comming	
TIME OUT	from #2 RSP motor. Sounds like	
	it's the clutch. Will report. Switch	
	Leads to 3-1-2.	

DATE	Checking C.2 & Fan for reported noise	LESNIAK
3/26		
TIME IN		
2:00		
TIME OUT		
2:20		

DATE		
3/27/96	Checked, watered and washed	Tayul
TIME IN		
8:40	station battery. Adjusted charger	
TIME OUT		
	and set on equalizing charg.	
10:00		
	Switched pump leads 1-3-2.	
	Pump #3 was cycling.	

DATE		LESNIAK
3-29	Checked #2 RSP Noises & trash &	
TIME IN	rock in volute noise & telescope	
2:50	up drive line at times. Motor &	
TIME OUT	Clutch check O.K.	
3:20		

KCSlip4 63594

SEA431685

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	AT station to gate off #2 RSP	T.T.
3-28-96	for Maint Mech. TO check inside	B.E.
TIME IN	of the pump. ALSO put #3 RSP in	
07:00	Lead to see if it cycles. and it	
TIME OUT	did. will notify Inst Tech. Put #1 RSP	
	on Lead. It's ok. / Cleaning station.	

DATE		
2-28	Opened inspection cover	
TIME IN	on #2, ran unit	Mark
	to clean rags around rings	
TIME OUT	The pump did seem to	Paula
	work down much easier	
	when we shut it down	

DATE	In Station to do COMPS project	LESNIAK SAGEN
3-28		
TIME IN	Reprogram Control loops	Taylor
10:00	#1 & 2 for low Flow	
TIME OUT		

DATE	Checked Station, Change w/w	
4-1-96	chart, Adjusted #2 RSP packing	
TIME IN	And flushed drain, hosed pump	
13:15	room, and cleaned grease off	
TIME OUT	pump and floor. I need to	
	get solvent. Recharged C-2	
	hydro tank Exercized RSPS	

KCSlip4 63595

SEA431686

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IN STATION TO CHECK AHL	PAULA
4-5-96	INSTALLED NEW MOTOR BEARING BUT SHAFT	
TIME IN	WORN WILL ORDER PARTS	
0630		
TIME OUT		
1230		

DATE	Sent Checklist	[illegible]
4-5-96	Sent Alarms	
TIME IN		
1015		
TIME OUT		
1035		

DATE	CHECKING PUMPS	STEVE
5 Apr 96		
TIME IN		
1200		
TIME OUT		
1415		

DATE	STATION CHECKLIST	Rick S
4-8-96	SENT ALARMS	
TIME IN	SWITCHED LEADS → 3, 1, 2 RSP	
1120	(#1 + 2 RSP'S HAVE MOTOR NOISE) BEARINGS/TACH	
TIME OUT	WILL REPORT	
1205		

KCSlip4 63596

SEA431687

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	SENT TO STATION BY W.P.	Rick S
4-9-96	GAS MONITOR NEEDED TO BE RESET	Tim T.
TIME IN		
1415		
TIME OUT		
1435		

DATE	Checking reported noises in Pump Units	LESNIAK
4-10	1 & 2	
TIME IN		
10:30	Removed a piece of wood from #1 Clutch,	
TIME OUT	which was jammed between gusset & drum	
2:00		
	#2 Slip rings badly worn - worked w/ George	
	to replace them.	

DATE	Checked and cleaned slip rings	
~~4-25~~ 4/10	on clutches for RSP's. Will install	Kyle
TIME IN		
11:25	new brushes on #2 RSP.	
TIME OUT		
13:45		
15:25	Installed new brushes in clutch	
	for RSP #2.	

DATE		
4/11/96	Completed slip rings P.M.	Kyle
TIME IN		
7:10	Please leave RSP #2 on stand-by,	
TIME OUT		
8:20	until the slip rings are fixed.	

KCSlip4 63597

SEA431688

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area check list	[illegible]
4-12-96		
TIME IN		
1125		
TIME OUT		
1200		

DATE	Called to Station on Power Outage	Durken
4-14-96	Pa will go get gen truck	
TIME IN	No D.C. Control	
0629	(Replaced Fuse in Battery Charger)	Tom Elwell
TIME OUT		
0850	→ STATION back to normal	

DATE	STATION CHECK	Mark S.
4-15-96	SENT ALARMS	
TIME IN		
1230		
TIME OUT		
1335		

DATE	IN STATION TO REMOVE AHF ROTOR	PAULA
4-16-96	FOR REPAIR. WILL BE OOS	
TIME IN		
0645		
TIME OUT		
0830		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CHECKING DC CONTROL PWR ALARM	J BALL
4-16-96	TO SCADA OK	
TIME IN		
1300		
TIME OUT		
1315		

DATE		
	Replumbing seal water	
TIME IN	lines	Green
TIME OUT	4/17 + 4/18	

DATE	Area Checked [illegible]	[illegible]
4-19-96	Recharged Hydro Tank	
TIME IN		
0750		
TIME OUT		
0830		

DATE		
4-22	Checking for lockout equip	LESNIAK
TIME IN		
12:25	marks improvements to seal water	
TIME OUT	system look great!	

KCSlip4 63599

SEA431690

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	STATION CHECK	Rick S.
4-22-96	SENT ALARMS	
TIME IN	SWITCHED RSP LEAD → 3, 2, 1	
1300	WHILE #1 RSP SEAL WATER WORK	
TIME OUT	IS BEING DONE	
1350		

DATE	Area Check	Tuth.
4-24-96	Post Alarms	
TIME IN		
1455		
TIME OUT		
1515		

DATE	On station to install new	Medosch
4-25-96	chainfall in wet well + tonnage	
TIME IN	capacity signs.	
1415		
TIME OUT		
1520		

DATE		J. Lewis
4/26/96	Sent an inst air alarm	
TIME IN		
1130		
TIME OUT	1350 - Checklist	Elmer
1140		

KCSlip4 63600

SEA431691

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	STATION CHECK	Rick S.
4-29-96	SENT READINGS	
TIME IN		
1420		
TIME OUT		
1450		

DATE	CHECKING #3 PSP	STEVE
4-30		
TIME IN		
0830		
TIME OUT		
0930		

DATE	IN STATION TO REPLACE REBUILT	PAULA
5-1-96	ARMATURE TO AMF.	
TIME IN		
1300		
TIME OUT		

DATE		
5/2/96	P.M Rain Gauge	Dayton
TIME IN		
TIME OUT		

KCSlip4 63601

SEA431692

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area Checklist	Tramble
5-3-96		
TIME IN		
1115		
TIME OUT		
1145		

DATE		
5-6	Worked on seal H^2O line	Green
TIME IN		
10:30	Ran out of Mapp gas	
TIME OUT		
3:00		

DATE	STATION CHECKLIST	Rick S.
5-9-96	SENT ALARMS	
TIME IN	CHANGED OUT W/W CHART	
TIME OUT		

DATE	STATION CHECK. AHU MAKING	PAULA
5-10-96	ALOT OF NOISE AGAIN. WILL WRITE UP	
TIME IN		
0800	SHUT-OFF UNIT	
TIME OUT		

KCSlip4 63602

SEA431693

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
5-13	Finishing seal H2O lines	Green
TIME IN	to #1	
0700		
TIME OUT		
	operator note: walls behind	
	pumps need grease cleaned	
	off.	
DATE	Area checklist	Blair
5/13/96		Olvedo
TIME IN		
0950		
TIME OUT		
DATE	INSTATION / checklist / Send ALARMS	Blair
5/13/96		
TIME IN		
09:57		
TIME OUT		
DATE	IN STATION TO WORK ON AHU	PAULA
5-14-96		
TIME IN	REPLACED UPPER BEARING 203 S22	
0640	AGAIN! SOUNDS O.K. SHAFT WORN.	
TIME OUT	BAD FIT. NEED TO KEEP AN EYE	
1145	ON THIS UNIT	

KCSlip4 63603

SEA431694

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
5/14/96	Checked and washed station batteries.	Vigil
TIME IN		
10:55		
TIME OUT		
12:05		

DATE	Inspect with Superior fire	Blair
5-15-96	Extinguisher	Leif
TIME IN		
11:43	cleared Packing Drain on #2	
TIME OUT	Pump, was Running Hose water	
	C-2 Alarm came in, cleared it.	
	Blair - no Radio or Phone, Ride	
	with Superior fire, Have Phone	
	with me But found no Jack in install	
	in his truck.	

DATE		Salsbury
5/16/96	Checked station. Did Yard care.	Olivo
TIME IN		
0828		
TIME OUT		
0935		

DATE		Paula
5-16-96	Checking AHU. OK.	
TIME IN		
1310		
TIME OUT		

KCSlip4 63604

SEA431695

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	STATION CHECKLIST	Rick S
5-20-96	PUMPED DOWN W/W	
TIME IN	SENT ALARMS	
1400		
TIME OUT		
1440		

DATE	INSTATION with Superior fire	Blair
5/21/96	Extinguisher	Leif
TIME IN		
11:57		
TIME OUT		

DATE	STATION CHECK	Olmeros
5-23-96	RECHARGED HYDRO TANK	Salsbury
TIME IN	GEN. CLEANING	
5/24/96	INSTATION - CHECK AREA	Blair
TIME OUT		
11:27		

DATE		
5/28/96	Check Telemetery	Payton
TIME IN		
TIME OUT		

KCSlip4 63605

SEA431696

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	STATION CHECKLIST	SALSBERY
5-28-96	SENT ALARMS	OLIVEROS
TIME IN		
1510		
TIME OUT		
1530		
DATE	Camps Project	LESNIAK/SAGEN
6/4/96		
TIME IN		
2:30		
TIME OUT		
DATE	- CHECKLIST	[illegible]
6 5 96	- CLEANING INSIDE STATION - RESTROOM	L.T
TIME IN	- CUTTING LAWN	
	- HOSING STATION.	
TIME OUT		
DATE	area check list, Changed chart	Lato
6-14	weed eated crown, stashion clean drive	
TIME IN	way trim Shrubs	
TIME OUT		

KCSlip4 63606

SEA431697

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	installation, Send ALARM	Blair
6-17-96	checklist, chamber #2 Packing	
TIME IN	gland	
12:59		
TIME OUT		

DATE		
6-18	Replacing coupling shim	Green
TIME IN	pump chamber #2 ESP	
10:30		
TIME OUT		

DATE	installed a new partition into the	J Ferris
6-18	PLC program	
TIME IN		
1200		
TIME OUT		

DATE	- CHECKLIST	
6-21-96	- EXCERSIDGD GATE	
TIME IN	-	
TIME OUT		

KCSlip4 63607

SEA431698

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	INSTATION · CHECKLIST Send ALARMS	Blair
6-24-96	Hose Packing gland on #2 P.U.	
TIME IN		
12:56		
TIME OUT		
DATE	- CHECK SPRINKLER SYSTEM.	M
6-25-96	AND EST. BARK DELIVERY.	
TIME IN		L.T
0730		
TIME OUT		
DATE	IN STATION TO ADD RING OF	PAULA
6-26-96	PACKING TO # 2 RSP	
TIME IN		
0745		
TIME OUT		
6-26-96	CUTING LAWN - CLEANING PARKING AREA	M.
DATE		
TIME IN		
TIME OUT		

KCSlip4 63608

SEA431699

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	- CHECK OF STATION	[illegible]
6-28-96	- EXERCISED PUMPS - PUMPED DOWN WETWELL	
TIME IN	- ADJUSTED #3 RSP PACKING.	L.T.
1300		
TIME OUT		
DATE	CHECKING TELEMETRY ALARMS	J BALL
7-1-96		
TIME IN		
0825		
TIME OUT		
0846		
DATE		
7/1/96	Checked and tested UPS.	[illegible]
TIME IN		
13:45		
TIME OUT		
14:25		
DATE	area check list Sent Alarms	L Tanner
7-3-96		
TIME IN		
TIME OUT		

KCSlip4 63609

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
7/3/96		
TIME IN		
110	Inspect for CAMPS project	M.D. Ambrosia
TIME OUT		
130		

DATE	In Stashion walk throw	L Tanner
25		
TIME IN		
14:00		
TIME OUT		

DATE	Station checklist, Send Alarms	L.T.
7-9-96	to W.P. Pump down and	B.F.
TIME IN	hosed w/w, Exercised RSP's	
11:50	Pulled morning glory out of	
TIME OUT	out side shrubery	

DATE	CHECKING GASDETECTION SYSTEM PLUGGED	J BALL
7-10-96	UNIT IN SEEMS OK NOW	
TIME IN		
0650	CHECKING UNITS 1505	STEVE
TIME OUT		
0705		J BALL
	IN 1525 CLEANED AND CHECKED	J LEWIS
	OUT 1538 RAIN GAUGE	

7-11-96 Mid Waste installed 1500 in wet well P Garcia/T. Coffey
time in 1153
time out 1202

KCSlip4 63610

7-11-96 RECHECKED RAINGAUGE

1315 J BALL
1330 J LEWIS

7.12 96 p/n Samples & reset P. Garcia
740 AM
750 AM

7.15.96 p/n sample & reset D Garcia
1005AM T. Coffey
1015

7-16-96/ STATION checklist, Send Alarms to W.P.
1315 Recharge hydro tank. Control battery's need
L.T. water, will write up. Exercized RSPS
B.F.

7/17/96 p/n samples & reset Dharcia
863 AM
812 AM

7/18/96
0930 PAINTER in TO CLEAN PAINT & PAINT EQUIP.
12:45 OUT - I'LL BE BACK.

7-19-96
7:30 PAINTER in TO PAINT AS ABOVE.

7/18.96 p/n samples D Garcia
1020 AM
1035 AM

KCSlip4 63611

SEA431702

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area check	L.T.
7-26-96	Yard work	
TIME IN	C-2 water Fill tank Valve leaking By	
8:45	Will Right up.	
TIME OUT		
	Repair & Calibrate Man Hole	Panton
12:00	Level Xmither	

DATE	Station checklist, Send Alarms	Fairchild
7-29-96	to W.P.	
TIME IN		
12:50		
TIME OUT		

DATE	Work on C-2 tank	Fen
1200		
TIME IN		
350		
TIME OUT		

DATE	IN STATION FOR MECH. DOM	PAULA
8-2-96		
TIME IN		
1100		
TIME OUT		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Yard work walk thru	C.T.
8-2-96	crew	
TIME IN	Fix ink in chart.	
15:00	#1 and #2 pump Runing	
TIME OUT	Speed Ramp up lead Flow drop	
15:30	OFF Runs Fine	

DATE		
8-2-96	Painter in to Clean Paint	
TIME IN	& Paint walls & piping in Pump	
07:30	Room	
TIME OUT		
16:00		

DATE	Instalation to reset pump room	Eleanor
8-3-96	flood alarm.	
TIME IN		
0710		
TIME OUT		

DATE	Station Checklist, Send Alarms to	B.F.
8-5-96	W.S. Recharged hydro tank	
TIME IN	Changed out manhole inker on	
13:10	chart. TEST RSP's	
TIME OUT		

KCSlip4 63613

SEA431704

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	POINTER IN TO CLEAN UP MESS	[illegible]
8-6-96	of LIFT STA.	
TIME IN		
07 30		
TIME OUT		
10:00		
DATE	Inspecting C-2 System for CAMPS	~~LES~~ NIAK
8-6	Replacement	LOLAND
TIME IN		
8:50		
TIME OUT		
DATE	CHECKING PUMPING UNITS 1-2-3	STEVE
6 AUG 6		
TIME IN		
1000		
TIME OUT		
1230		
DATE		
8/8	Checking Man hole level	Pointer
TIME IN	x m. Hour	
TIME OUT		

KCSlip4 63614

SEA431705

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checked Station,	T.L.
8.8.96		B.F.
TIME IN		
12:45		
TIME OUT		

DATE	Alarm Check list	[illegible]
8.9.96		
TIME IN		
1400		
TIME OUT		
1420		

DATE	Station checklist, Send Alarms to	B.F.
8/12/96	W.P. Pump down w/w test	
TIME IN	RSPS, Adjusted #2 BST packing	
15:00	unplugged drain and cleaned mess.	
TIME OUT		

DATE		
8/13/96	Replaced & Calibrated	Paytor
TIME IN	D/P Cell for Man hole	
11:00	Level	
TIME OUT		
13.30		

KCSlip4 63615

SEA431706

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IN STATION PURGING SYSTEM DUE TO	M.
8-14-96	STORAGE PROGRAM	
TIME IN		
0725		
TIME OUT		

DATE	Station Checklist	T.T.
8-16-96		
TIME IN		
0830		
TIME OUT		
0850		

DATE	Station walkthrough	B.E.
8-19-96		
TIME IN		
14:40		
TIME OUT		

DATE		
8/20/96	Check Pump Control	Parton
TIME IN		
TIME OUT		
10:30		

KCSlip4 63616

SEA431707

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Starting check list	T.T.
8-21-96	Sent Alarm's	
TIME IN	Exercise Influent Gate	
1100		
TIME OUT		
1135		

DATE	closing Influent Gate for Storage	T.T.
8-22-96	program	
TIME IN		
2315	Wet Well level at 95.1	
TIME OUT		
2330		

DATE	Storage program over	T.T.
8-23-96	Influent gate open "100%".	
TIME IN	All RSP in Auto	
0735	Station OK	
TIME OUT		
0825		

DATE	Station checklist, Take follow	B.F.
8-26-96	pump off line, Recharge hydro	
TIME IN	tank, Exercised ~~inf.~~ gate	
12:10	Exercised RSP's Adjusted #2 RSP	
TIME OUT	packing. Clean Top sink and	
1330	restroom. Cut the grass	

KCSlip4 63617

SEA431708

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Working on station SOP's	Tom Elwell
5-27-96		
TIME IN		
0840		
TIME OUT		
0945		

DATE	At station to replace AHU	T.T.
8-28-96	filters, Lamping in W/W	B.E.
TIME IN	Pump down & hosed wet well	
09:30		
TIME OUT		

DATE		
9/4/96	Check telemetery	[illegible]
TIME IN		
TIME OUT		
14:47		

DATE	Station check list, Sent Alarm's	T.T.
9-5-96	No. 2 Service Air Comp. leaking	M.O
TIME IN	Air at a Green Oil at pressure	
0920	relief valve W/O.	
TIME OUT		
0950		

KCSlip4 63618

SEA431709

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check	7-7.
9-6-96	Float Valve leaking W/O	
TIME IN		
1130		
TIME OUT		
1150		
DATE		
9-6-96	Removed slabs in drive to	Green
TIME IN	check flap gates.	Norman
12 30		Medosch
TIME OUT	#1 flap gate fell off.	
	#2 + 3 are rusted open	
	never to be closed again	
DATE	Inspecting Flap Gate situation	LESNIAK
9-9-96		
TIME IN		
TIME OUT		
DATE	Station checklist Sent alarms.	Olivas
9/9/96		
TIME IN		
TIME OUT		
1325		

KCSlip4 63619

SEA431710

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check	[illegible]
7-12-96		M.O
TIME IN		
1415		
TIME OUT		

DATE	IN STATION TO LOOK AT #2 SERVICE	PAULA
9-13-96	AIR COMPRESSOR	
TIME IN		
0630		
TIME OUT	NEED NEW RELIEF WILL ORDER	

DATE	Checked station	Eleanor
9-13-96	Recharged hydro tank	
TIME IN		
0900		
TIME OUT		

DATE	Station checklist Sent alarms.	Olivia
9/16/96		
TIME IN		
0915		
TIME OUT		

KCSlip4 63620

SEA431711

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IN STATION TO LOOK AT #2 [redacted]	PAULA
9-18-96	SERVICE AIR COMPRESSOR	
TIME IN		
0900		
TIME OUT		

DATE	Station check. Cleaned station.	Olivares
9/18/96		Tamble
TIME IN		
TIME OUT		

DATE	CHECKING INST AIR + 24VDC ALARM	JBALL
9-18-96		
TIME IN		
1155		
TIME OUT		

DATE	IN STATION TO WORK ON #2 SAC	
9-19-96		
TIME IN	0820	
[redacted]		
TIME OUT		

KCSlip4 63621

SEA431712

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
9-19	Installed Lockout Station	Green
TIME IN		
TIME OUT		

DATE	Area Check	T.T.
9-20-96	Recovered Hydro Tank	
TIME IN		
1430		
TIME OUT		
1445		

DATE	Station Checklist. Seal drains.	O'Neals
9/23/96		
TIME IN		
0835		
TIME OUT		

DATE	Checking Compressors & #3 Clutch	LESNAK
9-23-		
TIME IN		
TIME OUT		

KCSlip4 63622

SEA431713

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CHECKING R.S.P's.	STEVE
9-27		
TIME IN		
0850		
TIME OUT		
1100		

DATE	Station checklist. Scan alarms	Olivine
9/30/96	Need recording chart notified Larry Parkin	
TIME IN		
1102		
TIME OUT		

DATE	CHECKING PRESSURE SWITCHES ON THE	J BALL
10-1-96	SERVICE AIR COMPRESSORS FOUND	
TIME IN	OPERATION MANUAL HAD WRONG INFO -	
0645	CHANGED TO PROPER PSI READINGS IN	
TIME OUT	RED PAGE 8-10 OPERATIONS MANUAL	
0830		

DATE		
10/2/96	Watered station control batteries.	Floyd
TIME IN	Checked the operation of cooling	
10:00	water solenoid valve for service air. Electrically	
TIME OUT		
12:15	works well. Valve must be stuck	
	open.	

KCSlip4 63623

SEA431714

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
10/3/96	Checking C2 Water Solenoid	[illegible]
TIME IN	Installed New Chart	
TIME OUT		

DATE	STATION CHECK	Rich S
10-3-96		
TIME IN		
1120		
TIME OUT		

DATE	Station walk thru	[illegible]
10.4.96	Recharged hydro tank	
TIME IN		
1000		
TIME OUT		
	Checking C2 Water Solenoid	[illegible]

DATE	Station checklist. Sent alarms. Pumped	
10/8/96	down wet well	
TIME IN		
1015		
TIME OUT		

KCSlip4 63624

SEA431715

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
10/8/96	Working on service air compressors.	Hyel
TIME IN		
10:20		
TIME OUT		
DATE		
10/9/96	Installed LEAD-LAG	Hyel
TIME IN		
9:45	selector switch for service air	
TIME OUT		
13:45	compressors.	
DATE	C-2 Break Tank - redefine	LESNIAK
10-9	Float geometry to improve shut off	
TIME IN		
245		
TIME OUT		
DATE	Starting check - Dumped trash. Cleaned	Olivera
10-10-96	& hosed pump room. Adjusted packing on #2	Lakeberry
TIME IN	R.S.P.	
1040	CLEANED REST ROOM	
TIME OUT		

KCSlip4 63625

SEA431716

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	STATION CHECKLIST	Rick S.
10-14-96	SENT ALARMS	
TIME IN	RAN PUMPS	
1300		
TIME OUT		

DATE		
10/16	Mechanical PM check	Green
TIME IN		
650		
TIME OUT		

DATE	Performed P.M of slipings and brushes	Hynt
10/16/96	on clutches for R.S.P's.	
TIME IN		
10:45		
TIME OUT		

DATE	Station check .. Ran #1 & 3 R.S.P "follow"	Olivares
10/18/96	Adjusted packing on #1 R.S.P & cleaned	
TIME IN	drain.	
0915		
TIME OUT		

KCSlip4 63626

SEA431717

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	station checklist. Sent alarms.	Olivera
10/21/96		
TIME IN		
1205		
TIME OUT		

DATE	STATION CHECK	Rick E
10-24-96	PUMPED DOWN WET WELL TO	
TIME IN	TAKE OFF FOLLOW PUMP	
1430		
TIME OUT		

DATE	Checked station	EJS
10-25		
TIME IN		
1400		
TIME OUT		

DATE	Station checklist. Sent alarms.	Olivera
10/28/96	Pumped down sump & wet well to take	
TIME IN	off follow pump. Replaced filter media	
1230	Unplugged roof drain	
TIME OUT		

KCSlip4 63627

SEA431718

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
10/29/96	Checked station battery, put	Hyne
TIME IN		
14:40	charger on equalizing charge.	
TIME OUT		

DATE	Checked station. Exercised follow pump.	Olivera
10/31/96	Cleaned station in & out.	Sokoly
TIME IN		
1230		
TIME OUT		

DATE	Checked station	EJS
11-1-96		
TIME IN		
0900		
TIME OUT		

DATE	STATION CHECK LIST	Rick S
11-4-96	CHARGED HYDRO TANK	
TIME IN	SENT ALARMS	
TIME OUT		

KCSlip4 63628

SEA431719

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CHECKING PUMPS.	STEVE
8NOV		
TIME IN		
1300		
TIME OUT		
1500		

DATE	- CHECK OF STATION	
11-8-96	- YARD WORK	
TIME IN	- CHANGED WETWELL CHART	
1550		
TIME OUT		

DATE	IN STATION TO REPACK # 1 RSP	PAULA
11-12-96		M. GREEN
TIME IN	Where steam was excellent	
0645	Savings of packing	
TIME OUT	# 23018	

DATE	STATION CHECKLIST	ES
11-12-96	SENT ALARMS	VO
TIME IN	CLEANING	
0840		
TIME OUT		

KCSlip4 63629

SEA431720

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED:	NAMES
DATE	Checked station	VO / ES
11.15.96		
TIME IN		
1030		
TIME OUT		

DATE	STATION CHECKLIST	Rick S
11.18.96	SENT ALARMS	
TIME IN		
1400		
TIME OUT		

DATE	Checked station	EJS
11.22.96	Exercised RSP's	
TIME IN		
1010		
TIME OUT		

DATE	Bldg Survey by Med-Tox NW	Tom Choate
11/25/96		Bill Murray
TIME IN		
14.10		
TIME OUT		
15.25		

KCSlip4 63630

SEA431721

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	STATION CHECKLIST	Rick S.
11-25-96	SENT ALARMS	
TIME IN		
1400		
TIME OUT		

DATE	STATION CHECK	Rick S
11-27-96	CLEANING	
TIME IN		
1400		
TIME OUT		

DATE	STATION CHECK	Rick S.
12-2-96	SENT ALARMS	
TIME IN	RESET HIGH WET WELL	
1445	SCRUBBED PUMP RM FLOOR	
TIME OUT		

DATE	MECH P.M.	PIZZA
12-3-96		
TIME IN		
0845		
TIME OUT		

KCSlip4 63631

SEA431722

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	- CHECKLIST	[illegible]
12-3-96	- SENT ALARMS	
TIME IN	- RECHARGED HYDRO TANK	L.T
1100	- CLEANING	
TIME OUT		

DATE	#2 Motor/Clutch checks O.K. for	LEENIAK
12/5	reported vibration	
TIME IN		
2:30		
TIME OUT		

DATE	CHECKING R.S.P. UNITS	STEVE
12-6		
TIME IN		
1300		
TIME OUT		
1430		

DATE		
12/9/96	Performing el. P.M.	[illegible]
TIME IN		
8:35		
TIME OUT		

KCSlip4 63632

SEA431723

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	- CHECKLIST - SENT ALARMS	[signature]
12.10.96	- BLEW PARKING AREA	
TIME IN	- PUMPING DOWN WETWELL -	
1230	- CHANGED WETWELL CHART	L.T
TIME OUT		

DATE		
12/10/96	Performing el. P.M.	[signature]
TIME IN		
13:45		
TIME OUT		
15:35		

DATE	- CHECK OF STATION	[signature]
12.13.96		
TIME IN		L.T.
TIME OUT		

DATE	- CHECKLIST - SENT ALARMS	[signature]
12.17.96	- CLEANING MAIN FLOOR - RESTROOM - SINK	
TIME IN	- PUMPING DOWN WETWELL - Hosed ~~[illegible]~~ lamping	
1250	-	L.T
TIME OUT		

KCSlip4 63633

SEA431724

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	- CHECK OF STATION	
12 20 96	- CLEANING IN BASEMENT ~~[illegible]~~ LEVEL.	[illegible]
TIME IN	- CHECKING FAN MAKING NOISE	
0930		L.T.
TIME OUT		
	W/O CHECK AIR VENT UNIT BEARINGS SOUND BAD	

DATE	INSTALLATION	Blan
12-23-96	CHECKLIST	
TIME IN	SEND ALARMS	
12:58		
TIME OUT		

DATE	Performed El. C. M.	[illegible]
12/31/96		
TIME IN		
10:05		
TIME OUT		
13:25		

DATE	- CHECKLIST -	[illegible]
1 2 96	- PUT #3 RSP IN HAND SO THAT PUMPING UNIT WILL KEEP	
TIME IN	PUMPING. BUT IS ON A FLOAT SO IT IS FLUCUATING FROM	L.T.
1000 AM	220-400. WILL CHECK LATER TODAY.	
TIME OUT		
	~~Found~~ #3 In Hand, Speed Below	Paytan
	Min. Pumping. Two Pumps	
	Keeping Level down Put	
	#3 Back To Auto	

KCSlip4 63634

SEA431725

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	area check list, Sent Alarms	Lt
1-6-97	Stock area.	
TIME IN		
14:00		
TIME OUT		

DATE	CHECKING INST AIR SYSTEM INFO	JBALL
1-6-97		
TIME IN		
1525		
TIME OUT		
1530		

DATE	Load tested UPS, adjusted	Kyal
1/7/97	Charger	
TIME IN		
8:45		
TIME OUT		

DATE	DOING INSTRUMENT PMS WETWELL	J BALL
11-8-97	LEVEL DIDN'T SEEM TO CHANGE AFTER	
TIME IN	CALIBRATION CALLED PUMP CREW FOUND	
0650	LEAK IN BUBBLER LINE OR NEW	
TIME OUT		
1220		

KCSlip4 63635

SEA431726

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CHECKING PUMPS + MOTORS	STEVE
9 JAN		
TIME IN		
1215		
TIME OUT		
1445		

DATE	Checking #2 motor [illegible]	LESNIAK
1-9-97		
TIME IN		
12:30		
TIME OUT		

DATE	Area Check.	Jim T.
1-10-97		
TIME IN		
0800		
TIME OUT		
0830		

DATE	IN STATION TESTING BACKFLOW ASSEMBLY	PAULA
1-10-97		
TIME IN	ASSEMBLY FAILED RELIEF NOT OPENING	
1200	WILL REPAIR NEXT WEEK	
TIME OUT		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	WORKING ON BACKFLOW ASSEMBLY	PAULA
1-14-97		
TIME IN		
0700		
TIME OUT		

DATE	Area check list, Sent Alarms	L.T.
1-14-97		
TIME IN		
13:45		
TIME OUT		

DATE	Station Check	J.T.
1-17-97		J.T.
TIME IN		
1345		
TIME OUT		
1410		

DATE	Station Check list	J.T.
1-21-97	Area Check	J.T.
TIME IN	Sent Alarms	
1345		
TIME OUT		
1410		

KCSlip4 63637

SEA431728

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CHECKING #2 MOTOR	STEVE
1-28-97		
TIME IN		
0815		
TIME OUT		
1010		

DATE	Area check list	[illegible]
1-28-97	Station check	
TIME IN	Chart Recorder is out of Paper	
1330	Paper for Recorder is on order	
TIME OUT		
1405		

DATE	IN STATION TO CHANGE OIL, clean filters	BARNY
1-30-97	~~[illegible]~~ SERVICE AIR COMPRESSORS	
TIME IN		
1112		
TIME OUT		
1225		

DATE	In station Look around, and meet	Tit.
1-30-97	Montance Hour.	LT.
TIME IN		
11:35		
TIME OUT		

KCSlip4 63638

SEA431729

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms.	O'Hare
2/4/97		Tanner
TIME IN		
1220		
TIME OUT		

DATE	Found a chart to fit recorder.	Jack Stevens
2/10/97	One spare!	
TIME IN		
1030		
TIME OUT		
1040		

DATE		O'Hare
2/10/97	Station checklist. Sent alarms.	
TIME IN	turned heat down to 55°. Cleaned &	
0945	closed pump room	
TIME OUT		

DATE	area check	L.T.
2-14-97		
TIME IN		
10:00		
TIME OUT		

KCSlip4 63639

SEA431730

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE 2/18/97	Station checklist Sent alarms.	Oliveros Tanzer
TIME IN 1230		
TIME OUT		

DATE 2/20	Lub. pumps motors	Green
TIME IN		
TIME OUT		

DATE	Station checklist, Sent alarms. Replaced air filter, cleaned station	Oliveros
TIME IN 1100		
TIME OUT 2/24/97		

DATE 2/25/97	Checked and washed station	
TIME IN 9:30	batteries, adjusted charger and	Wynd
TIME OUT	set on equalizing charge	

KCSlip4 63640

SEA431731

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checked station.	CT / GS
2-25-97	Pulled floats	
TIME IN		
1130		
TIME OUT		

DATE	CHECKING PUMPS	STEVE
2-18		
TIME IN		
1200		
TIME OUT		
1300		

DATE	Station checklist. Set alarms.	Olivine
3/12/97		
TIME IN		
0850		
TIME OUT		

DATE	IW Sampler set up	Kathy
3/3/97		
TIME IN		
1050		
TIME OUT		
1200		

KCSlip4 63641

SEA431732

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
3/4/97	Checking Pump Controls	[illegible]
TIME IN		
TIME OUT		

DATE	IW Sample Collection	KF
3/4/97		
TIME IN		
1245		
TIME OUT		
~~1~~ 1700		

DATE	Check station	
3/4/97		
TIME IN		
1340		
TIME OUT		

DATE	Sample collection	Keiling
3/5/97		
TIME IN		
1215		
TIME OUT		
1225		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IW in WW	TA + KF
3/6/97		
TIME IN		
1048		
TIME OUT		
1100		

DATE	Check station	LT / CA
3/7/97		
TIME IN		
1350		
TIME OUT		

DATE	IW sampling	KF
3/10/97		
TIME IN		
1105		
TIME OUT		
1120		

DATE	Checklist	LT / CA
3/11/97	[illegible]	
TIME IN	Recharged expansion tank.	
1030		
TIME OUT		

KCSlip4 63643

SEA431734

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IW Sampling	KF
3/11/97		
TIME IN		
1140		
TIME OUT		
1150		

DATE	IW Sampling	KF
3/12/97		
TIME IN		
1145		
TIME OUT		
1155		

DATE	IW sampling	KF
3/13/97		
TIME IN		
1140		
TIME OUT		
1145		

DATE	IW sampling	KF
3/18/97		
TIME IN		
1130		
TIME OUT		
1140		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	area checklist - Sent Alarms	L.T.
3-18-97	Changed chart.	
TIME IN	adjusted packing on #2 pump needs	
12:20	packing Reset gas monitor	
TIME OUT		
13:20		

DATE	CHECKING - 24VDC CONTROL VOLTAGE	JBALL
3-18-97	ALARM	
TIME IN		
1310		
TIME OUT		
1320		

DATE	IN TO REPACK #2 RSP	BARNEY
3-20-97		GREEN
TIME IN		
0820		
TIME OUT		

DATE	CHECKING I.A. ALARM - TURNED ON	J BALL
3-20-97	GAS DETECTOR, REPLACED BULB	
TIME IN		
1040		
TIME OUT		
1055		
3-21-97	leaks good	L.T. C.A.
1500		

KCSlip4 63645

SEA431736

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IW sampling	KF
3/20		
TIME IN		
1330		
TIME OUT		
1340		

DATE	IW sampling	KF
3/24		
TIME IN		
1115		
TIME OUT		
1125		

DATE	area check list	L.T.
3-25-97	Sent Alarm's	C.A.
TIME IN		
12:45		
TIME OUT		

DATE	IW sampling	KF/GN
3/25/97		
TIME IN		
1315		
TIME OUT		

KCSlip4 63646

SEA431737

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	SENDING TELEMETRY ALARMS	J BALL
3-26-97		
TIME IN		
0820		
TIME OUT		
0845		

DATE	CHECKING PUMPS	STEVE
3-27		
TIME IN		
1205		
TIME OUT		
1450		

DATE	CHANGING PM 550 LOCAL REMOTE	J BALL
3-27-97		
TIME IN		
1405		
TIME OUT		

DATE		
3/28/97	Working on Pump Control Mode #3	Payton
TIME IN		
TIME OUT		
1130		

KCSlip4 63647

SEA431738

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
4/1/97	Working on Mode #3 Pump Control	Paxton
TIME IN		
TIME OUT		

DATE	CHECKLIST	TT/CA
4/2/97	SENT ALARMS	
TIME IN	Area Cleaning	
0915	Recharge Hydro Tank.	
TIME OUT		

DATE	CHANGING P.L.C BATTERIES	J BALL
4-3-97		
TIME IN		
0930		
TIME OUT		
0940		

DATE		
4/4/97	Working on Mode #3 Control	Paxton
TIME IN		
TIME OUT		

KCSlip4 63648

SEA431739

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Mech PM	[illegible]
4-4-97		
TIME IN		
1320		
TIME OUT		
1355		

DATE		
4/8/97	Completed Mode 3	[illegible]
TIME IN		
~~[illegible]~~		
TIME OUT		

DATE		
4-9-97	Vibration PM Monthly	Moore
TIME IN		INMAN
8:45		
TIME OUT		
0930		

DATE	Working On #2 Clutch	LESNIAK
4-9-97		
TIME IN		
1:00		
TIME OUT		

KCSlip4 63649

SEA431740

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check list	T.T
4.10.97	Sent Alarm's	E.A
TIME IN	Area Check, Area Cleaning	
1000	[illegible]	
TIME OUT	[illegible]	
1120	[illegible]	
	Area Jumping	

DATE	Here To PM Slip Rings	T. Elwell
4/10/97	Brushes	
TIME IN		
1345		
TIME OUT		

DATE	- Note: Please continue to use	LESNIAK
4-10-97	#2 Pumping unit in 2nd Follow	
TIME IN	until it is rebuilt (clutch-motor)	
2:00		
TIME OUT		

DATE	DRAIN VALVE FOR HYDRO-TANK	PAULA
4/11/97		
TIME IN		
0710		
TIME OUT		
	In Station at 1200	T.T.
	Helping Tank	
	Recharge Hydro Tank	

Out at → 1400

KCSlip4 63650

SEA431741

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
4-14-97	changed chart	joe [illegible]
TIME IN		
1420		
TIME OUT		
1430		

DATE	Measuring fan shaft	Bacary
4-15-97		
TIME IN		
TIME OUT		

DATE	Replaced hour meter for	Kizal
4/15/97	service air compressor #1.	
TIME IN		
8:20		
TIME OUT		
	Check Metrotel Telemetery	[illegible]

DATE	Checked	T/CA
4/15/97	[illegible]	
TIME IN	Recharge Hydro Tank. Hydro Tank	
1330	Drain Valve leaks. w/o.	
TIME OUT		
1415		

KCSlip4 63651

SEA431742

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CRANE INSPECTION	PAULA
4/17/97		
TIME IN	Fix HYDRO TANK DRAIN LINE	
0850		
TIME OUT		

DATE	Area Check	T.T.
4-22-97	Sent Alarm's	
TIME IN	Station checklist	
1140	Recharge Hydro Tank	
TIME OUT		
1245		

DATE	Station Check	T.T.
4-25-97	Recharge Hydro Tank	
TIME IN		
0745		
TIME OUT		
0805		

DATE	Called to Station By Main Control	T.T.
4-25-97	Low C-2 Pressure	
TIME IN		
1430	Pilot Valve Float for Air	
TIME OUT	Break Tank Stuck Close.	
1500		
	Adjusted Float, Recharge	
	Hydro Tank, System OK	

KCSlip4 63652

SEA431743

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	INSTATION	Blair
4/22/97	FLOAT STUCK IN BREAK	
TIME IN	TANK, A LITE touch to	
0926	it made it WORK.	
TIME OUT	TANK FILLED AND OBSERVED	
	OPERATION to ENSURE it	
	WOULD WORK OK.	

DATE	Adjusted & Fine-tuned C-2 Float	[illegible]
4/28/97	valve linkage. Tested OK	
TIME IN		
1100		
TIME OUT		

DATE	AIR COMP. OIL CHANGE	PAULA
5-1-97		
TIME IN		
1100		
TIME OUT		

DATE	Checklist	[illegible]
5/1/97	Sent alarms	
TIME IN	Recharged tank Hydro	
1418		
TIME OUT		

KCSlip4 63653

SEA431744

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	LUBE COMPRESSOR - CHECK HYDRO	PAULA
5-2-97	TANK, WILL ORDER NEW	
TIME IN	SAFETY VALVE	
0830		
TIME OUT		
DATE	Station Checklist - Sent Alarms	Oliveros
5/7/97	Recharge Hydro Tank	T.T.
TIME IN		
1100		
TIME OUT		
1135		
DATE	Station Check.	T.T
5-9-97		
TIME IN		
1245		
TIME OUT		
1300		
DATE	Station Check	[signature]
5/15/97	AREA CHECKLIST.	
TIME IN		
1100		
TIME OUT		
1115		

KCSlip4 63654

SEA431745

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check	T.T.
5-15 97	Recharge Hydro Tank	
TIME IN		
1340		
TIME OUT		
1405		

DATE	CHECKING PUMPS	STEVE
16 MAY		
TIME IN		
0900		
TIME OUT		
1040		

DATE		
5/16/97	change chart	Jackie [illegible]
TIME IN		
1445		
TIME OUT		
1500		

DATE	Station Check	DB & ME
5-15-97	Sent Alarms	
TIME IN	AREA Checklist	
1145		
TIME OUT		
1200		

KCSlip4 63655

SEA431746

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	INFO. TO ORDER PARTS # 1 SERVICE	PAULA
5/20/97	AIR COMP.	
TIME IN		
1415	RECHARGE HYDRO TANK	
TIME OUT		
DATE	Yard Work	7-7
5-21-97		
TIME IN		
1510		
TIME OUT		
1600		
DATE		
5/27/97	Found powerfail, exp haz	Jack Lewis
TIME IN		
1010	and low inst air alarms on	
TIME OUT		
1115	annunciator panel. They	
	reset when acknowledged	
DATE	Crane Inspections	LESNIAK
5-29		MOORE
TIME IN		
TIME OUT		

KCSlip4 63656

SEA431747

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area Check	T.T.
5.30.97	Station Check list	
TIME IN	Recharge Hydro Tank	
1020	Hosed Pump room and Flush	
TIME OUT	Drains.	
1055		

DATE		Jack Lewis
6/4/97	Sent an pump fail alarm to	
TIME IN	WPTP	
1215		
TIME OUT		
1230		

DATE	Station checklist. Sent alarm.	
6/5/97	Pumped down wet well & sump. Re charged	
TIME IN	hydro tank.	
0800	Yard Work Pump Down and	Chuck
TIME OUT	Hosed Wet Well	Trimble
0910		

DATE		
6/5/97	Sent alarms to WP and	Jack Lewis
TIME IN		
1035		
TIME OUT	adjusted the PLC Program.	
1100		

KCSlip4 63657

SEA431748

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check	T.T.
6-6-97		
TIME IN		
0800		
TIME OUT		
0815		

DATE	Working on #2 motor	Green
6/9		
TIME IN		
TIME OUT		

DATE	IN STATION TO REMOVE # 2 CLUTCH	GREEN
6/10/97	FOR REPAIR	NORMAN
TIME IN		
0645		
TIME OUT		

DATE		
6/10/97	Disconnected motor and clutch	Hyatt
TIME IN		
7:00	for DSS #2. Checked and	
TIME OUT		
	washed station batteries, set	
	chargers on equalizing charge.	

KCSlip4 63658

SEA431749

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarm	7.7
6-10-97	Pumped down wet well. Recharged	M.O
TIME IN	Hydro tank.	
0810	/ change Filters in A.H.U	
TIME OUT		

DATE	Station check	Olivia Trimble
6/12/97		
TIME IN		
1045		
TIME OUT		

DATE		
6/16/97	Changed ~~ge~~ chart	Jacki Lewis
TIME IN		
1315 ~~[illegible]~~		
TIME OUT		
1320		

DATE		
6/18/97	SENT ALARMS	JACKI LEWIS
TIME IN		
1430		
TIME OUT		
1500		

KCSlip4 63659

SEA431750

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check list	M.O
6-19-97	Sent Alarms	[illegible]
TIME IN	Recharge Hydro Tank	
0725	Pumped [illegible]	
TIME OUT		
0950		

DATE	REPLACING HYDRO TANK RELIEF	PAULA
6/19/97	VALVE	
TIME IN		
0725		
TIME OUT		

DATE	CHECKING MOTORS-CLUTCHES-PUMPS	STEVE
6-20-97		
TIME IN		
1210		
TIME OUT		
1340		

DATE	Station Check.	[illegible]
6-20-97		
TIME IN		
1330		
TIME OUT		
1340		

KCSlip4 63660

SEA431751

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	INSTATION	Blair
6/23/97	AREA CHECK	
TIME IN		
13:28		
TIME OUT		

DATE	Area Check	T-7
6-24-97	Sent Alarm	M.O
TIME IN	Station Check list	
1300	Pump Down Wet Well	
TIME OUT	Recharge Hydro Tank	
1345		

DATE	Station Check - Advised R.S.P.	Olmore
6/26/97		Trimble
TIME IN		
1400		
TIME OUT		

DATE	CHECK STATION RECHARGE	PAULA
6/27/97	HYDRO TANK	
TIME IN		
0740		
TIME OUT		

KCSlip4 63661

SEA431752

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent Harms.	Olivers
6/30/97		
TIME IN		
0700		
TIME OUT		
DATE	Checking Equipment	LESNIAK
6/30		
TIME IN		
10:45		
TIME OUT		
7-1-97	yard work	
12:00		LJ
1:15		
DATE		
7-2-97	install motor/clutch on #2	[illegible]
TIME IN		[illegible]
1300		Lesniak
TIME OUT		
DATE	WORKING ON #2 CLUTCH/MOTOR	PAULA
7-3-97		T. Elwell
TIME IN	Q&C #2 [illegible] in service.	LESNIAK
0630		Kyrul
TIME OUT	WORKING ON HYDRO TANK LEAKS	
	ALSO	

KCSlip4 63662

SEA431753

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area check	77
7-3-97	Recharge Hydro Tank	
TIME IN	Pump Down Wet Well	
1105		
TIME OUT		
1245		

DATE	Placed #2 P.U. on head will	LESNIAK
7-6-97	monitor at operation today	
TIME IN		
8:15	Installed lube capability to #3 Clutch	
TIME OUT	upper bearing and lubed it.	
	#1 Clutch has damaged plug to lube	
	port so I could not lube the clutch	
	bearing.	

DATE	INSTATION	Blair
7-7-97	SEND ALARMS	
TIME IN		
14:06		
TIME OUT		

DATE	Here To RePair Cord	T. Elwell
7/8/97	on CRANE	
TIME IN	gone Back to Shop To	
0745	get New Cord For Crane	
TIME OUT		
0820	Cord out of stock	
1030	RePaired Old Cord Will	
	ORDER New one For The Crane	

KCSlip4 63663

SEA431754

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Area check	7-7
7-8-97	Station check list	
TIME IN	Exercise Rec Gate	
1405	Area Jumping	
TIME OUT		
1505		

DATE		
7/11/97	Changed chart	Jack Lewis
TIME IN		
0950		
TIME OUT		
1000		

DATE	Station check	7-7.
7-11-97		
TIME IN		
1400		
TIME OUT		
1425		

DATE		
7/14/97	Checked metrotel	
TIME IN		Jack Lewis
0945		
TIME OUT		
1000		

KCSlip4 63664

SEA431755

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Pump Down Wet Well and Hoist.	T.T.
7-15-97	Test Rem All RS N.O.	
TIME IN	Sent Alarm, Pump Truck	
1200	Area Check, Electronics, Hydro	
TIME OUT	Tank, Station Check List	
1250		

DATE	CHECKING PUMPS	STEVE
7-17-97		
TIME IN		
1120		
TIME OUT		
1310		
7-17-97	Lawn work mowing	L.T.

DATE	Station Check.	T.T.
7-18-97 [redacted]		
TIME IN		
1055		
TIME OUT		
1120		
	[illegible]	[illegible]

DATE	Checked Station	[illegible]
7-21-97	Station Checklist.	
TIME IN		
1250		
TIME OUT		
115		

KCSlip4 63665

SEA431756

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
7/21/97	Checked, cleaned and load tested U.P.S.	Kynd
TIME IN		
13:50		
TIME OUT		

DATE		
7/22/97	Here to reset the CPA card on the	Jackson
TIME IN	PLC. Proved ineffective.	
1215	Called Main Control to notify	
TIME OUT	US West.	
1245		

DATE	Area Check Pump Down Well	T-7
7-23-97	Well and Head. Head Pump	
TIME IN	Room Clean	
0820	Silent Alarms	
TIME OUT		
0930		

DATE	CHECKING PUMPING UNITS	STAR
1-25-97		
TIME IN		
1010		
TIME OUT		
30		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check	[illegible]
7-25-97		
TIME IN		
1145		
TIME OUT		
1200		

DATE		
7/28/97	adjusted Metrotel	Jack
TIME IN		Lenz
1100		
TIME OUT		
1110		

DATE	Station checklist. Sent alarms.	[illegible]
7/29/97		
TIME IN		
1300		
TIME OUT		

DATE	checked out and measure	Tom
7/29/97	Air break tank & BFP device	
TIME IN		
2:20 pm		
TIME OUT		

KCSlip4 63667

SEA431758

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE 7-30-97 TIME IN 930pm TIME OUT	Reset all Alarm from power outage. Also could not reset D.C. power failure Alarm will have tech. Look at Ups is reset and working fine.	[illegible]
DATE 7/31/97 TIME IN 6:40 TIME OUT	Replaced 20A fuse for 24V battery charger and slowly brought floating voltage up. Set charger on equalizing charge	Kyal
DATE 7/31/97 TIME IN 0650 TIME OUT	Station check - Exercised R.C.P.s cleaned & swept station. Pumped down wet well.	Oliveros
DATE 7/31/97 TIME IN 0945 TIME OUT	WORKING ON SAC #1 NEW VALVES [illegible], STAMP & HEAD GASKETS	PAULA

KCSlip4 63668

SEA431759

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IN STATION TO REMOVE	BARNEY
8-1-97	WET WELL EXHAUST FAN FROM	
TIME IN	SERVICE, NEED NEW BEARINGS	
0630	and SHAFT	
TIME OUT	out - BACK 0815	
8-1-97	Yard work (spread moving glory)	[illegible]
DATE		
TIME IN		
TIME OUT		
DATE	Insp Eqpt for lubrication Pins	Salazar
8/1/97		
TIME IN		
1:00		
TIME OUT		
0:30		
DATE	Station checklist · Sent alarms.	O'Neil
8/4/97	M.T trash...	
TIME IN		
0740		
TIME OUT		

KCSlip4 63669

SEA431760

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checked station [illegible] RSP's	Olive
8/7/97		
TIME IN		
0650		
TIME OUT		

DATE	Checked and washed station	Kyle
8/11/97		
TIME IN	batteries, set charger on equalizing	
8:50		
TIME OUT	charge.	

DATE	station checklist. Sent alarms.	Olive
8/14/97		
TIME IN		
1250		
TIME OUT		

DATE	Here to install new	Tom [illegible]
8/12/97	CORD ON CRANE	
TIME IN		
0840		
TIME OUT		

KCSlip4 63670

SEA431761

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
8/13/97	[illegible]	[illegible]
TIME IN		
1350		
TIME OUT		
1300		
DATE	Checking Mechanical Equipment	LESNIAK
8/14/97		
TIME IN		
TIME OUT		
DATE	Checked station Pumped down [illegible]	Olwlox
8/14/97	[illegible] exercised R.C.Ps.	
TIME IN		
TIME OUT		
DATE	In station to let US West	CA
8/15/97	in	
TIME IN		
TIME OUT		

KCSlip4 63671

SEA431762

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checked stat[illegible] Sent alarms	Olivers
[illegible]	Changed filter in air handling unit.	
TIME IN		
[illegible]		
TIME OUT		

DATE	Sta[illegible] checked [illegible] pumps	
8/[illegible]		Olivers
TIME IN		
[illegible]		
TIME OUT		

DATE	Verify RSP Data for CAMPS order.	LESNINE
8-21		
TIME IN		
1[illegible]		
TIME OUT		

DATE	Station check	Rick S.
8-22-97		
TIME IN		
TIME OUT		

KCSlip4 63672

SEA431763

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	INSTATION	Blair
8/26/97		
TIME IN	SEND ALARMS	
15:05		
TIME OUT	Roof Drain PLUGGED	
	NO LADDER YET TO GET ON ROOF	
	CHECKLIST	
	AJUST & Hose OUT Packing Drain	
	ON #2 P.U.	
DATE	Checked station. Unplugged roof	Olivers
8/27/97	drain.	
TIME IN		
0950		
TIME OUT		
8-28-97	Yard work (mowing)	G.F.
DATE	Station Checklist. Sent alarms	Olivers
9/2/97	Pumped down wet well	
TIME IN		
1250		
TIME OUT		
DATE	Station Checklist. Sent alarms	Olivers
9/8/97	Cleaned station. Pumped down wet well	
TIME IN		
1220		
TIME OUT		
1		

KCSlip4 63673

SEA431764

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE 9/10/97	Changed chart	Jack Lewis
TIME IN 1220		
TIME OUT 1230		

DATE 9/12/97	Tested inst air compressors and DC volt alarms	Jack Lewis
TIME IN 1015		
TIME OUT 1030		

DATE 9/18/97	Checked out the system	RP
TIME IN		
TIME OUT		

DATE 9/15/97	Station checklist - sent alarms	Olivas
TIME IN 1450		
TIME OUT		

KCSlip4 63674

SEA431765

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	CHECKING MOTORS, CLUTCHES, PUMPS	STEVE
17 SEP		
TIME IN		
1115		
TIME OUT		
1500		

DATE	Station checklist. Sent alarms.	Oliveros
9/22/97	Cleaned & hosed pumproom. N.I. trash.	
TIME IN	Exercised Pumps & wetwell floats.	
	Adjusted packing on # 2 R.S.P.	
TIME OUT		
0915		

DATE	STATION CHECK	Rick S.
9-26-97		
TIME IN		
TIME OUT		

DATE	Station checklist. Sent alarms	Oliveros
9/30/97	Pumped down wet well. Adjusted & cleaned	
TIME IN	# 2 R.S.P.	
0910		
TIME OUT		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Check sump pump for replacement	Mike
10/2/97		D'Ambrosio
TIME IN		
9:45		
TIME OUT		
10:30		

DATE	Station checklist. Sent alarms.	Olivares
10/6/97	Pumped down sump. Hosed & cleaned	
TIME IN	#2 R.S.P packing drain.	
0730		
TIME OUT		

DATE	Checked station. Exercised R.S.P's.	Olivares
10/9/97	Cleaned & hosed pump room. Adjusted	
TIME IN	packing on #2 R.S.P. Pumped down	
1255	wet well.	
TIME OUT		

DATE	Station checklist. Sent alarms	Olivares
10/10/97	Switched service air compressor lead to	
TIME IN	#1.	
0920		
TIME OUT		
10-15	Yard work	L.T.

KCSlip4 63676

SEA431767

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist	Olsen
10/21/97	Adjusted #2 RSP packing	
TIME IN	+ hosed mess	
1450		
TIME OUT		
1550		

DATE	INSTATION With INSPECTOR	Blair
10-23-97	Check Pressure Vessels	
TIME IN		
10:44		
TIME OUT		

DATE	CHECKING PUMPS	STEVE
[illegible]-24		
TIME IN		
1115		
TIME OUT		

DATE	Station checklist - Sent alarms	Olivares
10/28/97	Cleaned & hosed pump room	
TIME IN		
1315		
TIME OUT		

KCSlip4 63677

SEA431768

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Here To PM Slip [illegible]	[illegible]
10/29/97		
TIME IN		
0[illegible]		
TIME OUT		
DATE	Station checklist. Sent alarms.	Oliveros
11/5/97	Pumped down wetwell. Cleaned & hosed	
TIME IN	Pump room	
0800		
TIME OUT		
DATE		
11/6/97	In the station to check the	Jacki Lewis
TIME IN	chart. Found a "Tee" in the odor /	
1030	supply room leaking. Turned off the	
TIME OUT	water which also goes to the sink and	
1100	also turned off the hot water tank.	
	Will report the leak.	
	Tied a plastic bag around problem as an indicator.	
DATE	Here To P.M. Station	Tom Elwell
11/7/97		
TIME IN		
1030		
TIME OUT		

KCSlip4 63678

SEA431769

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms.	Oliver
11/10/97	Pumped down wet well. Cleaned & hosed	
TIME IN	Pump room.	
0650		
TIME OUT		

DATE		
11-10	Repaired water leak in OC room	[illegible]
TIME IN	Turned on PCO	
TIME OUT		

DATE		
11-11-97	Cubes & Consultants in to	[illegible]
TIME IN	look @ the seal water system	
1150		
TIME OUT		
1230		

DATE	PM Station	T. Elm
11/12/97		
TIME IN		
0800		
TIME OUT		

KCSlip4 63679

SEA431770

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
11/13/97	Checked and cleaned station batteries,	Kyul
TIME IN		
11:35	set charger on equalizing change.	
TIME OUT		

DATE	Area Checklist, Sent Alarms	T-T
11-18-97	Station Check	M.O
TIME IN	Pump Down Wet Well	D.Y
1135	Recharge Hydro Tank	
TIME OUT	Hosed [illegible] Clean No. 2 RSP	
1235	Unplugged [illegible] drain.	
	Switch Pump Sequence from a	
	2-3-1 to a 3-1-2	

DATE	CHECKING PUMPS	~~0930~~
19 NOV		STOVE
TIME IN		
0930		
TIME OUT		
1100		

DATE		
11/19/97	Preparing the instrumentation	Jack Lewis
TIME IN	and wiring for a recorder	
1000	change.	
TIME OUT		
1300	Turned off circuit breaker #13	
	to shut off the heater which was	heater OK
	running continuously. will	Jack Lewis
	report problem to the electricians.	

KCSlip4 63680

SEA431771

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
11/19	PM Rain Gauge	[illegible]
TIME IN		
TIME OUT		

DATE		
11/20/97	Replaced the recorder.	[illegible]
TIME IN		
1200	Blue = wet well	
TIME OUT		
1500	Red = Manhole overflow	

DATE	Station checked. Sent alarm	[illegible]
11/25/97	Hosed & pumped down wet well. Exercised	[illegible]
TIME IN	influent - [illegible] Changed out air [illegible]	[illegible]
0745	on ventilating [illegible]	
TIME OUT		

DATE		
11/25/97	SERVICE AIR COMP	J. EVANS
TIME IN		
1330		
TIME OUT		
1500		

KCSlip4 63681

SEA431772

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checked station Exercised R.S.P.	Olivero
11/26/97		Yarno
TIME IN		
1145		
TIME OUT		

DATE	Station checklist. Sent alarms.	Olivero
12/1/97	Hosed pump room & R.S.P. packing drain	Yarno
TIME IN		
1235		
TIME OUT		

DATE	Cleaning lower Two floors	DUANE
12-3-97	etc	
TIME IN		
1115		
TIME OUT		
0400		

DATE	Station Check	T-1
12-5-97		
TIME IN		
1215		
TIME OUT		
1235		

KCSlip4 63682

SEA431773

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Pump room flood alarm	[illegible]
12-7/97	Bubbler purge switch in	
TIME IN	detent position - pulled switch	
00:10	back to normal position.	
TIME OUT	pumped down & closed	
	pump room	

DATE	Station checklist. Sat. alarms.	[illegible]
12/6/97	Unplugged #2 pump packing [illegible]	[illegible]
TIME IN		
1200		
TIME OUT		

DATE	Fixed Assets	[illegible]
12-9-97		
TIME IN		
0725		
TIME OUT		
0800		

DATE	Preparations for work on #2 RSP	LESNIAK
12/9		
TIME IN		
10:00		
TIME OUT		

KCSlip4 63683

SEA431774

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IN STATION TO REPACK # 2	PAULA
12/10/97	RSP	
TIME IN		
0800	NOT GATED YET WILL COME BACK	
TIME OUT	LATER	

DATE	Station Check, Gated No. 2	T.T.
12-10-97	RSP.	M.O.
TIME IN		
0815		
TIME OUT		
1215	CHECKING PUMP	STEVE
	RAULEIGH S. CABED #3 UNIT.	

DATE	Checked and tested UPS.	Idynl
12/11/97		
TIME IN		
9:55		
TIME OUT		

DATE	Area Check	T.T.
12-12-97		
TIME IN		
1035		
TIME OUT		
1055		

KCSlip4 63684

SEA431775

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
12/12/97	Changed the chart. Found the	[illegible]
TIME IN	time/date (annotation) pen	
1345	not functioning. Will	
TIME OUT	replace recorder when a	
1355	new one comes.	
	Recorder is under warranty.	

DATE	Sent Alarms	[illegible]
12-15-97	Station checklist, Area check	
TIME IN	Pump [illegible] West Wall	
0845	Area [illegible]	
TIME OUT		
0932		

DATE	MECH. PM.	PAULA
12/16/97		
TIME IN		
0915		
TIME OUT		

DATE	checking station	[illegible]
12-17-97		
TIME IN		
0800		
TIME OUT		
0845		

KCSlip4 63685

SEA431776

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist, Sent Alarm's	T.T.
12-22-97	Area Chk.	
TIME IN		
1345		
TIME OUT		
1425		
DATE	Area Chk	T.T.
12-26-97	Station Checklist	
TIME IN		
0800		
TIME OUT		
0820		
DATE	Area Chk, Sent Alarm's	T.T.
12-29-97	Station Checklist	
TIME IN	Pump Down Wet Well	
1420	Exercise Influent Valve	
TIME OUT		
1516		
12-31-97	Yard Work	L.T.
DATE	Station Chk.	T.T.
1-2-98		R.S.
TIME IN		
0800		
TIME OUT		
0845		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station checklist. Sent alarms	[illegible]
1/5/98		
TIME IN		
1040		
TIME OUT		

DATE	Station check	7.7
1-9-98		R.S
TIME IN		
0945		
TIME OUT		
1015		

DATE	station check list	DY
1-13-98	hose pump room	MC
TIME IN	send alarms	
1330		
TIME OUT		
1330		

DATE	BACKFLOW TESTING	PAULA
1-15-97	REPLACED TWO [illegible] IN RELIEF	
TIME IN	VALVE	
3845		
TIME OUT		

KCSlip4 63687

SEA431778

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
1/15/98	changed chart	Jack Lee
TIME IN		
1000		
TIME OUT		
1005		
DATE	Station check	Olivera
1/15/98		Yarno
TIME IN		
1130		
TIME OUT		
DATE	Checked the station for the weekend	Nick
1-16-98		
TIME IN		
1435		
TIME OUT		
DATE	Station checklist. Sent alarms	Olivera
1/22/98	Pumped down wetwell.	
TIME IN		
1110		
TIME OUT		

KCSlip4 63688

SEA431779

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	STATION CHECK	Rich S
1-23-98		
TIME IN		
1140		
TIME OUT		

DATE	Station check list	D Yarno
1-26-98	[illegible]	
TIME IN	[illegible]	
1420	pump down [illegible]	
TIME OUT		
1530		

DATE	[illegible] tank	D YARNO
1-27-98	[illegible] at 40	
TIME IN	PSI [illegible]	
1000	[illegible] Sagdan	
TIME OUT	[illegible] out pumps at test	
1100	switch	

DATE	Working on C-2 System - locked out	LESNIAK
1-27	#2 RSP motor because water overflow	
TIME IN	was dripping on it	
11:30		
TIME OUT	Replaced relief valve with proper unit	
	meeting code - per Star Brass. System	
	returned to normal #2 RSP switched	
	back on.	
	Star Brass Works $28001	

583 Apt Wy So. $121.35
Kunkle V ~~P20E01~~ 100 PSI
6010EE01 KM 100

KCSlip4 63689

SEA431780

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
1/28/98	Changed the chart.	[illegible]
TIME IN		
0945		
TIME OUT		
0950		

DATE		Selinger
1/28/98	Perform lube PM on	
TIME IN	RSP Pumps & MTRS	
13:00		
TIME OUT		
1530	all lubes completed as	
	necessary	

DATE	Checked station	[illegible]
1/29/98		
TIME IN		
TIME OUT	Cleared Plug valve & site	[illegible]
	glass in seal water HP	
	Tank, Checks OK	

DATE	STATION CHECK	Rick S.
1-30-98		
TIME IN		
1115		
TIME OUT		

KCSlip4 63690

SEA431781

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check list	D Yakno
2-2-98	Send alarms	
TIME IN	pump wet well	
0830	cleaning as needed	
TIME OUT	hose pump room	
0830	hose wet well	
DATE		
2/3/98	Checked and cleaned station batteries,	Hyd
TIME IN		
7:35	set charger on equalizing charge.	
TIME OUT		
1215	STOVE-CHECKING PUMPS & STUFF	
1445		
DATE	Checking station	D YAKNO
2-5-98		
TIME IN		
1200		
TIME OUT		
DATE	Station check for weekend	
2-6-98		
TIME IN		
1015		
TIME OUT		

KCSlip4 63691

SEA431782

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check list	D YARNO
2-9-98	send alarms	
TIME IN	hose pump room	
1300	pump down wet	
TIME OUT		

DATE	Checking station	D YARNO
2-12-98		
TIME IN		
1100		
TIME OUT		

DATE	[illegible]	[illegible]
2-18-98		
TIME IN		
[illegible]		
TIME OUT		

DATE	Station Checklist	Yarno
2/17/98	Sent alarms	DeBlasi
TIME IN		
1200		
TIME OUT		

KCSlip4 63692

SEA431783

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Checking station with electrical	D YASINO
2-18-98	eng. per Sagen	C.D.
TIME IN		
TIME OUT		

DATE	Station check	T-T
2-20-98	Need [illegible] station	
TIME IN	[illegible] AH4	
0915		
TIME OUT		
0940		

DATE	Station Checklist	D.Y.
2-23-98	Send alarms	
TIME IN	Close pump room etc	
1280		
TIME OUT		

DATE	Area check	T-T
2-24-98	Change filters in AH4 16X25X2	
TIME IN	Outside Jumping.	
1310		
TIME OUT		
1350		

KCSlip4 63693

SEA431784

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
2/27/98	changed the chart	Jack [illegible]
TIME IN		
1125		
TIME OUT		
1130		

DATE	Station Check -	7-7
2-27-98		
TIME IN		
1440		
TIME OUT		
1455		

DATE	Station check list	D YARNO
3-2-98	Send alarms	
TIME IN	hose pump room	
0830		
TIME OUT		
~~3-2-98~~		

DATE	Area Check, Station Checklist	Tim T
3-6-98		
TIME IN		
0745		
TIME OUT		
0825		

KCSlip4 63694

SEA431785

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Checklist	CD
3/9/98	Sent alarms	
TIME IN		
TIME OUT		
DATE	Pressure wash outside	D YARNC
3/12/98	of building	
TIME IN		
TIME OUT		
DATE	Station Chck. Wet Well Ink	Tim T
3-13-98	Fin Needs [illegible]	
TIME IN	Chart Record	
1010	Exchange Friction Tank	
TIME OUT		
1050		
DATE	Station checklist	D. YARNC
3-16-98	send alarms	
TIME IN	pump down [illegible]	
TIME OUT		

KCSlip4 63695

SEA431786

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
3/17/98	Checked and cleaned station batteries,	
TIME IN		
7:50	set charger on equalizing charge.	Kyal
TIME OUT		
DATE	Weekend shotgun check	[illegible]
3-20-98	" " "	
TIME IN	Air Handling Fan 773101A - Noisy	
1100		
TIME OUT		
DATE	Station Check list	D. YARNO
3-24-98	Send alarms	
TIME IN	Low wet well	
	& low pump room	
TIME OUT		
DATE		
3/24/98	Test a [illegible] power [illegible]	[illegible]
TIME IN		
1215		
TIME OUT		
1230		
3-26-98	[illegible]	[illegible]

KCSlip4 63696

SEA431787

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check,	T & T
3-27-98	outside pumping	
TIME IN		
1045		
TIME OUT		
1130		
	Instrument Air Regulator	
	leaking Air. W/O	

DATE		
3/30/98	Checked the chart	[illegible]
TIME IN		
1430	checked inst. air regulator.	
TIME OUT	[illegible] 0.15	
1440	Slight air leaking [illegible]	
	[illegible]	

DATE	Station checklist	CD
3/31/98	Seal Alarms	DY
TIME IN		
0845		
TIME OUT		

DATE	in station with insurance	D. YARNO
3-31-98	adjuster	
TIME IN		
TIME OUT		

KCSlip4 63697

SEA431788

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	HERE TO PM Slip Rings	Tom Ekell
4/2/98	+ Bushes	
TIME IN		
0720		
TIME OUT		
0915		

DATE	CHECKING PUMPS	STEVE
2 APR 98		
TIME IN	PLEASE LEAVE #3 IN 2ND	
1215	FOLLOW	
TIME OUT		
1500		

DATE	IN STATION TO CHECK #3 RSP	Barry
4-3-98		
TIME IN		
0955		
TIME OUT		

DATE	Station Check, Adjusted Chart	T. T.
4-3-98	Recorder Paper.	
TIME IN	W/O for No. 3 RSP.	
0810		
TIME OUT	Keep No. 3 RSP in 2ND follow	
0900		

KCSlip4 63698

SEA431789

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	[illegible]	[illegible]
[illegible]	Sent [illegible]	[illegible]
TIME IN		
[illegible]30		
TIME OUT		

DATE		
4/6/98	Checked and adjusted charger,	Hyrel
TIME IN		
11:35	tested WPS.	
TIME OUT		

DATE	Station Check Noted No.3 RSP - OFF	C.D
4-7-98		T-T
TIME IN	Coupled [illegible]	
0645	with [illegible]	
TIME OUT	[illegible]	[illegible]
[illegible]05	[illegible] to check unit [illegible]	[illegible]

DATE	CHECKING #3	STEVE
8 APR 98		
TIME IN		
1345		
TIME OUT		
1530		

KCSlip4 63699

SEA431790

East Marginal Pump Station

	DESCRIPTION OF WORKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Power Outage at Station	T T
4-9-98	City Power Back in Service	L. D
TIME IN		
0630		
TIME OUT		
0730		

DATE		
4/9/98	Checked the operation of Transfer	Hyal
TIME IN	switch. There is a time delay of 2 min	
6:35		
TIME OUT	We did not wait long ~~enough~~ enough.	

DATE	Station Check	T. T
4-10-98	Wet Well Level at 94.9	
TIME IN	Purge Bubblers	
0720		
TIME OUT		
0755		

DATE	Checking CONTROL BATTERIES	Tim Ekell
4/10/98	AND Charger	
TIME IN		
0920		
TIME OUT		
1005		

KCSlip4 63700

SEA431791

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check list	[illegible]
4/13/98	Send alarms	
TIME IN		
0830		
TIME OUT		

DATE	Station check Dumped Trash	T [illegible]
4-14-98	Pump Down Wet Well	[illegible]
TIME IN		
0825	New Pump Sequence 3-1-2	[illegible]
TIME OUT		
0915		
4-15-98	[illegible] work	LT

DATE	Station check	T [illegible]
4-17-98	Purge Bubbler, Wet Well at 94.6	
TIME IN		
0950		
TIME OUT		
1025		

DATE	Station check list	D VARRO
4/20/98	Send alarms	
TIME IN		
1400		
TIME OUT		

KCSlip4 63701

SEA431792

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Replaced belt on motor room	
7-21	exhaust fan	Green
TIME IN		
10:00	Loaded up and took away	
TIME OUT	scrap flap gate	

DATE	Station Check.	Tim T
4-21-98		
TIME IN	Change Filter's in Air	
1100	Ventilating Unit.	
TIME OUT		
1130		

DATE	Checking Station Flow and	T=T
4-23-98	Wet Well level, 94.6	
TIME IN		
0935		
TIME OUT		
0950		

DATE	Station Check, Empty Area Trash	Tim T
4-24-98	Pump Building	
TIME IN		
0900	Wet Well level at 94.6	
TIME OUT		
0935		

KCSlip4 63702

SEA431793

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check lists	D YARNO
4-27-98	Send alarm	
TIME IN	hose pump room	
0900	pump down w/ well	
TIME OUT	clean outside	

DATE		
5-1-98	Changed to [illegible]	[illegible]
TIME IN		
0850		
TIME OUT		
[illegible]		

DATE	Station check.	T-T
5-1-98	Purge Bubblers	
TIME IN	Pump Room Wet well	
1115		
TIME OUT		
1145		

DATE	Station check list	D YARNO
5-5-98	send alarm	
TIME IN	house cleaning	
0730	[illegible]	
TIME OUT	near wet well	

KCSlip4 63703

SEA431794

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
5/7/98	Replaced the DC Batteries	[illegible]
TIME IN		
0950		
TIME OUT		
1010		

DATE	Im Station to Test Run	Tim T
5-7-98	Trailer Mounted Generator	
TIME IN		
0955	Transfer Switch Not Working	
TIME OUT		
1300	W/O.	

DATE	Station Check, Purge Bubbler	Tim T
5-8-98	Recharge Hydro Tank.	
TIME IN		
0700	Wet Well level at 94.6	
TIME OUT		
0745		

DATE	Station check lock	N. YARNO
5-11/98	Send alarms	
TIME IN	hose pump room	
0900	clean out sude	
TIME OUT		

KCSlip4 63704

SEA431795

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check	T&T
5-15-98		
TIME IN		
1330		
TIME OUT		
1345		
DATE		D YARNO
5-18-98	Station check list	
TIME IN	pump down w/w	
0830	hose pump room	
TIME OUT	sent alarms	
DATE	Gather Data for CAMPS #3 RSP	LESNAK
5/18/96	Impeller replacement	
TIME IN		
9:30		
TIME OUT		
DATE		
5/19/98	Checked station batteries, set charger	Kynl
TIME IN		
9:30	on equalizing charge.	
TIME OUT		

KCSlip4 63705

SEA431796

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Hose To PM Station	Tom Ewell
5-19-98		
TIME IN		
1245		
TIME OUT		
3:00	Installed New Rain Gauge	Payton

DATE		
5/28/98	Performed an inst. P.M.	Jack Lewis
TIME IN		
1200		
TIME OUT		
1500		

DATE		
6/1/98	changed chart.	Jack Lewis
TIME IN		
1110		
TIME OUT		
1120		

DATE	Station check list	D. YARNO
6-1-98	Send alarms	
TIME IN	pump & hose w/w	
1100	hose pump room	
TIME OUT	flushed hydro tank	

KCSlip4 63706

SEA431797

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
~~1000~~ 6/2/98	Replaced the inst. air PRV above	Jack Lewis
TIME IN	the inst. air compressors	
1000		
TIME OUT		
1320		

DATE	Station Check, Shut Down Station	Tim T
6-2-98	So Inst Tech could change	
TIME IN	PRV	
1210	Change Filter's in Air Ventilating	
TIME OUT	Unit.	
1330	Pump Down Wet Well.	

DATE		Salazar
6/3/98	here to lube Fans	
TIME IN		
12:30		
TIME OUT		

DATE	Station check list	D YARNO
6-8-98	Send alarms	
TIME IN		
1030		
TIME OUT		

KCSlip4 63707

SEA431798

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check.	Tim T
6-12-98	Adjusted Chart Recorder	
TIME IN		
0835	Purge Bubblers	
TIME OUT	Wet Well level at > 94.6	
0905		

DATE	Station check list	D. YARNO
6-15-98	Send alarms	
TIME IN	have pump room	
1450		
TIME OUT		

DATE	HERE TO P.M. STATION	Jim Elwell
6/17/98		
TIME IN		
1120		
TIME OUT		

DATE	Load tested UPS.	Kyel
6/18/98		
TIME IN		
13:50		
TIME OUT		

KCSlip4 63708

SEA431799

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check	Tim T
6-19-98	Outside Lamping	
TIME IN	Wet Well level at 94.6	
0750	Pump Bubblers	
TIME OUT		
0820		

DATE	STATION CHECK	PAULA
6/23/98		
TIME IN		
1130		
TIME OUT		

DATE	Station Checklist	Tim T
6-23-98	Sent Alarms	
TIME IN	Area Check	
1255		
TIME OUT		
1340		

DATE	Station check	D. YARNO
6-25-98	pump down w/w	
TIME IN	hose w/w	
1300	lamping	
TIME OUT		

KCSlip4 63709

SEA431800

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check for weekend	[illegible]
6-26-98		
TIME IN		
1700		
TIME OUT		

DATE	Starting check list	D. YARNO
6-29-98	Send alarms	
TIME IN	hose pump room	
1130	hose & pump down w/w	
TIME OUT	Send alarms etc	

DATE	In station to help Ed Cox group	D. YARNO
6-30-98	with checking flap valves on	
TIME IN	effluent & influent gates	
0800	1 gate missing, 1 gate fallen off	
TIME OUT		

DATE	Crane Inspections	J Hopkins
6-30-98		
TIME IN		
12:00		
TIME OUT		
12:20		

KCSlip4 63710

SEA431801

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check	Tim T
7-2-98	Purge Bubblers	
TIME IN	Wet Well level at 94.6	
1030	Pump Down Wet Well	
TIME OUT	Recharge Hydro Tank	
1130		

DATE	Remove Flap Gate from #1 RSP	LESNIAK
7/5	discharge pit	GREEN
TIME IN		YARNO
6:40		
TIME OUT		

DATE	Station Check list	D YARNO
7-6	Send alarm	
TIME IN	hour pump room	
	pump W/W, hour	
TIME OUT		

DATE	IN STATION TO CHECK A.C'S	GREENE
7/6/98		
TIME IN		
1350		
TIME OUT		
1430		

KCSlip4 63711

SEA431802

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station closed for the weekend	
7-10 98		
TIME IN		
1900		
TIME OUT		

DATE	Station check list	O. YARNO
7-14 98	Test alarms	
TIME IN	hoed pump room	
1400	house cleaing	
TIME OUT		

DATE	Checking #2 Clutch	LESNIAK
7-15		
TIME IN		
TIME OUT		

DATE	Starting Cycle	Tim T
7-17-98	Purge W/ Air Bubbler	
TIME IN		
1105	New Pressure Vessel	
TIME OUT	Certificate	
1150		
	Wet Well level at → 94.6	

KCSlip4 63712

SEA431803

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check list	D. YARNO
7-27-98	Send alarm	
TIME IN	~~hose~~ hose pump room	
1200	pump down w/w	
TIME OUT		

DATE		
7/27/98	Changed the chart.	Jack [illegible]
TIME IN		
1400		BK
TIME OUT		
1410		

DATE	Station Check	Tim T
7-31-98	Pump Bubblers	
TIME IN	Test Pan RSP.	
0915	Wet Well level at 94.2	
TIME OUT		
1015		

DATE	Station check list	D. YARNO
8-3-98	Send alarms	
TIME IN	hose pump room	
1300	pump down w/w	
TIME OUT		

KCSlip4 63713

SEA431804

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Lube RSP motors, clutches & Pumps	Schlosser
8-5-98		
TIME IN		
TIME OUT		

DATE	Station Check	Tim T
8-7-98	Wet Well level at 94.6	
TIME IN		
1240		
TIME OUT		
1305		

DATE	Station check list	D. YARNI
8-14-98	Send alarm	
TIME IN	Lose pump room	
1130		
TIME OUT		

DATE	Station Check	Tim T
8-14-98	Wet Well level at 94.5	
TIME IN	Recharge Hydro Tank.	
0735		
TIME OUT		
0825		

KCSlip4 63714

SEA431805

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check list	D. YARNO
8-17-98	Send alarms	
TIME IN	check & hose w/w	
1215	hose pump room	
TIME OUT	Switchead leads 1-2-3	

DATE		
8-20-98	ON SITE W/ HAWK MECH TO	D Rossett
TIME IN	SURVEY FOR SUMP PUMP PIPING..	
1105		
TIME OUT	WP NOTIFIED.	
11 20		

DATE	Station check	D. YARNO
8-20-98		
TIME IN		
1200		
TIME OUT		

DATE	Station check list	D. YARNO
8-24-98	Send alarms	
TIME IN	hose pump room	
1200		
TIME OUT		

KCSlip4 63715

SEA431806

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
8/24/98	Checked and cleaned station batteries,	Hyal
TIME IN		
12:50	set charger on equalizing charge.	
TIME OUT		

DATE		
8-26-98	Salt test	Hopkins Jones
TIME IN		
8:10		
TIME OUT		

DATE	Station check	Tim T
8-28-98	West Wall level at -94.8	
TIME IN	Purge Bubblers	
1115		
TIME OUT		
1150		

DATE	Station check list	D. YARNO
8-31-98	Send alarms	
TIME IN	Low pump room	
1030	pump down w/o	
TIME OUT		

KCSlip4 63716

SEA431807

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
8/31/98	changed chart.	Jack Lewis
TIME IN		
1230		
TIME OUT		
1240		
DATE		
9/2/98	Sent alarms.	Jack Lewis
TIME IN		
1215		
TIME OUT		
1315		
DATE	Station check	Tim T
9-4-98	Wet Well level at → 94.8	
TIME IN	Purge Wet Well Bubbler's	
1100		
TIME OUT		
1135		
DATE	Station check list	O. YANNO
9-8-98	Send alarm	
TIME IN	pump down w/n	
1100	change pump sequence 2-3-1	
TIME OUT	hose pump room	

KCSlip4 63717

SEA431808

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	IN STATION FOR MECH	BARNEY
9-11-98	PM	
TIME IN		
0800		
TIME OUT		

DATE	Station Check	T=T
9-11-98	Purge Wet Well Bubbler's	
TIME IN	Wet Well level at 94.9	
1000		
TIME OUT		
1030		

DATE	Station check list	D. YARNO
9-14-98	Send alarms	
TIME IN	Lose pump room	
1000		
TIME OUT		

DATE		
9/17/98	Installed new sprinkler controler.	Kyal
TIME IN		
11:00		
TIME OUT		

KCSlip4 63718

SEA431809

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check	Tim T
9-18-98	Wet Well level at 94.9	
TIME IN	Purge Bubbler's.	
1000		
TIME OUT		
1040		
1115	STEVE - CHECK UNITS	
1345		

DATE	Station check list	D. YARNO
9-22-98	Send alarms	
TIME IN	Lose basement	
0800	clean out yard	
TIME OUT		

DATE	Recharge Hydro Tank.	Tim T
9-22-98	Station Check.	
TIME IN	Exercise Influent Gate	
1215	Check Float's in Wet Well	
TIME OUT		
1320		

DATE	Station check	D. YARNO
9-24	Lose pump room	
TIME IN	House cleaning	
1145		
TIME OUT		

KCSlip4 63719

SEA431810

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check	T. T
9-25-98	W.T. Well level at 94.9	
TIME IN		
0830	Purge Bubblers	
TIME OUT		
0915		

DATE		
9/28/98	Checked and cleaned station batteries,	Jdyal
TIME IN	set charger on equalizing charge.	
8:30		
TIME OUT		

DATE	Station check list	D. YARNO
9-28-98	Send alarms	
TIME IN	pump down w/w	
1300	hose pump room	
TIME OUT		

DATE	Station check list	D. YARNO
9-30-98	pump down w/w	
TIME IN		
1400		
TIME OUT		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station Check	Tim T
10-2-98	Wet Well level at 94.9	
TIME IN	Purge Bubblers.	
1300		
TIME OUT		
1340		

DATE	Station check list	P. YARNO
10-5-98	Send alarms	
TIME IN	Honey pump room	
1400	check wet well	
TIME OUT	pump down w/w	

DATE	Station check	D. YARNO
10-6-98	pump w/w	
TIME IN		
1400		
TIME OUT		

DATE	Let Superior Fire Extinguisher take Fire Extinguisher	Mike
10-7-98	to schmid	
TIME IN		
1130		
TIME OUT		

KCSlip4 63721

SEA431812

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
10/8/98	Replaced belt on W.W. E.F	Green
TIME IN		
TIME OUT		
DATE	Station Check Purge Bubbler's	Tim T
10-9-98	Wet Well level at 95.0	
TIME IN		
1145		
TIME OUT		
1220		
DATE	Station check list	A. YARNO
10/15/98	Send alarms	
TIME IN	Lose base mest - pump room	
0900		
TIME OUT		
	* Limit. air compressor ?	
	switched loads	
DATE	Station Check	T-T
10.16.98	Wet Well level at 95.0	
TIME IN	Purge Bubbler's	
1030		
TIME OUT		
1140		

KCSlip4 63722

SEA431813

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Reset PLC per W.P.	Eleanor
10-19-99		
TIME IN		
1130		
TIME OUT		

DATE		
10/19/98	Reset the PLC and UPS.	Jack Lewis
TIME IN		
0830		
TIME OUT		
0910		

DATE		
10/19/98	Disconnected motor for RAP #3.	Kyle
TIME IN		
7:30		
TIME OUT		

DATE	Station check list.	D. YARNO
10/20/98	Send alarm	
TIME IN		
0700		
TIME OUT		

KCSlip4 63723

SEA431814

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Working on RSP #3 clutch &	Barney
10-20-98	motor	
TIME IN		
0915		
TIME OUT		

DATE	CHECKING SAC 1 & 2	GREENE
10/20/98		
TIME IN		
1000		
TIME OUT		

DATE		
10/21	Remove #3 motor + clutch	Green
TIME IN		Barney
TIME OUT	Exhaust Fan for Wet Well	Tim T
	Not Working W/O.	
	Reset UPS	
	Check Telemetry	Lyton

DATE	Starting Check.	
10-23-98	Wet Well level at 94.9	
TIME IN	Purge Bubblers	
0910		
TIME OUT		
0940		

KCSlip4 63724

SEA431815

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	station check list	D. YARNO
10/26/98	Send alarms	
TIME IN	Home pump room	
	pump down w/c	
TIME OUT		

DATE		
10/27/98	Deliver + install #3	Green
TIME IN	Motor + clutch	Barney
		Lishinlah
TIME OUT	completed + ready to be wired	

DATE		
10/27/98	Connected motor for RSP #3 and	Kyrd
TIME IN		
13:55	tested. Sounds good.	
TIME OUT		

DATE	Put No. 3 RSP in Service	Tim T
10-28-98	for Maintenance to Check	
TIME IN		
0725	Purge Bubbler's	
TIME OUT		
0810	Pump Sequence 3-2-1	
	checked #3 motor + clutch.	
	There is a clacking sound inside	Green
	of clutch. I will discuss it with Jim.	

KCSlip4 63725

SEA431816

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
10/28/98	Checked and tested WPS.	Kyal
TIME IN		
8:25		
TIME OUT		

DATE		
10-28-98	Change oil on compressors.	Salvyan
TIME IN		
10:00		
TIME OUT		

DATE	Checking out #3 Motor/Clutch	LESNIAK
10/28	Overhaul. Clicking sound could	
TIME IN	be a piece of insulation from coil	
1:30	windings. We will monitor it	
TIME OUT	Unit works & sounds beautifully	
	otherwise.	

DATE	Station check	D. YARNO
10-28 98		
TIME IN		
1400		
TIME OUT		

KCSlip4 63726

SEA431817

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check	O. YAKNO
10-29-98		
TIME IN		
0700		
TIME OUT		
DATE		
TIME IN		
TIME OUT		
DATE		
TIME IN		
TIME OUT		
DATE		
TIME IN		
TIME OUT		

KCSlip4 63727

SEA431818

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
10/29	Repaired W/W Exhaust fan	Payton
TIME IN		
TIME OUT		
DATE	Station Check	T=T
10-30-98	Wet Well level at 94.6	
TIME IN	Purge Bubbler's	
0925		
TIME OUT		
0955		
11:30	Reset UPS Alarm	Payton
	3-2-1	
DATE	station check test	N. YARNO
11-2-98	Send alarms	
TIME IN	hose pump room	
0800	hose w/c	
TIME OUT		
DATE	Reset U.P.S	S.L
11-3-98	Purge Bubbler's	T=T
TIME IN		
0725		
TIME OUT		

KCSlip4 63728

SEA431819

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Asset Check	Jeger
11/4		Wegener
TIME IN		
1115		
TIME OUT		
DATE	Follow up check on Motor/Clutch #3	LESNICK
11/5/98		
TIME IN		
1:45		
TIME OUT		
DATE	Station Check.	T=T
11-6-98	Pump Rubber	S.L
TIME IN		
1000	Wet Well level — 94.6	
TIME OUT		
1030		
DATE	Station check list	D YARNO
11-9-98	Send alarms	
TIME IN	hose basement	
1400	hose w/w	
TIME OUT	pump down w/w	

KCSlip4 63729

SEA431820

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Hose To Check. Slip	
1/10/98	Rings + Brushes	
TIME IN		
0915		
TIME OUT		

DATE	Station check	T=T
11-13-98	Recharge Hydro Tank.	
TIME IN	Purge Buddies	
0705		
TIME OUT	Wet Well level at 94.6	
0900		
	Lamping in Wet Well	
	Exercise Influent Gate	

DATE	Station check list	D. VARNO
11-16-98	Send alarms	
TIME IN	Lose pump room	
0830	pump down w/o	
TIME OUT	Change ~~pen~~ blue pen in chart	

DATE	Station Check	T=T
11-20-98	Purge Buddies	
TIME IN	Wet Well level at 94.8	
0950		
TIME OUT		
1030		

KCSlip4 63730

SEA431821

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check least	D. YARNO
11-27-98	Send alarms	
TIME IN	Low basement	
0830		
TIME OUT		

DATE	Station check.	T-T
11-25-98	Wet well level at 98.00	
TIME IN	Two Pump's Running.	
1315	Purge Buttons.	
TIME OUT		
1325	[Roof Leaking W/O]	

DATE	Station check	D. YAKUTO
11-25/98		
TIME IN		
1400		
TIME OUT		

DATE	Lube station fans	Salazar
11-30-98		
TIME IN		
1000		
TIME OUT		

KCSlip4 63731

SEA431822

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Station check list	D. YARNO
11-30-98	Send alarm	
TIME IN	hear equipment	
1200	Switch leads to 1-2-3	
TIME OUT	check w/c	

DATE		
11/30/98	Checked and cleaned station batteries,	Kyul
TIME IN	set charger on equalizing charge.	
13:40		
TIME OUT		

DATE	Station Check, Pump Down	Tim T
12-3-98	Wet Well, Purge Bubblers	
TIME IN	Wet Well level at 94.9	
0730		
TIME OUT		
0845		
12-4	STEVE - CHECKING R.S.P.S.	
	12:00 - 2:00P	

DATE	Station check list	D. YARNO
12/7/98	Send alarm	
TIME IN	hear pump room	
1200		
TIME OUT		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Survey for Sump Pump	Schlatter
12-7-98	Replacement Contract	
TIME IN		
1430		
TIME OUT		
1440		
DATE	Hawk Mechanical on site for	Schlatter
12-8-98	Sump Pump Replacement Contract	
TIME IN	work. Locked out / Removed existing sump pump.	
1035	Temp Sump Pump installed and	
TIME OUT	in use.	
1445		
DATE	Hawk Mechanical - Sump Pump	Schlatter
12-9-98	Replacement contract work.	
TIME IN	New sump pump installed and in	
0700	operation.	
TIME OUT		
1345		
DATE	Reset UPS per MCC	D. YAHNO
12/9/98	Cleaned drain on roof	
TIME IN		
1400		
TIME OUT		

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Hawk Mechanical - Sump Pump Replacement	Schlatter
12-10-98	contract. Pick up tools - demob.	
TIME IN		
0700		
TIME OUT		
0735		

DATE	Station Check	Tim T
12-11-98	Wet Well level → 95.2	
TIME IN	Purge Bubbler's	
1030		
TIME OUT		
1105		

DATE	Station check list	J. YARNO
12/14	Send alarms	
TIME IN	hose pump room	
1130	check & hose w/u	
TIME OUT	~~[illegible]~~ Run other pumps	

DATE	Station Check	Tim T
12-15-98	Change Filter's in Ventilation	
TIME IN	Unit	
1210	Purge Bubbler's	
TIME OUT		
1250		

KCSlip4 63734

SEA431825

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	Dunkirk Bush painting Contractors -	Burns
12-18-98	paint sump pump piping	
TIME IN		
0800		
TIME OUT		
1035		

DATE	Station check.	T-T
12-18-98	Pump Building &	
TIME IN	Wet Well level at 94.9	
1325		
TIME OUT	Test Pom RSP's	
1350		

DATE	Called out to check Station on	B.F.
12-19-98	Telemetry & UPS Fail.	
TIME IN	(Station ok) Had to reset	
20:45	telemetry fail & UPS.	
TIME OUT	Wet well 94.9 & #1 RSP on.	
	Telemetry fail keeps comming on	
	Notified W.P.	

DATE	Called out on U.P.S. Fail	B.F.
12/20/98	Reset ok. Notified W.P. THAT	
TIME IN	it should be checked out by	
0730	elect. Also Telemetry fail still	
TIME OUT	exists. Station (operating ok.)	

KCSlip4 63735

SEA431826

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE		
12/4/98	Checked UPS, charger is not working	Thyal
TIME IN	well. Will replace. Reset Telemetry.	
6:40		
TIME OUT		
	Installed new control board for	
	the charger.	

DATE	station check list	D. YARNO
12-21-98	purged bubbler	C. DeB.
TIME IN	Send alarms	
1000	hose cleans	
TIME OUT		

DATE	Checking Station	D. YARNO
12/23/98		
TIME IN		
1330		
TIME OUT		

DATE	station check list	D. YARNO
12-28	Send alarms	
TIME IN	pump down w/w	
1100	hose pump room	
TIME OUT		

KCSlip4 63736

SEA431827

East Marginal Pump Station

	DESCRIPTION OF TASKS, EVENTS, PROBLEMS, OR OBSERVATIONS SEEN OR PERFORMED	NAMES
DATE	New 1999 Log Book in Station	Tim T
12-30-98		
TIME IN		
1320	Wet Well level at 94.9	
TIME OUT		
1335		

DATE		
12/31/98	changed chart.	Jack Lewis
TIME IN		
1115	collected old chart for the	
TIME OUT	archives.	
1130		

DATE	Station Checking Purge Bubblers	Tim T
12-31-98	Wet Well level at 95.8	
TIME IN		
1405		
TIME OUT		
1435		

DATE		
TIME IN		
TIME OUT		