BOEING PLANT

1963

RECORD

KCSlip4 69632

SEA437723

Meter reading 2519

KCSlip4 69633

SEA437724

Received
2-5-63 4 Tanks Chlorine

No. #43312 = Sent Back - 2-28-63
#57245 = Sent Back - 4-4-63
#34810 = sent Back - 4-4-63
#56297 = Sent Back - 5-22-63

Received
2-28-63 1 Tank Chlorine
No. 54365 = Sent Back = 4-4-63

Received
4-4-63 3 Tanks Chlorine
No #50299 - Sent Back - 5-22-63
#43506 Sent Back = 5-22-63
#54896 - Sent Back = 7-11-63

Received
5-22-63 3 Tanks Chlorine
No. #54690 - Sent Back 8-22-63
#56724 - Went to Cascad Vista
#55069 - Sent Back - 9-24-63

Received
- 11-63 1 Tank Chlorine
No. 57801 Sent Back 8-22-63

Received
-22-63 2 Tanks Chlorine
No. 45613 sent Back - 9-24-63
No: 47797 - sent Back

24-63 2 NEW CHLORINE TANKS
No. 52767 sent Back
No. 52453 sent Back

28-63 2 New Chlorine Tanks
No. - 43853 sent Back
No. - 57550 - Sent To Cascade

February 63

Feb 1-63 Hilson — took over plant today pumped sludge ran lab. washed down tanks cleaned water screens on chlorinator and cleaned orfice in chlorinator, cleaned pump wet well.

2-2-63 Hilson — Pumped sludge washed down tanks, sump in floor was running over. took up on packing on #2 and #3 pumps, cleaned pump wet well was here from 10 AM to 12:00

2-3-63 Hilson — Pumped sludge washed tanks put oil in both filter arms cleaned out pump wet well pumped out sump in floor at 10:00 and 11:55 was here from 10:00 AM to 12:00

2-4-63 Hilson — Pumped sludge washed down tanks, ran lab. No 2 pump stoped, opened hole at bottom of pump and took out some rage wast, seems O.K. know, Maintanence men put in water meter today. Cleaned pump wet well, started to wash wall in bath room, added 100# lime to Digester

2-5-63 Wilson Pumped Sludge washed down tanks. ran lab, Cross ~~here to do some~~ wireing for pumps, Wendy here and changed water line. cleaned pump wet well and helped both Wendy & Cross

2-6-63 Wilson Pumped sludge washed tanks down ran lab. Jim from Renton plant here showed him what the duties are. worked up rock in No 1 filter so it will not pond, cleaned pump wet well, pumped sludge befor going home.

2-7-63 Wilson Pumped sludge, washed tanks down, Al. Woods came and we pulled No 1 sump pump was plugged with rages back in by 9:30 A.M. works O.K. now. ran lab, moved sludge from one bed to the other and pumped sludge from digester, cleaned sump pump wet well, pumped out floor sump, pumped sludge to digester befor going home

2-8-63 Wilson

Pump Sludge, ran lab, pump sludge from digester to pits, Cross and Windy both here to put in sump pump did not get it done cleaned pump wet well pump out sump, pumped sludge befor going home

2-9-63

2-10-63

2-11-63 Pumped Sludge then started
Hilson to dig dick for Eff. line
Woods was here helping too.
Ran lab, cleaned pump
wet well, washed down
tanks pumped Sludge
befor going home,

2-12-63 Night man put on a new
Hilson tank of Chlorine, No. 43312
Pumped Sludge ran lab,
Buckley was here to check
on effluent line, we will fill
up dick and lay pipe on
top, so started to fill dick
pump Sludge befor going home

2-13-63 Pumped sludge, flow meter
Hilson was not working, repaired same
Wood's was over and we filled
in the dick, ran lab, washed
some windows, cleaned pump
wet well, and pump sludge befor
going home there was a power
failer Cross was here and he
could not find anything wrong
switch to the other line and
it was O.K. then called
Renton plant and reported it
when I got home,

2-14-63 Pumped sludge, washed down
Wilson tanks, washed windows,
Willis called Boeing plant and
got the power back to the
other line so switched back
to main line at 9:45 A.M.
ran lab, cleaned up paper in
yard, Woods came over and
we took the old black logs
out to the gate, cleaned pumps
in well, pumped sludge
befor going home, checked
wet well pumps No 1 was plugged
went over to Renton plant
and Woods came back with
me and we pulled the pump
it was full of rags.
1 hr, over time,

2-15-63 Pumped sludge washed down
Wilson tanks, both wet well pumps
stoped pumping, went to
Renton plant and called Willis,
Woods came and we pulled
No 1, not a thing in it
both pumps are locked
changed floats so No 2
pump going on first to
see if it will work better,
ran lab, cleaned pump
wet well greased all equip.
washed floor, pumped sludge
befor going home,

KCSlip4 69640

SEA437731

2-16-63

2-17-63

KCSlip4 69641

SEA437732

2-18-63 Hilson — Pumped Sludge, washed tanks down, Ran lab. cleaned up part of the Chlorinator. cleaned out pump wet well. No 2 pump partly plugged, reported it to Willis. Went over to Renton plant to help Woods change Effluent line to new sewage line got back at 3:45 changed clothes and went home.

2-19-63 Hilson — Pumped Sludge, washed tanks down, Ran lab. Woods came over and we pulled out No 1 pump was plugged with rags. started to wash wall in office, cleaned out pump wet well. pumped sludge befor going home

2-20-63 Hilson — Pumped Sludge, washed down tanks, Ran lab washed on wallsin office. Wood's came over at 12:00 and we started to get the Effluent line ready to hook up to the new sewage line.

2-21-62 Wilson Pumped sludge washed tanks down Ran lab, Woods helped me I got down in pump wet well and cleaned it out, Helped maintanance men most of the day 2:45 had to pull No 2 wet well pump was full of rags pump sludge stayed till 5:00 O'clock to help get Effluent line in.

2-22-62 Wilson Pumped sludge washed down tanks 8:30 went to Renton plant so Woods could go and check pump station Ran lab, put check valves back in overflow line 2:00 PM went over to Renton plant so Woods could go and check pump station cleaned up pump room and office pumped sludge befor going home

2-23-63

2-24-63

2-25-63 Wilson — A New tank of Chlorine was put on the line at 5:30 AM by Jim No 57245. Pump Sludge washed tanks down, Ran lab, went with Willis to the new plant back at 11:45, pump sludge cleaned up dirt along Effluent pipe, cleaned pump wet well Wendy was here to work on sump pump, pumped sludge befor going home

2-26-63 Wilson — Pumped Sludge washed down tanks, ran lab, Wendy was here and finished putting in sump pump, Cross will have to wire it yet, pump out scum box, cleaned up pump room, cleaned pump wet well, night man said light switch by outer door hogwire, check it out it is O.K. light comes on when yardlights go on, pumped sludge befor going home

2-27-43 Pumped sludge washed tanks down, Ran lab, cleaned out one sludge bed and started to draw sludge from digester, put some sludge on lower and flower beds cleaned pumps out well, pumped sludge befor going home
Wilson

2-28-43 Pumped sludge washed down tanks Ran lab drawing sludge from digester cleaned filters in chlorinator cleaned pumps out well, made out monthly report to go to Willis got one new tank of Chlorine no 54345 tank no 43317 was sent back, Al and Joe where here so I showed them how to make the sump pumps work pumped sludge befor going home
Wilson

KCSlip4 69646

SEA437737

March 63

3-1-63 Hilson Pumped Sludge washed tanks down Ran lab, cleaned out grease in pit by communotor man here from Boeing to look at water meter they think they have it in the wrong place. Woods came over and we pulled no. 2 wet well pump it had rags in it A Engineer from Boeing came and picked up the slip for the chlorine tank that was returned cleaned pump wet well and pumped Sludge befor going home

3-2-63

3-3-63

KCSlip4 69647

SEA437738

3-4-63 Wilson — Pump sludge washed tanks down Ran lab, put some sludge through the grinder to put on lawn Cross was here and hooked up the float switch for the sump pump, cleaned pump wet well. Woods came over and we hauled out the old black top. pumped sludge befor going home,

3-5-63 Wilson — pumped sludge washed tanks down Ran lab, went over to Ruston plant. and got lawn mower and cut the grass, and put sludge on part of the lawn, Cross here and put out let in wash room cleaned pump wet well pumped sludge befor going home

3-6-63 Hilson Pumped sludge washed tanks down Ran lab. Woods came over and got the lawn mower Put some sludge on the lawn went with Willies to new plant site to put plugs in sewage line but did not get it done cleaned pump wet well and pumped sludge befor going home

3-7-63 Pumped sludge washed tanks down went with Al. Woods to work in new pipe line but did no good, Ran lab. put lime on lawn went back to new plant site to start 1 pump ~~cleaned pump~~ wet well, pump sludge befor going home

3-8-63 Hilson Pumped sludge washed down tanks Ran lab. pumped out scum pit, put chlorben on 1st. filter for ponding. filled in ditch by effluent pipe ~~pulled~~ No 1 wet well pump full of rags cleaned wet well pumped sludge befor going home

KCSlip4 69649

SEA437740

3-9-63

3-10-63

3.11-63 Wilson — a New tank of Chlorine was put on the line over the week end No. 54365 Pumped sludge, washed tanks down, Ran lab, worked on No 1 filter to try and keep it from ponding, cleaned pump out well, pumped sludge before going home.

3-12-63 Wilson — Pumped sludge washed down tanks Ran lab put leaves on part of the lawn, cleaned pump out well, go routine duties, pumped sludge before going home

KCSlip4 69650

SEA437741

3-13-63 Pumped sludge washed down
Wilson tanks Ran lab. got mower
from Roton plant and mowed
the yard cleaned pump wet
well, pumped sludge befor
going home

3-14-63 Pumped sludge washed down
Wilson tanks Ran lab washed
wood work in office
pumped sludge at noon
cleaned pump wet well pumped
sludge befor going home

3-15-63 Pumped sludge washed tanks
Wilson down, Ran lab sink trap
got a hole in it took it off
and took it over to Wilkie
to get a new one also springs
for sludge grinder, cleaned
pump wet well, pumped all quiet
pumped sludge befor going home

3-16-63

3-17-63

KCSlip4 69651

SEA437742

3-18-43 Wilson — Pumped sludge washed down tanks, Ran lab Buckler Malory, Davies and Willis here to look around, cut grass up by the digester Woods repaired sink trap and we put it back on, cleaned pump wet well pumped sludge befor going home,

3-19-43 Wilson — Pumped sludge washed down tanks Ran lab, washed walls in hallway pumped sludge at noon, Windy here to put water meter down in man hole, Meter reading was 2519 Cleaned pump wet well pumped sludge befor going home,

3-20-43 Wilson — Pumped sludge washed tanks down Ran lab pumped sludge at 11:25, mowed the lawn cleaned pump wet well, pumped sludge befor going home

3-21-43 Wilson — Pumped sludge washed down tank ran lab repaired sludge grinder pumped sludge at noon changed chlorine tanks #54365 off #34810 on cleaned pump wet well pumped sludge befor going home

3-18-63 Hilson Pumped sludge washed down tanks, Ran lab Bucklin Malory, Davies and Willis here to look around, cut grass up by the digester Woods repaired sink trap and we put it back on, cleaned pump wet well pumped sludge befor going home,

3-19-63 Hilson Pumped sludge washed down tanks Ran lab, washed walls in hallway pumped sludge at noon, Windy here to put water meter down in man hole, Meter reading was 2519 Cleaned pump wet well pumped sludge befor going home,

3-20-63 Hilson Pumped sludge washed tanks down Ran lab pumped sludge at 11:25, mowed the lawn cleaned pump wet well, pumped sludge befor going home.

3-21-63 Hilson Pumped sludge washed down tank ran lab repaired sludge grinder pumped sludge at noon changed chlorine tanks #54365 off #34810 on cleaned pump wet well pumped sludge befor going home

KCSlip4 69653

SEA437744

3-22-43 Nelson Pumped sludge washed down tanks ran lab, cleaned out one sludge bed to have it ready for sludge. pumping sludge for 3 min. every hr. to see if it will work out better, cleaned pump wet well, Woods came over and we pulled No. 2 pump and took out the rags

3-23-43

3-24-43

3-25-43 Nelson Pumped sludge washed tanks down Ran lab, went over to Renton plant and got Wilky and we pulled No 1 wet well pump and took out the rags, cleaned pump wet well, went to Renton plant and got 5 new teeth for communicator and put them in

KCSlip4 69654

SEA437745

3-26-63 Pumped sludge washed tanks
Hilson down, Ran lab work pump
room down, cleaned pump
wet well pump per sludge every
1½ hrs

3-27-63 Pumped sludge every 1½ hr.
Hilson washed tanks down
Ran lab, flow meter
out of order, had air
line repaired and back in
service. 5 hrs today for sludge
cleaned pump wet well.
went out to Renton plant
and got [illegible] and set Buffalo
No 2 wet well pump and took
out the rags.

3-28-63 Pumped sludge every 1½ hr.
Hilson washed tanks down
Ran lab, took foot valve
off of sump pump was
a piece of string on it
put it back work OK now,
cross prop here and put
a foot disconnect on
no. 1 sump pump, did
not have time to put
one on no. 2 pump.

KCSlip4 69655

SEA437746

3-29-63 Wilson Pumped sludge every 1½ hr
washed down tanks, Ran lot,
cleaned out sump for
sump pump, cleaned screen
on water line to chlorinator
cleaned pump wet well
pulled No 1 and No 2 wet
well pumps and derayed
and put them back.
sump pump lost is prim
stayed till 4:00 to get
it started

3-30-63 Pumped sludge 5 min. 9:00 AM
Wilkinson " " 5 min. 2:00

KCSlip4 69656

SEA437747

April 63

1-4-63 Hilson — Pumped sludge every 1½ hr. washed tank down, Ran lab, pumped sludge from digester to green house bed, went to Renton plant and got the lawn mower and cut the lawn then took mower back cleaned pump wet well. Cross was here and put fast disconnect on No 2 wet well pump

4-2-63 Hilson — Pumped sludge every 1½ hr. washed down tanks, ran lab. Cleaned pump wet well.

4-3-63 Hilson — Pumped sludge every 1½ hr. washed down tank. Ran lab, cleaned pump wet well, went to Renton plant and got tony to help me pull No 1 wet well pump was plugged with rags. Woods came over and we cleaned up the sludge beds, showed tony how to pump sludge and what to check on Saterdays.

KCSlip4 69657

SEA437748

4-4-63 Pumped sludge every 1½ hr.
Hilton washed down tanks Ran lab
changed Chlorine tank & took off
No. 34910 and put on No 54297
pumped sludge from digester
to drying bed in grin house
Cleaned pump wet well

4-5-63 Pumped sludge every 2 hr
washed down tanks Ran lab.
Floor mixer out of order repaired
and back in service. cleaned
pump wet well went to Renton
plant and got Wood's we
pulled both 1 and 2 wet well
pumps and took out rags

4-6-63 Pumped sludge at 10 AM
Tony Pumped sludge at 1 PM

4-7-63

4-8-63 Pumped sludge every 2 hr.
Hilton washed down tanks
Ran lab. cleaned pump
wet well. all routine
duties.

KCSlip4 69658

SEA437749

4-9-63 Wilson	Pumped sludge every 2 hr, washed down tanks Ran lab, cleaned pump wet well, got mower from Renton plant and cut the lawn then took mower back.
4-10-63 Wilson	Pumped sludge every 2 hr, washed tanks down Ran lab, Cleaned pump wet well, repairing lawn where truck run over it,
4-11-63 Wilson	Pumped sludge every 2 hr washed tanks down Ran lab, Cleaned pump wet well and worked in yard,
4-12-63 Wilson	Pumped sludge every 2 hr, washed tanks down Ran lab, Cleaned pump wet well Rain just about all day, cleaning varnish off public floor
SAT. 4-13-63 Wilson	Pumped Sludge AT 10-AM 1-PM

KCSlip4 69659

SEA437750

4-15-63 Pumped sludge every 2 hr,
Kilson washed down tanks,
Ran lab, cleaning off
varnish off office floor,
Cleaned pump wet well,

4-16-63 Pumped sludge every 2 hr,
Kilson washed down tanks,
Ran lab, Cleaned pump wet
well,

4-17-63 Pumped sludge every 2 hr,
Kilson washed down tanks,
Ran lab, Took Chlorine tank
No 56297 off and put on full
tank No. 50299, Put 1 ring
of packing in sump pump,
Cleaned pump wet well,
Cleaned air relay units for
flow meter

4-18-63 Pumped sludge every 2 hr,
Kilson washed tank down,
Ran lab, pumped out scum
pit, got lawn mower from
Renton plant and cut the
lawn then took lawn
mower back cleaned pump
wet well.

KCSlip4 69660

SEA437751

4-19-63 Pumped sludge every 2 hr.,
Wilson washed down tanks
Ran lab, finished trimming
lawn, cleaned pump
wet well, cleaned
filter in chlorinator

SAT.
4-20-63 Pumped Sludge AT 10 AM & 2 PM
Tony

4-21-63

4-22-63 Pumped sludge every 2 hr.,
Wilson washed tanks down
Ran lab, cleaned out
sump pump, sump
cleaned pump wet well
cut the lawn with
hand mower,

4-23-63 Pumped sludge every 2 hr's,
Wilson washed down tanks
Ran lab, Cleaned pump wet
well, and routine duties,
Woods came over from
Renton plant and we
pulled No 1 + No. 2 wet
well pumps and took
out the rags

KCSlip4 69661

SEA437752

4-24-63 Hilson — Pumped sludge every 2 hrs washed down tank Ran lab put weed killer on lawn pumped sludge to green house beds Cleaned pump wet well.

4-25-63 Hilson — Pumped sludge every 2 hrs washed tanks down Ran lab, put Chlorine on No 1 filter cleaned out one sludge bed so I can put more sludge in it, Cleaned pump wet well.

4-26-63 Hilson — Pumped sludge every 2 hr, washed down tank's Ran lab, pumped scum from pit to digester, went to new plant for a look see, Tony came over and we pulled No 1 wet well pump and took out the rags Bill Swanson was here Cleaned pump wet well.

SAT. 4-27-63 Tony — Pumped Sludge at 10 A.M & 2 P.M

4-28-63

KCSlip4 69662

SEA437753

4-29-63 Pumped sludge every 2 hrs
Hilson washed down tanks
Ran lab. cleaned pump
out well went to Renton
plant and got [illegible] for flow
meter chart. Took Chlorine
tank no 50299 off and put
full tank no 43506 on line

4-30-63 Pumped sludge every 2 hrs
Hilson Washed tank's down Ran lab.
cleaned spray arms on bio-
filter Glen was here to work
on sump pump's but did not
have a drill the size he needed.

KCSlip4 69663

SEA437754

May 63

5-1-63 Hilson Pumped sludge every 2 hrs washed down tanks Ran lab. pumped sludge from digester to drying bed. Glen was here and we pulled No 1 + No 2 wet well pumps and put new bolts in plate on bottom of pump's also put air petcock in check valve's, got lawn mower from Renton plant and cut lawn, cleaned pump wet well.

5-2-63 Hilson Pumped sludge every 2 hrs washed tanks down. Ran lab. Flow meter and No 2 wet well pump out off service, air locked, called Boeing plumer's and threshod one pump that was pumping air, 12:00 noon pump and flow meter back in service. changed flow on #1 bio-filter

5-3-63 Pumped sludge every 2 hr.
Kilson washed tanks down Ran lab.
Changed pump wet well
cut labor with hand
Mower 2:45 PM pulled #4
wet well pump to take
out rags
SAT.
5-4-63 Pumped Sludge at
Tony 10 AM - 2 PM

5-5-63

5-6-63 Pumped sludge every 2 hr
Kilson washed tanks down
Ran lab. worked on
flow meter Al Woods
came over and we pulled
#2 wet well pump and
took out rags & cleaned
pump wet well

5

KCSlip4 69665

SEA437756

5-7-63 Pumped sludge every 2 hrs
Wilson Washed tanks down Ran lab,
cleaned pump wet well
Installed new diaphragm
in both air relay units
for flow meter, out of
service at 9:30 AM and back
in service at 1:30 PM flow
meter working good for now

5-8-63 Pumped sludge every 2 hrs
Wilson washed tanks down Ran lab,
cleaned pump wet well, Woods
came over and we pulled
No 2 wet well pump and
took out rags

5-9-63 Pumped sludge every 2 hrs
Wilson washed down tanks, ran lab,
pumped out scum pit, too
digester, got lawn mower
from Renton plant we
mowed the lawn, cleaned
out pump wet well,

5-10-63 Pumped sludge every 2 hr,
Wilson washed down tanks, Ran lab.
put weed-B-gone on the
lawn cleaned pump wet
well

5-11-63 Pumped sludge
Tony at 10 AM & 3 PM

KCSlip4 69666

SEA437757

5-12-63 -

5-13-63 Pumped sludge every 2 hrs
Wilson washed tanks down Raw lab.
cleaned pump wet well
routine duties

5-14-63 Pumped sludge every 2 hrs
Wilson washed tanks down Raw lab
cleaned pump wet well
washed windows.

5-15-63 Pumped sludge every 2 hrs
Wilson washed down tanks Raw lab
cleaned arms on bio-filters
pumped sludge from digester
to drying bed. got mower
from Rayon plant and
cut the lawn cleaned
pump wet well.

5-16-63 Pumped sludge every 2 hrs
Wilson washed down tanks Raw lab.
cleaned pump wet well

5-17-63 Pumped sludge every 2 hrs
Wilson washed tanks down Raw lab.
took off chlorine tank No 43506
put on full tank No 54896
cleaned pump wet well
pulled No 2 wet well pump

KCSlip4 69667

SEA437758

and put in new air screw
in impeller. Went with
Willie to new plant
5-18-63 Pumped Sludge
TONY at 10 AM. & 2 P.M.

5-19-63

5-20-63 Pumped sludge every 2 hrs
Kilson washed tanks down
Ran lab. cleaned water
strainer in chlorinator
cleaned pump out well
pulled No 1 wet well pump
to take out the rags

5-21-63 Pumped sludge every 2 hr,
Kilson washed tanks down
Ran lab, cleaned pump
wet well

5-22-63 Pumped sludge every 2 hrs
washed tanks down Ran lab,
Recond 3 tanks Chlorine No.'s
#54690 #54724 # 55069, sent
back 3 tanks No's 54297 #50299
#43506, pumped out scum
pit, cleaned out pump wet well

KCSlip4 69668

SEA437759

5-23-63 Pumped sludge every 2 hrs
Kilson washed tanks & lawn
Ran lab. Got manure
from Renton plant and
mowed the lawn
Changed pump out well
pulled No. 2 wet well
pump and took out rags

5-24-63 Pumped sludge every 2 hrs
Kilson washed tanks lawn
Ran lab. Cleaned pump
wet well

5-25-63 Pumped sludge at
Tony 10-A.M + 2-P.M.

5-26-63

5-27-63 Pumped sludge every 2 hrs
Kilson washed tanks down
Ran lab. went to Renton
plant and got a lawn
sprinkler. Wendy came
over to help pull No. 2
wet well pump to get
out rags

KCSlip4 69669

SEA437760

5-28-63 Pumped sludge every 2 hrs
Hilson washed tanks down
ran lab. cleaned pump
wet well. Windy came
back today to weld
No 2 wet well pump
impeller to see if it
would help to keep out
rags, got a new lawn
sacker from Willis

5-29-63 Pumped sludge every 2 hrs
Hilson washed down tanks
Ran lab, cleaned pump
wet well, pumped out
scum pit, got sand
from Renton plant and
cut the lawn

5-30-63

5-31-63 Pumped sludge every 2 hrs
Hilson washed down tanks
cleaned pump wet well
helped out at Renton plant

6-1-63
Tony Pumped Sludge at
10 AM & 2 PM

KCSlip4 69670

SEA437761

June 1963

6-1-63

6-2-63

6-3-63 Pumped sludge every 2 hrs
Wilson washed tank down
Ran lab, cleaned pump
wet well and did some
yard work.

6-4-63 pumped sludge every 2 hrs
Wilson washed tank down Ran lab,
cleaned pump wet well
cleaned water filter in
chlorinator

6-5-63 pumped sludge every 2 hrs
Wilson washed tank down Ran lab.
bypassed plant for 1 hr. for
work on pipe line
cleaned pump wet well
cleaned both bio-filtrarms
pumped one bed of sludge
from digester.

6-6-63 Pumped sludge every 2 hrs
Wilson washed tank down
Ran lab, cleaned pump
wet well got mower
from Renton plant and
cut the lawn

KCSlip4 69671

SEA437762

6-7-63 Pumped sludge away 2 hrs
Kilson washed tanks down
Ran lab. went with Scott
to new plant to clean
out wet well. pumped
out scum pit to digesty
cleaned pump out wet well
pulled No. 1 out well
pump to get out sage

6-8-63 Pump sludge at 10AM & 2 PM
Tony

6-10-63 Pumped sludge away 2 hrs
Kilson washed down tanks
Ran lab. got lawn mower
from Renton plant and cut
the lawn cleaned pump
wet well.

6-11-63 Pumped sludge away 2 hrs
Kilson washed tank down
Ran lab, cleaned pump
wet well, trimmed grass
around [illegible] tanks

6-12-63 Pumped sludge away 2 hrs
Kilson washed down tanks
Ran lab, cleaned pump
wet well, Water in hot house
leaking.

KCSlip4 69672

SEA437763

6-13-63 Pumped sludge every 2 hrs
Hilson washed tank down
Ran lab. mowed the lawn
cleaned pump pit well
cleaned bell bio-filter
arms

6-14-63 Pumped sludge every 2 hrs
Hilson washed tanks down
Ran lab cleaned pump
out well, pumped out
scum pit.

6-15-63
Tony Pumped Sludge
at 10AM + 2PM

6-16-63

6-17-63 Pumped sludge every 2 hrs
Hilson washed tanks down
Ran lab. cleaned pump out
well pumped one bed of
sludge from digester
cleaned bio-filter arms

KCSlip4 69673

SEA437764

4-18-63 Pumped sludge every 2 hrs
Wilson washed tanks down.
Ran lab, cleaned pump
wet well, Tony came over
and we pulled No 2 wet
well pump to take out
rags. cut grass around
digester.

4-19-63 Pumped sludge every 2 hrs
Wilson washed tanks down
Ran lab, cleaned pump
wet well, Called Lowry
plumbing shop to repair
valve on their main
steam line.

4-20-63 Pumped sludge every 2 hrs
Wilson washed tanks down
Ran lab, got manure from
Renton plant and mowed
the lawn, cleaned pump
wet well, went with
Wallace to new plant
took Chlorine tank No
54896 off line and put
on No 54690

KCSlip4 69674

SEA437765

6-21-61 Pumped sludge every 2 hrs
Wilson washed down tanks
Ran lab. cleaned pumps
wet well, pumped out
scum pit, cleaned both
bio filter arms

6-22-63 Pumped Sludge at
Tony 10 AM & 2 PM

6-23-63

6-24-63 Pumped sludge every 2 hrs
Wilson washed tanks down
Ran lab. Wendy was here
at 8:00 AM and pulled out
No 1 wet well pump and
took it to town for
repair, cleaned pump
wet well.

6-25-63 Pumped sludge every 2 hrs
Wilson Washed tanks down
Ran lab, got mower from
Renton plant and mowed
the lawn, cleaned pump
wet well.

KCSlip4 69675

SEA437766

6-26-63 Pumped sludge every 2 hrs
Wilson washed tanks down.
Ran lab, Wendy came at
8:00 AM to put No 1 unit
well pump back after it
had been repaired. Boeing
electrian brought out 10
bulbs for yard lights, put
in one up on the roof,
cleaned pump out well.

6-27-63 Pumped sludge every 2 hrs
Wilson washed tank down
Ran lab. Woodie came
over and we put 2
bulbs in yard lights
cleaned pump out well.

6-28-63 Pumped sludge every 2 hrs
Wilson washed tanks down
Ran lab, pumped out
scum pit. cleaned
bio-filter arms cleaned
SAT. pump out well.
6-29-63 Pump [illegible]
Tony 10 AM & 2 PM

KCSlip4 69676

SEA437767

July

7-1-63 Wilson — Pumped sludge every 2 hrs washed tank down Ran lab repaired float in water tank on roof cleaned pump wet well got mower from Renton plant and mowed the lawn. Woods came over and we pulled No 1 wet well pump to derag.

7-2-63 Wilson — Pumped sludge every 2 hrs washed tank down Ran lab. pumped digested sludge to drying bed's put new diaphragm in air relay unit for flow meter cleaned pump wet well.

7-3-63 Wilson — Pumped sludge every 2 hrs washed tank's down Ran lab mowed part of the lawn cleaned pump wet well. greased all equipment, cleaned water filters in chlorinator

7-4-63 W. Woods — Electricity was off at 7:10 A.M. called Jim Hart Electrician at Boeings he told me he called Wed to Renton Plant about change over I changed to Vault 13 Pumped Sludge 10 AM + 2 PM

7-5-63 Pumped sludge every 2 hrs
washed tanks down
Raw lab. Changed power
back to vault No 7
cleaned pump wet well
pumped out scum pit

7-6-63 Pumped sludge
every at 10 AM & 3 PM
Sump Pump out order

7-7-63

7-8-63 Pumped sludge every 2 hrs
Rain Washed tank down
Raw lab, got lawn
mower from Renton
plant and cut the lawn
cleaned pump wet well

7-9-63 Pumped sludge every 2 hrs
Clear washed tanks down
Raw lab. cleaned pump
wet well

7-10-63 Pumped sludge every 2 hrs
Clear washed tanks down Raw lab
bypassed plant from 10:00 AM &
11:00 AM for work on big
pipe line, cleaned water filters
in chlorinator, cleaned pump
wet well.

KCSlip4 69678

SEA437769

7-11-63 Pumped sludge every 2 hrs
Wilson washed tanks down
Ran lab. cleaned bio filter
arms Ser. Chlorine tank
No 54896 back and received 1
tank Chlorine No 57801
Cleaned pumps wet well

7-12-63 Pumped sludge every 2 hrs
Wilson washed tanks down
Ran lab. pumped out
scum pit cleaned pumps
wet well cleaned water
filters in chlorinator
went over to Renton
plant to help with
chlorine tanks.

SAT
7-13-63 Pumped Sludge for 30 min.
Tony at 9:30 A M Pumped
Sludge for 15 min. 1:30 P M

SUN
7-14-63 Pumped sludge 9:15 A M 2:15 P M

7-15-63 Pumped sludge washed
tank down checked lift
station at new plant and
sprayed plant helped at
Renton plant cut grass
here.

KCSlip4 69679

SEA437770

7-16-63 Pumped sludge every 2 hrs
Hilson washed tank down
Ran lab, cleaned out
one drying bed in hot
house, pumping Digested
sludge from digester to
drying bed, cleaned two
filter arms cleaned pump
wet well,

7-17-63 Pumped sludge every 2 hrs
Hilson washed tanks down
Ran lab, cleaned pump
wet well cleaned water
filter in chlorinator,

7-18-63 Pumped sludge every 2 hrs
Hilson washed tank's down
Ran lab. went with Tony
to new plant to wash down
wet well and start pump
1:30 PM went with Willis
to new plant and pump station
cleaned pump wet well,

7-19-63 Pumped sludge every 2 hrs
Hilson washed tank down. Ran lab
went to Renton plant and
help Tony put on B.O.D. test
got mower and cut lawn
cleaned water filters in
chlorinator pumped out scum
pit cleaned pump wet well

7-20-63
Tony Pumped Sludge
at 10 AM and 2 PM

7-21-63 Pumped Sludge 9:30 AM + 2:15 PM

7-22-63
Wilson Pumped sludge every 2 hrs
washed tanks down
Ran Lab. cleaned pump
wet well worked on No. 1
bio-filter for ponding.

7-23-63
Wilson Pumped sludge every 2 hrs
washed tanks down
Ran Lab. went with Willie
to new pump station
working up rock in No. 1
bio-filter to keep it from
ponding cleaned pump
wet well

7-24-63
Wilson Pumped sludge every 2 hrs
washed tanks down
went to Renton plant
and helped run BOD test.
Ran lab hrs, cleaned
pump wet well.

7-

KCSlip4 69681

SEA437772

7-25-63 Pumped sludge, washed
Wilson down tanks went to
Renton plant and pumped
sludge thru to Skyway
and skimmed and washed
down plant, cut lawn
lawn here then back
to Renton plant to
pump sludge back at 3:15 P.M.

7-26-63 Pumped sludge washed down
Wilson tanks went with Wilson
to Cascade Girls to look
at that plant, pumped
out scum pit Ran Lab,
changed chlorine tanks

7-27-63 Pumped Sludge
Jones at 10 AM & 2 PM

7-28-63 Pumped Sludge 9:15 AM + 2 PM
al

7-29-63 Pumped Sludge every 2 hrs
Wilson washed tank down Ran lab,
Kirby + Glen were here and
took out No. 2 wet well pump
to repair shaft and bearing
cleaned pump wet well.

KCSlip4 69682

SEA437773

7-30-63 Pumped sludge every 2 hrs
Wilson washed down tank's, Ran lab.
Wendy and Glen have to
put No 2 wet well pump
back after repairing
cleaned bio-filter arms
cleaned pump wet well.

7-31-63 Pumped sludge every 2 hrs
Wilson washed down tank's
Ran lab, cleaned pump
wet well cleaned out 1 sludge
bed.

7-

KCSlip4 69683

SEA437774

August 1963

8-1-63 Pumped sludge every 2 hrs
Hilson washed down tanks
Ran lab. cleaned water
filters in chlorinator
Cleaned pump wet well.

8-2-63 Was at Seattle for state
Hilson test till 2:30 P.M.
At pumped sludge at 8:00
10:30 & 2:10 got hose at
2:30 cleaned pump wet
well checked pump. and
pump sludge at 3:15

8-3-63 Pumped Sludge
Tony at 10 AM & 3 PM

8-4-63

8/5/63 Pumped sludge every 2 hrs
Hilson washed tanks down
Run lab, pumped digested
sludge to drying bed.
got mower from Renton
plant and cut the lawn
cleaned pump wet well

KCSlip4 69684

SEA437775

8-6-63 Pumped sludge every 2 hrs
Wilson washed tanks down
Ran lab, took Chlorine
tank No. 5677 4 up to Cascade
Vista plant, cleaned out
pumps wet well, gassed
all equipment

8-7-63 Pumped sludge checked
Wilson out plant then went
to Renton plant to work
back at 10:30 pumped sludge
and ran lab. back to Renton
plant at 12:00 to pump sludge
went to the way plant
at 12:30 and washed plant down
back to Renton at 1:45 back
here at 2:45 cleaned pumps
wet well & pumped sludge

8-8-63 Pumped sludge every 2 hrs
Wilson washed down tanks
Ran lab. cleaned bio-filter
spray arms cleaned pump
wet well. cleaned water
filters in chlorinator

8-9-63 Pumped sludge every 2 hrs
Wilson washed down plant Ran lab.
pumped out scum pit
got mower from Renton &
cut the lawn, cleaned out
pump wet well

KCSlip4 69685

SEA437776

8-10-63

8-11-63

8-12-63 Pumped sludge at 7:30 A.M.
Hilson then went to Cascade Vista
plant 4 fuses where blown
on motors, tape on float
was off, then went to
pump station to start
pumps got back at 11:30
A.M. then at 1:00 PM went with
Willis back to Cascade Vista
back at 2:15 then to Skyway
plant to check it back here
at 2:55 PM

8-13-63 Pumped sludge washed tank
Hilson down cleaned bio filter spray
arms Ran lab, cleaned
pump wet well. went over
to Bran Myer to see how
that plant is run and
help Scott, back at 2:30 P.M.
changed Chlorine tank, took
off tank no 57801 and put
on tank no. 55069

8-14-63 Pumped sludge washed down
Klein tanks Ran lab, got mower
from Renton plant and
mowing the lawn
changed pump just will
went with Willie to new
plant to start No 1 pump

8-15-63 Pumped Sludge 3 times
Tony Washed Tanks down

8-16-63 Pumped Sludge and
Tony Washed Tanks

8-17-63 Pumped Sludge
Tony

8-18-63

19-63 Pumped sludge washed
Klein down plant went to
cascade plant then to
new lift station back at
11:00 AM ran lab. 1 P.M
went to Highway plant
and new lift Station and
Cascade plant back at
7:35 P.M. pumped Sludge
behind of the plant
Scales was broken when
they took out Point

KCSlip4 69687

SEA437778

9-20-63 Pumped sludge washed
Hilson tanks down cleaned bio-
filter spray arms Ran
lab. Wendy was here to
weld part back on scales
that was broken off,
got mower from Renton
plant an mowed the lawn
pumped out scum pit
cleaned pump wet well.

9-21-63 Pumped sludge every 2 hrs
Hilson washed down tanks
Ran lab. cleaned bio-filter
spray arms, worked on
rock in No 1 bio filter to
keep from ponding cleaned
pump wet well

9-22-63 Pumped sludge went with
Al to Cascade plant, pump
Station and Skyway Bob here
while I was gone, picking
up samples for B.O.D.
Ran lab. cleaned pump
wet well, pulled No 2
wet well pump to derag.
Received 2 tank chlorine,
No 45613 No 47797

KCSlip4 69688

SEA437779

8-23-63 Hilson	Pumped Sludge went to Renton plant to set B.O.D. test, washed down tanks Ran lab. greased all equipment Cleaned pump wet well went with Al to pump station and Cascade plant
8-24-63 Tony	Pumped Sludge at 10 A.M. + 2 P.M.
8-26-63 Bob	Pumped sludge every Two hr., hosed down clarifiers
8-27-63 [illegible]	Pumped sludge every Two hr, washed and brushed down clarifiers.

8-28-63 Pumped sludge every 6 hrs
Wilson washed down tank Ran lab.
cleaned spray arm in both
bio filters. got mower from
Renton and mowed the lawn
cleaned water filters in
chlorinator cleaned pump wet
well.

8-29-63 Pumped sludge every 2 hrs

8-31-63 Pumped Sludge
Tony twice a day

KCSlip4 69690

SEA437781

September 57

9-1-63

9-2-63 Pumped sludge at 8:00 AM + washed down tanks, back at 1 P.M. checked plant and pumped sludge. back at 3:00 checked plant and pumped sludge.
Hilson

9-3-63 Pumped sludge every 2 hrs. washed down tank, Ran lab. got mower from Kenton plant and cut lawn. pulled No 1 wet well pump and dragged tony helped. cleaned pump wet well. steam pipe to digester leaks reported it to Willis
Hilson

9-4-63 Pumped sludge every 2 hrs washed down plant, Ran lab. pumped out scum pit cleaned spray arms in both bio fillers cleaned pump wet well. tony came over and we put a bulb in yard light.
Hilson

9-5-63 Pumped Sludge every 2 hrs
Wilson washed down tanks Ran
lab. Windy here at 8 AM
to repair steam pipe to
digester, cleaned pump wet
well pumped 4000 gal
digested Sludge to drying
bed.

9-6-63 Pumped sludge every 2 hrs
Wilson washed tanks down
Ran lab. went to Renton
plant to see if Willis needed
me to work there, cleaned
pump wet well

9-7-63 Pumped Sludge twice
[illegible]

[illegible]

Pumped sludge, then went
to Renton plant, then to
Cascade plant then to pump
station to Renton plant
then to Skyway plant
back here at 11:45 AM back
to Renton plant at 12:20 PM
back here at 2:45 PM pumped
sludge and cleaned pump
wet well.

9-10-63 Hilson — Pumped sludge every two hrs; Washed down tanks Ran lab, cut lawn washed down pump room cleaned pump wet well.

9-11-63 Hilson — Pumped sludge washed tank down went to Dryn Mawr plant to pick up Chuck to take him to Renton plant to run test, & was there to all day, hue at 11:30 AM & 3:00 PM to pump sludge

9-12-63 Hilson — Pumped sludge washed down tanks then to Renton plant to run more tests back hue at 11:30 AM and 3:00 PM to pump sludge

9-13-63 Hilson — Pumped sludge washed tanks down Ran lab. back to Renton plant to run more tests.

9-14-63 Tony — Pump sludge at 10 AM & 2 PM

9-16-63 Pumped sludge washed down tanks went to Renton plant at 9:00 AM then to Cascade and new pump station back here at 11:30 AM to pump sludge then back to Renton plant Put on new tank Chlorine No. 47797

9-17-63 Pumped sludge Washed down tanks Ran lab. Went with Tony to Cascade Skyway and pump station got mower from Renton plant and mowed the lawn, cleaned pump wet well.

9-18-63 Pumped sludge washed down tanks Ran lab put 5 teeth in communator went to safety program at Milo

9-19-63 Pumped sludge washed down tanks Ran lab, cleaned bio filter spray arms cleaned pump wet well, greased all equipt, 11:00 AM gone on Vacation back the 1st of Oct. Why?

9-20-63 pumped sludge, washed down plant
ran lab test, helped Tony & Al at
Cascade, ground sludge for Metro eng.

9-21-63 Pumped Sludge at 10 AM & 2 PM

9-23-63 Pumped Sludge. ran lab tests.
checked Plant. al

9-24-63 Pumped sludge washed down Tanks
al checked Plant.

9-25-63 Pumped sludge. washed down Tanks
al checked Plant.
cleaned + Pumped out scum Pit.

9-26-63 Pumped sludge. washed down Tanks
al

9-27-63 Pumped sludge washed down Tanks
al cleaned Bia filter spray armes

9-28-63 Pumped Sludge at
10 AM + 2 PM

9-30-63 Pumped sludge, washed Tanks
al checked Plant.

KCSlip4 69695

SEA437786

10-7-63 Al. + Tony	Pumped Sludge 8:AM. 11:AM 1:PM + 3 PM. changed chlorine Tank checked Plant
10-8-63 Al	Pumped Sludge 8:AM 11:AM 1:PM + 3:PM checked Plant
10-9-63 Wilson	Pumped sludge went with Al to Cascade, back here at 10:30 Al washed down tank & ran lab and cleaned pump wet well & went to WPC. meeting in the P.M.
10-10-63 Wilson	Pumped sludge went with Al to Cascade and pump station got mower from Renton and mowed the lawn cleaned bio filter spray arms cleaned pump wet well
10-11-63 Wilson	Pumped sludge pumped out scum pit washed down tanks went with Al. to Cascade and Skyway. Ran lab. cleaned out pump wet well. cleaned water filters in chlorinator
10-12-63	Pump Sludge at 10 A.M. + 2 PM

KCSlip4 69696

SEA437787

10-14-63 Hilson — Pumped sludge washed down plant, went with Al. to Cascade plant + pump station back here and Ran lab, cleaned pump wet well, Al came over and we cleaned out on sludge bed,

10-15-63 Routine Duties — Kn

10-16-63 Routine Duties — Kn

10-17-63 Routine Duties — Kn

10-18-63 Routine Duties — Kn

10-19-63 Pumped Sludge at 10AM + 2PM

10-20-63

10-21-63 Hilson — Pumped sludge at 7:30 A.M. 11:00 AM 1:30 PM 3:15 PM Worked at Renton Plant

10-22-63 Hilson — Pumped sludge at 7:30 AM 10:30 AM pulled No 2 wet well pump for repair Pumped sludge at 12:30 PM + 3:00 P.M.

KCSlip4 69697

SEA437788

10-23-63 Pumped sludge at 7:30 AM
Kilson 11:00 AM & 12:00 and 3:00 P.M.

10-24-63 Maintenance men
Kilson hurry to pull back No 2 wet well pump after repairing new lower bearing and repaired shaft.

10-25-63 Pumped sludge. Worked at
Kilson Cascade and new pump station No 2 wet well pump not working have to get Mundy again.

10-26-63 Pumped sludge 8:45 AM & 1:45 PM
al cleaned no 1 wet well pump. Ajusted shaft on no 2 wet well pump. Pumping OK now.

10-27-63

10-28-63 Pumped sludge washed down
Kilson tanks Ran lab. went to Cascade skyway and pump station got two tanks Chlorine no - 43853 and 57550 cleaned pump wet well.

KCSlip4 69698

SEA437789

10-29-63 Pumped sludge washed
Nelson down tanks went to
Cascade and pump station
worked at Renton plant

10-30-63 Pumped sludge washed
Nelson tanks down went to
pump station and Skyway
First old in P.M.

KCSlip4 69699

SEA437790

11-1-63 Pumped sludge washed
Hilson down tank - worked at
Renton Cascade & pump
station - Skyway plants

11-2-63 Pumped sludge 8:45 AM &
AC 1:15 PM.

11-3-63

11-4-63 Pumped sludge washed
Hilson down tanks went to
Cascade pump station
and Skyway Ran lab.

11-5-63 Pumped sludge washed
Hilson down, tanks, pumped
out scum pit Ran lab,
cut grass worked on
filter at Renton
plant cleaned out pump
wet well

11-6-63 Pumped sludge washed
Hilson tanks down Ran lab.
Cleaned pump wet well
First aid in P.M.

11-13-63 Hilson	Pumped Sludge washed down tanks went to cascade + pump station + Skyway deraged pump pump first aid class in P.M.
11-14-63 Hilson	Pumped Sludge went to first aid in A.M. P.M. went to pump station and Skyway + washed down tanks
11-15-63 Hilson	Pumped Sludge washed down tanks went to cascade pump station and Skyway Run lab. worked in new spray field at cascade in A.M.
11-16-63 Tony	Pumped Sludge at 10 AM and 2 PM
11-17-63	
11-18-63 Hilson	Pumped Sludge washed down tanks went to pump station and Cascade to work on new spray field cleaned pump out well

KCSlip4 69701

SEA437792

11-19-63 Pumped sludge washed down
Hilson tanks went to Cascade,
pump station & Skyway
Ran lab, started to draw
sludge from digester to
drying bed. Cleaned pump
well,

11-20-63 Pumped sludge washed down
Hilson tanks went to Cascade
Pump station and
Skyway, First aid in PM

11-21-63 Pumped sludge work in
Hilson spray field at Cascade
all day,

11-22-63 Pumped sludge washed tanks
Hilson down went to Cascade, pump
station and Skyway
Ran lab. Cleaned pump
wet well.

11-23-63 Pumped Sludge
11-24-63 at 10AM + 3PM

11-25-63 Pumped sludge washed
Hilson down tanks cleaned pump
wet well, worked at Cascade
pump station and Skyway

KCSlip4 69702

SEA437793

11-26-63 Wilson	Pumped sludge washed down tanks went to Cascade and pump Station, ran lab, changed pump unit well, went to Skyway and pump Station Pulled No 2 unit well pump to drag.
11-27-63 Wilson	Pumped sludge washed down plant went to Cascade, pump station + Skyway ~~worked on lawn~~ Cleaned pump unit well got word from Boeing that power on Vault 13 will be off now week end left note to come,
11-28-63 Wilson	Pumped sludge 10:00 AM 2:00 PM worked at Renton
11-29-63 Wilson	Pumped sludge 8:00 AM, 2:00 + 3:PM worked at Renton Cascade + Skyway
11-30-63	Pumped sludge at 10 AM + 2 PM

December 1963

12-1-63

12-2-63 Pumped sludge washed down
Kilson tanks went to Cascade, pump
Station and Skyway
went to Seattle for Chlorine
at 12:30 PM.

12-3-63 Pumped sludge washed tanks
Kilson down Ran lab. cleaned
pump wet well, Wendy
was here and took out
the Chlorinator, checked it [illegible]

12-4-63 Pumped sludge washed down
Kilson tanks Ran lab. Wendy here
to get book on Chlorinator
Cleaned pump wet well, Went
to Kirkland with Wendy to
set up Chlorinator.

12-5-63 Pumped Sludge washed down
Kilson tanks, pumped out scum pit
Ran lab. washed down bio filter
arms Cleaned pump wet well
went to Skyway and pump
Station

12-6-63 Pumped sludge washed down tanks
Ran lab. greased all equipt. Cleaned
pump wet well. went to Cascade
and Skyway

KCSlip4 69704

SEA437795

12-7-63 Tony	Pumped sludge at 10 AM + 2 PM
12-8-63	
12-9-63 Wilson	Pumped sludge washed down tanks Ran lab, cleaned pump out well, + mowed the lawn
12-10-63 Wilson	Pumped sludge washed down tanks, Ran lab, cleaned pump out well, went to Cassopolis to work in spray field in afternoon.
12-11-63 Wilson	Pumped sludge washed down tanks, Ran lab, cleaned pump out well, went to Cassad to work on spray fields
12-12-63 Wilson	Pumped sludge washed down tanks, Ran lab Cleaned pump out well, pumped out scum pit.
12-13-63 Wilson	Pumped sludge washed down tanks, Ran lab. cleaned bio filter arms, went to pump station to clean bar screen, Cleaned pump out well
12-14-63	Pumped Sludge at 10 AM + 2 PM

KCSlip4 69705

SEA437796

12-16-63 Kilson	Pumped sludge, washed down tanks went to Renton plant to work on filter, then to Cascade and pump station then back here, Ran lab.	12 7A
12-17-63 Kilson	Pumped sludge washed down tanks went to Cascade to work on spray fields, cleaned pump wet well here, Ran lab. went to pumpstation and skyway,	12 7A
12-18-63 Kilson	Pumped sludge washed down tanks Ran lab. Reported to Willis that bearing in mixer on digester is bad, Cleaned pump wet well.	12. 7A 12 7A
8-63 Kilson	Pumped sludge washed down plant Ran lab cleaned iron filter arms, cleaned pump wet well, pumped out ~~[illegible]~~ pit	12 7.
12-20-63 Kilson	Pumped sludge, washed down tanks, went to Cascade to clean pump wet well. Ran lab. cleaned pump wet well pulled no. 2 wet wet well pump to drying,	1
12-21-63 Tony	Pumped Sludge at 10 AM + 2 PM	

KCSlip4 69706

SEA437797

12-23-63 Hilson	Pumped Sludge washed down tanks, Ran lab. went to Cascade, pump station and Skyway. Routine duties.
12-24-63 Hilson	Sump pump running when I got here at 7:00 AM was air locked, Pump Sludge, washed down tanks, Ran lab, went to Cascade + pump Station + Skyway, cleaned pump wet well.
12-25-63 Hilson	Worked at Preston plant pumped sludge here 3 times
12-26-63 Hilson	Pumped sludge washed down tanks went to Cascade, pump station + Skyway Ran lab, cleaned pump wet well.
12-27-63 Hilson	Pumped sludge washed down tanks Ran lab, went to Cascade + pump station and Skyway, cleaned pump wet well.
12-28-63	Pumped Sludge at 9:30 AM + 2 PM

12-30-43 Pumped sludge washed
Wilson down tanks Ran lab.
Cleaned pump met mill

KCSlip4 69708

SEA437799

1964

KCSlip4 69709

SEA437800