F4 Over Head Door Sill



F5 Control Joint Detail

Notes

Saw Cut Joints:
- Wet-Cut Saw - Between 4 to 12 hours after finish
- Soff-Cut Saw™ - Between 1 to 4 hours after finish



F6 Anchor Bolt Detail



STIRRUP HOOKS
(Tie Bends Similar)

BAR SIZE	d	D	90° A	90° B	135° A	135° B	135° H*
#3	3/8"	1½"	4"	2¼"	4"	2¼"	2½"
#4	1/2"	2"	4½"	3"	4½"	3"	3"
#5	5/8"	2½"	6"	3¾"	5½"	3¾"	3¾"
#6	3/4"	4½"	1'-0"	9"	8"	9"	4½"
#7	7/8"	5¼"	1'-2"	10½"	9"	10½"	5¼"
#8	1"	6"	1'-4"	12"	10½"	12"	6"



RECOMMENDED END HOOKS							
BAR SIZE	d	D	180° HOOKS A	180° HOOKS B	180° HOOKS J	90° HOOKS A	90° HOOKS B
#3	3/8"	2¼"	5"	2½"	3"	6"	4½"
#4	1/2"	3"	6"	2½"	4"	8"	6"
#5	5/8"	3¾"	7"	2½"	5"	10"	7½"
#6	3/4"	4½"	8"	3"	6"	1'-0"	9"
#7	7/8"	5¼"	10"	3½"	7"	1'-2"	10½"
#8	1"	6"	11"	4"	8"	1'-4"	12"
#9	1⅛"	9½"	1'-3"	4½"	1 1⅜"	1'-7"	13½"
#10	1¼"	10¾"	1'-5"	5"	1'-1 ¼"	1'-10"	15"
#11	1⅜"	12"	1'-7"	5½"	1'-2 ⅜"	2'-0"	16½"
#14	1⅝"	18¼"	2'-3"	6½"	1'-9 ⅜"	2'-7"	19½"
#18	2¼"	24"	3'-0"	9"	2'-4 ½"	3'-5"	27"

F7 Standard Hook Details



F3 Hairpin Detail



F8 Section At Ramp



F2 Pad Footing Detail



F9 Section At Ramp



F1 Typical Thickened Edge Detail

For Anchor Bolt Location
See Anchor Bolt Layout Plan
Provided By MB Systems
Manufacturer

CALL BEFORE YOU DIG

1-888-258-0808

SALSA Steel Corp.
Foundation Design Service

P.O. Box 396
Chowchilla, California 93610

800-574-9484

WE DO FOUNDATIONS RIGHT!

www.METALBUILDINGFOUNDATIONS.com

Salsa Steel Corp. Assumes No Responsibility Or Liability For The Construction Of Supervision Of The Work Described Within These Drawings And/Or Specifications. Any Omissions Or Discrepancies In, Or Revisions To, The Drawing And/Or Specifications Must Be Brought To The Attention Of Salsa Steel Corp. For Review And Resolution Prior To Proceeding With Construction.

The Ideas, Designs And Arrangements Represented By These Drawings And Specifications Are, And Shall Remain, The Property Of Salsa Steel Corp. No Part Shall Be Copied, Disclosed To Others Or Used In Connection With Any Work Or Project Other Than The Work Specified Herein Without The Express Written Consent Of Salsa Steel Corp.

PROJECT

PEMACO SUPEFUND SITE

Maywood, CA

CLIENT

Sturdi-Quick Prefabricated Structures

324 S. Diamond Bar Blvd., #223
Diamond Bar, CA 91765

SHEET CONTENTS

DETAIL SHEET

Drawn By: L. Lozano

Checked By: S. Thomson

DATE

8/11/2006

REVISED:

NO.	DATE	BY
1		
2		
3		

JOB NO.

SS-02797

SHEET NO.

SA-2

OF SHEETS