From:	Wetmore, Cynthia
To:	Jolish, Taly
Subject:	FW: Montrose GW System
Date:	Thursday, April 23, 2015 8:58:03 AM
Attachments:	Montrose TGRS Cost Estimates for Functional Test Water Discharge Options....docx image002.png image001.png

---

Cynthia Wetmore, Technical Support Section
US.EPA, Region IX, Superfund Division
75 Hawthorne Street, San Francisco, 94105
(415)972-3059

From: Wetmore, Cynthia
Sent: Tuesday, February 24, 2015 9:42 AM
To: 'James Wells'
Subject: RE: Montrose GW System

Rough cost estimate – feel free to call to discuss.

Thanks, Cynthia W

Cynthia Wetmore, Technical Support Section
US.EPA, Region IX, Superfund Division
75 Hawthorne Street, San Francisco, 94105
(415)972-3059

From: James Wells [mailto:JWells@everettassociates.net]
Sent: Friday, February 20, 2015 3:54 PM
To: Wetmore, Cynthia
Subject: Montrose GW System

Hi Cynthia,

Can you help me with what's probably a dumb question about operation of the full scale system?

I understand that pCBSA is expected to break-through the liquid GAC fairly quickly (thus LGAC is not expected to reduce pCBSA concentration in reinjection water). Breakthrough occurs when all the sorption sites are filled with pCBSA, so wouldn't there be breakthrough for pesticides and benzene and TCE and other stuff too since all the sites in the GAC are occupied by pCBSA? Or are the sorptive characteristics of the other organics so different that they can still be removed even if pCBSA is breaking through? On a related note: what do we know about pCBSA sorption? Have you folks generated a Koc for this compound?

Thanks,

Jim W

James T. Wells, PhD, PG
L. Everett & Associates, LLC
3700 State Street, Suite 350
Santa Barbara, CA 93105
805-880-9302 (office)
805-570-0267 (mobile)
www.everettassociates.net