17

Attachment 17

Scheduled Maintenance Activities

BUCKEYE CARIBBEAN TERMINALS
MASTER PM LIST REPORT
JD Edwards Program

Equipment Tag	Equipment Description	Service Type	Primary Craft	Frequency
BCTYA	BCT Yabucoa Terminal	Grease Valve	OP	Yearly
BCTYAPSM2	Water Treatment Pumps	Change Oil/Lube	ME	Yearly
BCTYAPSM3	Storm Water Pumps	Change Oil/Lube	ME	Yearly
BCTYAPSM4	Dock Storm Water Pumps	Change Oil/Lube	ME	Yearly
BCTYAOWS1	Oil Water Separator	Separator	OP	Yearly
BCTYATK2OSP	Barge Dock Open Sump Pit	Tanks - 1 Year	OP	Yearly
BCTYATK2OSP	Barge Dock Open Sump Pit	Tank Maintenance	OP	Yearly
BCTYAALSH1OSP	Dock Sump Level Switch	Sump Alarm	EL	Yearly
BCTYAALSH2OSP	Barge Sump Level Switch	Sump Alarm	EL	Yearly
BCTYATK01C	Comp Air Vessel-Wemco TK Farm	OSHA Inspection	SV	Yearly
BCTYAFT5835	Outfall Low Flow Transmitter	Calibration	OP	Yearly
BCTYAFT5805	Outfall High Flow Transmitter	Calibration	OP	Yearly
BCTYAFT5835	Outfall Low Flow Transmitter	Quarterly Check	OP	Quarterly
BCTYAFT5805	Outfall High Flow Transmitter	Quarterly Check	OP	Quarterly

BUCKEYE CARIBBEAN TERMINALS
CONDITION BASE MAINTENANCE

Equipment Tag	Equipment Description	Service Type	Primary Craft	Frequency

WWTA	As Specified on Maintenance Manual Schedule (Excel Format).	Condition Base Corrective Maintenance. Operational checks as a normal operational routine, deficiencies are reported to Maintenance for planning scheduling and excecution.	Multiple	Routine Maintenance Schedule
Ditches	Storm Water Ditches (Outlook Schedule)	Cleanup	Contractor	Semiannual