Massachusetts Department of Environmental Protection
Northeast Regional Office
One Winter Street, Boston, MA 02108

EMERGENCY OR ACCIDENTAL SEWAGE BYPASS OR SEWER OVERFLOW INCIDENT REPORTING

Immediately call DEP at 617-654-6506 or after 5 pm and weekends at 1 (888) 304-1133
DEP NERO Fax: 617-292-5850

Date of this Report: 04/24/18 Time: 0800 A.M. X P.M. ___

Date of Incident: 04/22/18 Time: 1242 A.M. ___ P.M. X

Municipality: City of Lowell Permit Number, if applicable: MA0100633

Facility Name/Location: LOWELL REGIONAL WASTEWATER TREATMENT UTILITY

Name and Title of Person Reporting Incident: Louis Anderson
(Please Print Full Name)

Phone No.: (978) 970 - 4248

Incident Duration: From (Date): 04/22/18 Time: 12 42 A.M. ___ P.M. X
To (Date): 04/23/18 Time: 0030 A.M. X P.M. ___
(Print "ongoing" if applicable)

Estimated Total Flow: _____ gallons

Treatment (please check one): ☐ None ☑ Primary ☑ Disinfection ☑ Screening ☐ Lime
☑ Other treatment: Grit Removal

Name of Receiving Waters, if any: MERRIMACK RIVER to CONCORD RIVER BEAVER BROOK

Cause of incident, please explain: High Flow

Corrective measures taken or to be taken: Secondary Bypass was stopped as soon as possible

Additional information/comments: Report will follow

Person contacted at MA DEP: DAVID FERRIS Date: 04/24/18 Time: 0800

Other Agencies Contacted:
☑ U.S. EPA: 1-800-424-8802 or 1-888-372-7341
Person contacted at U.S. E.P.A.: GEORGE HARDING
☑ MA Marine Fisheries (Coastal Waters Only, as necessary): (978) 465-3553
☐ Local BOH, Person contacted: _____
☐ MWRA (in their service area): (617) 539-4191, Person contacted: _____
☑ Others Contacted: All Downstream Users EPA - Ted L

7/20/04(incidentform 20040720.doc)

Massachusetts Department of Environmental Protection
Northeast Regional Office
One Winter Street, Boston, MA 02108

EMERGENCY OR ACCIDENTAL SEWAGE BYPASS OR SEWER OVERFLOW INCIDENT REPORTING

Immediately call DEP at 617-654-6506 or after 5 pm and weekends at 1 (888) 304-1133
DEP NERO Fax: 617-292-5850

Date of this Report: 04/24/18 Time: 0800 A.M. X P.M. ___

Date of Incident: 04/21/18 Time: 0918 A.M. X P.M. ___

Municipality: City of Lowell Permit Number, if applicable: MA0100633

Facility Name/Location: LOWELL REGIONAL WASTEWATER TREATMENT UTILITY

Name and Title of Person Reporting Incident: Louis Anderson, Head Operator
(Please Print Full Name)

Phone No.: (978) 970 - 4248

Incident Duration: From (Date): 04/21/18 Time: 0918 A.M. X P.M. ___
To (Date): 04/22/18 Time: 0100 A.M. X P.M. ___
(Print "ongoing" if applicable)

Estimated Total Flow: _____ gallons

Treatment (please check one): ☐ None ☑ Primary ☑ Disinfection ☑ Screening ☐ Lime
☑ Other treatment: Grit Removal

Name of Receiving Waters, if any: MERRIMACK RIVER X CONCORD RIVER BEAVER BROOK

Cause of incident, please explain: High Flow

Corrective measures taken or to be taken: Secondary Bypass was stopped as soon as possible

Additional information/comments: Report will follow

Person contacted at MA DEP: DAVID FERRIS Date: 04/24/18 Time: 0800

Other Agencies Contacted:
☑ U.S. EPA: 1-800-424-8802 or 1-888-372-7341
Person contacted at U.S. E.P.A.: GEORGE HARDING
☑ MA Marine Fisheries (Coastal Waters Only, as necessary): (978) 465-3553
☐ Local BOH, Person contacted: _____
☐ MWRA (in their service area): (617) 539-4191, Person contacted: _____
☑ Others Contacted: All Downstream users - EPA - Tech.

Massachusetts Department of Environmental Protection
Northeast Regional Office
One Winter Street, Boston, MA 02108

EMERGENCY OR ACCIDENTAL SEWAGE BYPASS OR SEWER OVERFLOW
INCIDENT REPORTING

Immediately call DEP at 617-654-6506 or after 5 pm and weekends at 1 (888) 304-1133
DEP NERO Fax: 617-292-5850

Date of this Report: 04/24/18 Time: 0800 A.M. X P.M. ___

Date of Incident: 04/20/18 Time: 1025 A.M. X P.M. ___

Municipality: City of Lowell Permit Number, if applicable: MA0100633

Facility Name/Location: LOWELL REGIONAL WASTEWATER TREATMENT UTILITY

Name and Title of Person Reporting Incident: Louis Anderson, Head Operator
(Please Print Full Name)

Phone No.: (978) 970 - 4248

Incident Duration: From (Date): 04/20/18 Time: 1025 A.M. X P.M. ___
To (Date): 04/21/18 Time: 0200 A.M. X P.M. ___
(Print "ongoing" if applicable)

Estimated Total Flow: _____ gallons

Treatment (please check one): ☐ None ☑ Primary ☑ Disinfection ☑ Screening ☐ Lime
☑ Other treatment: Grit Removal

Name of Receiving Waters, if any: MERRIMACK RIVER X CONCORD RIVER BEAVER BROOK

Cause of incident, please explain: High Flow

Corrective measures taken or to be taken: Secondary Bypass was stopped as soon as possible

Additional information/comments: Report will follow

Person contacted at MA DEP: DAVID FERRIS Date: 04/24/18 Time: 0800

Other Agencies Contacted:
☑ U.S. EPA: 1-800-424-8802 or 1-888-372-7341
Person contacted at U.S. E.P.A.: GEORGE HARDING
☑ MA Marine Fisheries (Coastal Waters Only, as necessary): (978) 465-3553
☐ Local BOH, Person contacted: ___
☐ MWRA (in their service area): (617) 539-4191, Person contacted: ___
☑ Others Contacted: All Downstream Users - Spir Tech