DMR Copy of Record

Permit					
Permit #:	**MD0050903**	**Permittee:**	BOONES ESTATE MHC, LLC	**Facility:**	BOONES MOBILE ESTATE WWTP
Major:	No	**Permittee Address:**	2138 ESPEY CT., SUITE 1 CROFTON, MD 21114	**Facility Location:**	1091 MARLBORO ROAD LOTHIAN, MD 20711
Permitted Feature:	001 External Outfall	**Discharge:**	**001-A** 11-DP-0191		
Report Dates & Status					
Monitoring Period:	**From 10/01/18 to 10/31/18**	**DMR Due Date:**	**11/28/18**	**Status:**	**NetDMR Validated**
Considerations for Form Completion					
RESIDUAL CHLORINE LIMITS APPLIES ONLY IF CHLORINE OR CHLORINE COMPOUNDS ARE USED AS DISINFECTING AGENT.					
Principal Executive Officer					
First Name:	Edward	**Title:**	Superintendent	**Telephone:**	410-353-0383
Last Name:	Crooks				
No Data Indicator (NODI)					
Form NODI:	--				

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.8					19 - mg/L		01/01 - Daily	GR - GRAB
					Permit Req.						>=	5 INST MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	1.4	=	1.3	26 - lb/d			=	2.4	=	2	19 - mg/L		01/07 - Weekly	24 - COMP24
					Permit Req.	<=	5.3 MX MO AV	<=	8 MX WK AV	26 - lb/d			<=	8 MX MO AV	<=	12 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.4			=	7.9	12 - SU		01/01 - Daily	GR - GRAB
					Permit Req.						>=	6.5 MINIMUM			<=	8.5 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	3.7	=	5.4	26 - lb/d			=	6.4	=	10	19 - mg/L		01/07 - Weekly	24 - COMP24
					Permit Req.	<=	5.3 MX MO AV	<=	8 MX WK AV	26 - lb/d			<=	8 MX MO AV	<=	12 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	21.9			19 - mg/L		01/30 - Monthly	24 - COMP24
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	24 - COMP24
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	1	--	Sample			=	393.6	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	2	--	Sample			=	4087.2	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon CUM TOTL	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Value NODI															
00605	Nitrogen, organic total [as N]	1 - Effluent Gross	0	--	Sample															
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	24 - COMP24
					Value NODI									B - Below Detection Limit/No Detection						
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample															
					Permit Req.	<=	1.9 MX MO AV	<=	10 MX DA AV	26 - lb/d			<=	2.9 MX MO AV	<=	15 MX DA AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI		B - Below Detection Limit/No Detection		B - Below Detection Limit/No Detection					B - Below Detection Limit/No Detection		B - Below Detection Limit/No Detection				
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample								=	21.9			19 - mg/L		01/30 - Monthly	24 - COMP24
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	24 - COMP24
					Value NODI															

00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample									=	3.2			19 - mg/L		01/30 - Monthly	24 - COMP24
					Permit Req.										Req Mon MO AVG			19 - mg/L		01/30 - Monthly	24 - COMP24
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample			=	57.5	76 - lb/mo										01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo										01/30 - Monthly	CA - CALCTD
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	2	--	Sample			=	456.5	50 - lb/yr										01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon CUM TOTL	50 - lb/yr										01/30 - Monthly	CA - CALCTD
					Value NODI																
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.07	=	0.115	03 - MGD										99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD										99/99 - Continuous	RC - Recorder (auto)
					Value NODI																
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample																
					Permit Req.											<	.1 MAX MUM	19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI												9 - Conditional Monitoring - Not Required This Period				
51040	E. coli	1 - Effluent Gross	0	--	Sample											=	2	30 - MPN/100mL		01/07 - Weekly	GR - GRAB
					Permit Req.											<=	126 MX MO GMN	30 - MPN/100mL		01/07 - Weekly	GR - GRAB
					Value NODI																

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
Boones.PDF	pdf	551609

Report Last Saved By

BOONES ESTATE MHC, LLC

User: [redacted]

Name: Edward Crooks

E-Mail: [redacted]m

Date/Time: 2018-11-28 11:16 (Time Zone: -05:00)

Report Last Signed By

User: [redacted]

Name: Edward Crooks

E-Mail: [redacted]

Date/Time: 2018-11-28 14:30 (Time Zone: -05:00)

Superintendent of record: Ed Crooks
Certification no. 00281

BOONES MOBILE HOME PARK
MONTHLY OPERATING REPORT
Activated Sludge WWTP - Anne Arundel County

OCTOBER 2018		GENERAL					INFLUENT			ACTIVATED SLUDGE PROCESS											FINAL EFFLUENT													
				F°			SU	mg/L	mg/L		mg/L	30 min	mg/L	Inches	Aeration	Blanket		F°	SU		SU	mg/L	mg/L	mg/L	mpn	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	Filter	UV	
init / time	Date	Day	Wx	Temp	Odor	MGD	pH	BOD	SS	Color	D O	Settle	ph	Waste	Level	in feet	Foam	Temp	pH	Appearance	pH	D O	BOD	TSS	E Coli	NH3	NO2+NO3	TKN	ORG N	TN	TP	Running	Cleaned	
	01	MON	CLR	79°	NO	083	7.4			BRN		230	7.2					°		CLR	7.6	8.5										X		UV
	02	TUE	CLR	80°	NO	.061	7.4			BRN		230	7.3				LITE	°		CLR	7.6	8.3	2.0	8.0	ND	ND						X	X	UV
	03	WED	CLR	77°	NO	.061	7.5			BRN		230	7.3	1MIN			LITE	°		CLR	7.6	8.0										X		UV
	04	THU	CLR	75°	NO	.069	8.3			BRN		230	7.2	1MIN			LITE	°		CLR	7.5	8.1										X	X	UV
	05	FRI	CLR	70°	NO	.066	7.6			BRN		240	7.2	6			LITE	°		CLR	7.5	8.0										X		UV
	06	SAT	CLD	72°	NO	.066				BRN		230	7.3				LITE	°		CLR	7.6	8.0										X		UV
	07	SUN	CLD	76°	NO	.072				BRN		240	7.3	6			LITE	°		CLR	7.6	8.0										X		UV
	08	MON	CLD	76°	NO	.068	7.6			BRN		230	7.2	1MIN			MED	°		CLR	7.6	8.0										X	X	UV
	09	TUE	CLD	76°	NO	.067	7.6			BRN		240	7.2	6			MED	°		CLR	7.6	8.1	2.0	4.0	1.0	ND						X		UV
	10	WED	CLD	76°	NO	.058	7.4			BRN		250	7.2	12			MED	°		CLR	7.6	8.0										X		UV
	11	THU	RAIN	78°	NO	.062	7.6			BRN		250	7.2	12			MED	°		CLR	7.5	8.1										X	X	UV
	12	FRI	CLR	60°	NO	.115	8.0			BRN		230	7.1	1MIN			MED	°		CLR	7.4	7.8										X		UV
	13	SAT	CLD	62°	NO	.085				BRN		240	7.3	6			MED	°		CLR	7.7	7.8										X		UV
	14	SUN	CLD	59°	NO	.084				BRN		250	7.5	12			MED	°		CLR	7.7	8.0										X		UV
	15	MON	RAIN	60°	NO	.072	7.5			BRN		250	7.3	12			MED	°		CLR	7.7	8.3										X	X	UV
	16	TUE	CLD	59°	NO	.074	7.4			BRN		260	7.4				MED	°		CLR	7.7	8.1	2.0	2.0	2.1	ND						X		UV
	17	WED	CLR	57°	NO	.062	7.6			BRN		260	7.6				HEAVY	°		CLR	7.9	8.2										X		UV
	18	THU	CLR	51°	NO	.064	7.8			BRN		260	7.5				MED	°		CLR	7.8	8.2										X	X	UV
	19	FRI	CLR	49°	NO	.061	7.9			BRN		260	7.5	24			LITE	°		CLR	7.8	8.1										X		UV
	20	SAT	CLR	59°	NO	.062				BRN		270	7.5	36			LITE	°		CLR	7.7	8.4										X		UV
	21	SUN	CLR	61°	NO	.064				BRN		270	7.3	36			LITE	°		CLR	7.8	8.2										X		UV
	22	MON	CLR	49°	NO	.065	7.7			BRN		240	7.3	12			LITE	°		CLR	7.6	8.1										X	X	UV
	23	TUE	CLR	62°	NO	.060	7.5			BRN		260	7.3	24			LITE	°		CLR	7.6	8.6	ND	10.0	8.5	ND						X		UV
	24	WED	CLR	52°	NO	.060	8.1			BRN		250	7.4	12			LITE	°		CLR	7.7	8.4										X		UV
	25	THU	CLR	46°	NO	.063	7.7			BRN		260	7.3	24			LITE	°		CLR	7.7	8.5										X	X	UV
	26	FRI	CLD	47°	NO	.063	7.8			BRN		250	7.3	18			LITE	°		CLR	7.6	8.6										X		UV
	27	SAT	RAIN	47°	NO	.081				BRN		260	7.3	12			MED	°		CLR	7.6	8.7										X		UV
	28	SUN	CLR	61°	NO	.099				BRN		270	7.4	36			LITE	°		CLR	7.8	8.3										X		UV
	29	MON	CLR	57°	NO	.060	8.7			BRN		240	7.1	12			LITE	°		CLR	7.5	8.5										X	X	UV
	30	TUE	CLR	57°	NO	.073	7.8			BRN		310	7.3	36			LITE	°		CLR	7.6	8.6	6.0	8.0	ND	ND	21.9	ND	ND	21.9	3.20	X		UV
	31	WED	CLR	47°	NO	.055	7.9			BRN		290	7.3	36			MED	°		CLR	7.6	8.7										X		UV
TOTAL						2.155														0	236.8	255.2	12.0	32.0	x	0.0	21.9	0.0	0.0	21.9	3.20		x	
AVERAGE						.070														x	7.6	8.2	2.4	6.4	x	ND	21.9	ND	ND	21.9	3.20		x	
MAXIMUM						.115														x	7.9	8.7	2.0	10.0	x	ND	21.9	ND	ND	21.9	3.20		x	UV
MINIMUM						.055														x	7.4	7.8	x	x	x	x	x		x	x	x		x	

Comments: Per permit, lab results for 30 OCT will be used in NOV max weekly calculations

Chesapeake Labs, Inc. 1000 Butterworth Court Stevensville, MD 21666 (410) 643-8745	Report To:	Water Services, Inc. Ed Crooks 14E Iron Gate Drive Waldorf, MD 20602	Report #:	1810-Boones	Page 1 of 2
			Report Month:	October 2018	
			Plant Name:	Boones Mobile Home Park WWTP	

LABORATORY RESULTS

Collection			BOD mg/L	TSS mg/L	NH_3 mg/L	E. Coli MPN/100 ml
Location	001 Comp., E. Coli Grab	Result	2	8	ND	ND
Date	10/02/18	Date Analyzed	10/03/18	10/03/18	10/08/18	10/02/18
Time	0950 Comp., 0950 Grab	Time Analyzed	0745	0930	1700	1450
By	EC	Analyst	AH/MM	MM	RS	CR
Received	10/02/18, 1310	Qualifiers				

Collection			BOD mg/L	TSS mg/L	NH_3 mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	2	4	ND	1.0
Date	10/09/18	Date Analyzed	10/10/18	10/12/18	10/15/18	10/09/18
Time	0910 Comp., 0910 Grab	Time Analyzed	0745	0800	1300	1240
By	EC	Analyst	MM	MM	RS	CR
Received	10/09/18, 1130	Qualifiers				

Collection			BOD mg/L	TSS mg/L	NH3 mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	2	2	ND	2.1
Date	10/16/18	Date Analyzed	10/17/18	10/19 18	10/19 18	10/16/18
Time	1115 Comp, 1115 Grab	Time Analyzed	0745	1520	1100	1500
By	EC	Analyst	MM	SEH	RS	CR
Received	10/16/18, 1400	Qualifiers				

Collection			BOD mg/L	TSS mg/L	NH_3 mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	ND	10	ND	8.5
Date	10/23/18	Date Analyzed	10/24/18	10/29/18	10/26/18	10/23/18
Time	1245 Comp., 1245 Grab	Time Analyzed	0745	1530	1600	1540
By	EC	Analyst	MM	MM	RS	CR
Received	10/23/18, 1520	Qualifiers				

Collection			BOD mg/L	TSS mg/L	NH_3 mg/L	E. Coli MPN/100 ml	NO3+NO2 mg/L	Organic N mg/L	T. Phos mg/L	Total N mg/L	TKN mg/L
Location	001 Comp, E. Coli Grab	Result	6	8	ND	ND	21.9	ND	3.20	21.9	ND
Date	10/30/18	Date Analyzed	10/31/18	11/02 18	11/02/18	10/30/18	10 31/18	11/02/18	10/31/18	11/02/18	11/02/18
Time	1250 Comp., 1250 Grab	Time Analyzed	0745	0830	1400	1622	1427	1400	1637	1247	1247
By	EC	Analyst	MM/TS	MM	RS	DC	SRB	RS	MM	RS	RS
Received	10/30/18, 1600	Qualifiers									MS

Comments:
Results are valid only when an approval signature has been added to the document

EPA Lab ID: MD00086

Chesapeake Labs, Inc. 1000 Butterworth Court Stevensville, MD 21666 (410) 643-8745	Report To:	Water Services, Inc. Ed Crooks 14E Iron Gate Drive Waldorf, MD 20602	Report #:	1810-Boones	Page 2 of 2
			Report Month:	October 2018	
			Plant Name:	Boones Mobile Home Park WWTP	

LABORATORY RESULTS

Sodium thiosulfate present in E. coli sample prior to testing
ND: Not Detected above the reporting limit

Approved by Laboratory Director,

[redacted] (b) (4)

Methods of Analysis: BOD: SM 5210 B-2011, TSS: SM20 2540D, Total Phosphorus: HACH 8190, Ortho Phosphorus: HACH 8190, Ammonia (NH_3): SM22 4500-NH_3 G, TKN: EPA 351.2, Nitrate-nitrite ($NO_3 + NO_2$): EPA 353.2, SM20 4500-NO_3^- D, E. Coli: Colilert-18 ®
Reporting Limits: BOD: 2 mg/L, TSS: 1 mg/L, Total and Ortho Phosphorus: 0.10 mg/L, Ammonia: 0.5 mg L, TKN: 0.625 mg/L, Nitrate – nitrite: 0.5 mg/L, E. Coli: 1 MPN/100 ml
Qualifiers: MS: matrix spike recovery out of acceptable limits; R: RPD out of acceptable limits; H: sample out of holding time; L: lab fortified blank out of acceptable range; A: sample not acidified to pH <2; T: sample not received at correct temperature; C: see comments

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:
14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	NH3		E. COLI					LAB ID NUMBER
					CONTAINER:			P	P		S					
					PRESERV.:			7	2		7					
10-02	0950	WW	☒	☐	BOONES MHP	3	3°	X	X							
10-02	0950	WW	☐	☒	BOONES MHP	1					X					
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED CROOKS DATE/TIME: See Above RELINQUISHED BY: ED CROOKS DATE/TIME: 10-2-18 1310

RECEIVED BY: DATE/TIME: RELINQUISHED BY: DATE/TIME:

RECEIVED BY: DATE/TIME: RELINQUISHED BY: DATE/TIME:

[redacted] (b) (4) DATE/TIME: 10-02-18 1310

pH: Labeled Preserved Ice: Yes or No

SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES

Temperature: 3.6 Custody Seal: Intact Broken/Missing COOLER #

FOR LAB USE ONLY
Comments:
LAB #
In-house location:
Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:
14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:
REQUESTED COMPLETION DATE: PO#:
PROJECT NAME/STATE:
PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	NH3	~~NO2 NO3, ORG. N, TP, TN~~ T/		E. COLI				LAB ID NUMBER
					CONTAINER:			P	P	P		S				
					PRESERV.:			7	2	2		7				
10 8	0910	WW	☒	☐	BOONES MHP	3	10	X	X	X						
		WW	☐	☒	BOONES MHP	1						X				
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: Ed Crooke	DATE/TIME: See Above	RELINQUISHED BY: Ed Crooke	DATE/TIME: 10-9-18 1130
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:

FOR LAB USE ONLY
Comments:
LAB #
In-house location:
Entered into LIMS:

[redacted] (b) (4)
pH: Labeled Preserved
DATE/TIME: 10-09-18 1130
Ice: Yes or No
SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES
Temperature: 3-6
Custody Seal: Intact Broken/Missing
COOLER #

Please use Black Ink to complete form

© Water Testing Labs of MD, Document Control # WTL-STF-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:

14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	NH3		E. COLI					LAB ID NUMBER
					CONTAINER:			P	P		S					
					PRESERV.:			7	2		7					
10/16	1115	WW	☒	☐	BOONES MHP	3	2°	X	X							
10/16	1115	WW	☐	☒	BOONES MHP	1					X					
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED (Rooks)	DATE/TIME: See Above	RELINQUISHED BY: ED (Rooks	DATE/TIME: 10-16-18 1400
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:

FOR LAB USE ONLY
Comments:
LAB #
In-house location:
Entered into LIMS:

[redacted] (b) (4)
pH: Labeled Preserved
DATE/TIME: 10-16-18 1400
Ice: Yes or No
SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES
Temperature: 3.6
Custody Seal: Intact Broken/Missing
COOLER #

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104

V

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:

14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	NH3		E. COLI					LAB ID NUMBER
CONTAINER:								P	P		S					
PRESERV.:								7	2		7					
10 23	1245	WW	☒	☐	BOONES MHP	3	2°C	X	X							
10·23	1245	WW	☐	☒	BOONES MHP	1					X					
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: EO CROOICS	DATE/TIME: See Above	RELINQUISHED BY: EO CROOICS	DATE/TIME: 10·23·18 1520
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
(b) (4)	DATE/TIME: 10 23 18 1520 Ice: Yes or No	SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES Temperature: 4.0 Custody Seal: Intact Broken/Missing	COOLER #

FOR LAB USE ONLY

Comments:

LAB #

In-house location:

Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:
14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	NH3	NO2-NO3, ORG. N, TP, TN		E. COLI				LAB ID NUMBER
CONTAINER:								P	P	P		S				
PRESERV.:								7	2	2		7				
10:30	1250	WW	☒	☐	BOONES MHP	3	10	X	X	X						
1030	1250	WW	☐	☒	BOONES MHP	1						X				
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED CROOKS DATE/TIME: See Above

RELINQUISHED BY: ED CROOKS DATE/TIME: 10 30 18 1600

RECEIVED BY: DATE/TIME:

RELINQUISHED BY: DATE/TIME:

RECEIVED BY: DATE/TIME:

RELINQUISHED BY: DATE/TIME:

RECEIVED BY LAB: DATE/TIME:

pH: Labeled Preserved Ice: Yes or No

SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES

Temperature: 4.0 Custody Seal: Intact Broken/Missing COOLER #

FOR LAB USE ONLY

Comments:

LAB #

In-house location:

Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104