DMR Copy of Record

Permit					
Permit #:	**MD0050903**	**Permittee:**	BOONES ESTATE MHC, LLC	**Facility:**	BOONES MOBILE ESTATE WWTP
Major:	No	**Permittee Address:**	2138 ESPEY CT., SUITE 1 CROFTON, MD 21114	**Facility Location:**	1091 MARLBORO ROAD ANNE ARUNDEL COUNTY LOTHIAN, MD 20711
Permitted Feature:	001 External Outfall	**Discharge:**	**001-A** 11-DP-0191		
Report Dates & Status					
Monitoring Period:	**From 06/01/18 to 06/30/18**	**DMR Due Date:**	**07/28/18**	**Status:**	**NetDMR Validated**
Considerations for Form Completion					
RESIDUAL CHLORINE LIMITS APPLIES ONLY IF CHLORINE OR CHLORINE COMPOUNDS ARE USED AS DISINFECTING AGENT.					
Principal Executive Officer					
First Name:	Edward	**Title:**	Superintendent	**Telephone:**	410-353-0383
Last Name:	Crooks				
No Data Indicator (NODI)					
Form NODI:	--				

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.8					19 - mg/L		01/01 - Daily	GR - GRAB
					Permit Req.						>=	5 INST MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	1.7	=	4.8	26 - lb/d			=	3	=	7	19 - mg/L		01/07 - Weekly	24 - COMP24
					Permit Req.	<=	5.3 MX MO AV	<=	8 MX WK AV	26 - lb/d			<=	8 MX MO AV	<=	12 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.4			=	7.8	12 - SU		01/01 - Daily	GR - GRAB
					Permit Req.						>=	6.5 MINIMUM			<=	8.5 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	3.3	=	6.8	26 - lb/d			=	5.8	=	10	19 - mg/L		01/07 - Weekly	24 - COMP24
					Permit Req.	<=	5.3 MX MO AV	<=	8 MX WK AV	26 - lb/d			<=	8 MX MO AV	<=	12 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	21.6			19 - mg/L		01/30 - Monthly	24 - COMP24
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	24 - COMP24
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	1	--	Sample			=	369.8	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	2	--	Sample			=	2605.3	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon CUM TOTL	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Value NODI															
00605	Nitrogen, organic total [as N]	1 - Effluent Gross	0	--	Sample															
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	24 - COMP24
					Value NODI									B - Below Detection Limit/No Detection						
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample															
					Permit Req.	<=	1.9 MX MO AV	<=	10 MX DA AV	26 - lb/d			<=	2.9 MX MO AV	<=	15 MX DA AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI		B - Below Detection Limit/No Detection		B - Below Detection Limit/No Detection					B - Below Detection Limit/No Detection		B - Below Detection Limit/No Detection				
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample								=	21.6			19 - mg/L		01/30 - Monthly	24 - COMP24
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	24 - COMP24
					Value															

					NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample									=	3.7			19 - mg/L		01/30 - Monthly	24 - COMP24
					Permit Req.										Req Mon MO AVG			19 - mg/L		01/30 - Monthly	24 - COMP24
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample			=	63.4	76 - lb/mo										01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo										01/30 - Monthly	CA - CALCTD
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	2	--	Sample			=	314.4	50 - lb/yr										01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon CUM TOTL	50 - lb/yr										01/30 - Monthly	CA - CALCTD
					Value NODI																
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.068	=	0.186	03 - MGD										99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD										99/99 - Continuous	RC - Recorder (auto)
					Value NODI																
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample																
					Permit Req.											<	.1 MAX MUM	19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI												9 - Conditional Monitoring - Not Required This Period				
51040	E. coli	1 - Effluent Gross	0	--	Sample											=	3	30 - MPN/100mL		01/07 - Weekly	GR - GRAB
					Permit Req.											<=	126 MX MO GMN	30 - MPN/100mL		01/07 - Weekly	GR - GRAB
					Value NODI																

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
Boones.PDF	pdf	502082

Report Last Saved By

BOONES ESTATE MHC, LLC

User:	[redacted] (b) (6)
Name:	Edward Crooks
E-Mail:	[redacted] (b) (6)
Date/Time:	2018-07-25 13:27 (Time Zone: -04:00)

Report Last Signed By

User:	[redacted] (b) (6)
Name:	Edward Crooks
E-Mail:	[redacted] (b) (6)
Date/Time:	2018-07-25 15:48 (Time Zone: -04:00)

Superintendent of record: Ed Crooks
Certification no. 00281

BOONES MOBILE HOME PARK
MONTHLY OPERATING REPORT
Activated Sludge WWTP - Anne Arundel County

JUNE 2018		GENERAL					INFLUENT			ACTIVATED SLUDGE PROCESS											FINAL EFFLUENT													
				F°			SU	mg/L	mg/L		mg/L	30 min	mg/L	Inches	Aeration	Blanket		F°	SU		SU	mg/L	mg/L	mg/L	mpn	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	Filter	CL2	
init / time	Date	Day	Wx	Temp	Odor	MGD	pH	BOD	SS	Color	D. O.	Settle	ph	Waste	Level	in feet	Foam	Temp	pH	Appearance	pH	D. O.	BOD	TSS	E. Coli	NH3	NO2+NO3	TKN	ORG. N	TN	TP	Running	CTC	Final
	01	FRI	CLD	72°	NO	.064	7.7			BRN		260	7.1	24				°		CLR	7.4	8.8										X		UV
	02	SAT	CLR	80°	NO	.076				BRN		260	7.2	24				°		CLR	7.6	8.9										X		UV
	03	SUN	RAIN	69°	NO	.050				BRN		260	7.3	24				°		CLR	7.5	8.8										X		UV
	04	MON	CLD	59°	NO	186	7.3			BRN		240	7.2					°		CLR	7.5	9.1										X		UV
	05	TUE	CLR	65°	NO	.079	7.6			BRN		240	7.3					°		CLR	7.6	9.3										X		UV
	06	WED	CLD	69°	NO	.068	7.5			BRN		250	7.3	12			LITE	°		CLR	7.6	8.9	7.0	10.0	4.1	ND						X		UV
	07	THU	CLR	69°	NO	.060	7.7			BRN		240	7.3	6			LITE	°		CLR	7.6	8.9										X		UV
	08	FRI	CLR	81°	NO	.066	7.4			BRN		260	7.3	24			LITE	°		CLR	7.6	8.8										X		UV
	09	SAT	RAIN	76°	NO	.067				BRN		240	7.2				LITE	°		CLR	7.5	8.7										X		UV
	10	SUN	CLD	78°	NO	071				BRN		250	7.3				LITE	°		CLR	7.6	8.9										X		UV
	11	MON	RAIN	61°	NO	.059	7.6			BRN		270	7.4	36			LITE	°		CLR	7.7	8.8										X		UV
	12	TUE	CLR	63°	NO	.054	7.6			BRN		270	7.6	30			LITE	°		CLR	7.8	8.9	3.0	7.0	2.0	ND						X		UV
	13	WED	CLR	74°	NO	.065	7.6			BRN		250	7.5	12			LITE	°		CLR	7.7	8.4										X		UV
	14	THU	CLR	75°	NO	.057	8.3			BRN		240	7.2	9			LITE	°		CLR	7.5	8.8										X		UV
	15	FRI	CLR	77°	NO	.066	7.7			BRN		270	7.5	12			LITE	°		CLR	7.7	8.2										X		UV
	16	SAT	CLR	82°	NO	.067				BRN		270	7.5				LITE	°		CLR	7.7	8.4										X		UV
	17	SUN	CLR	84°	NO	.058				BRN		270	7.4				LITE	°		CLR	7.7	8.6										X		UV
	18	MON	CLR	93°	NO	.079	7.7			BRN		290	7.4	18			LITE	°		CLR	7.5	7.8										X		UV
	19	TUE	CLR	79°	NO	.051	7.8			BRN		310	7.5	36			LITE	°		CLR	7.7	8.5	2.0	3.0	9.5	ND						X		UV
	20	WED	CLR	77°	NO	.071	7.7			BRN		300	7.5	39			LITE	°		CLR	7.7	8.5										X		UV
	21	THU	CLR	76°	NO	.066	7.8			BRN		290	7.4	36			LITE	°		CLR	7.6	8.3										X		UV
	22	FRI	RAIN	70°	NO	.069	7.5			BRN		290	7.4				LITE	°		CLR	7.6	8.1										X		UV
	23	SAT	CLD	76°	NO	.069				BRN		290	7.4	36			LITE	°		CLR	7.6	7.9										X		UV
	24	SUN	CLR	84°	NO	.069				BRN		280	7.4	12			LITE	°		CLR	7.6	7.8										X		UV
	25	MON	CLR	75°	NO	.058	7.9			BRN		310	7.3	42			LITE	°		CLR	7.5	8.6										X		UV
	26	TUE	CLR	73°	NO	.066	7.9			BRN		300	7.4	36			LITE	°		CLR	7.6	8.3	ND	3.0	1.0	ND	21.6	ND	ND	21.6	3.70	X		UV
	27	WED	CLD	77°	NO	.060	7.8			BRN		310	7.5	24			LITE	°		CLR	7.7	8.1										X		UV
	28	THU	CLR	80°	NO	.058	8.0			BRN		290	7.4	36			LITE	°		CLR	7.5	8.1										X		UV
	29	FRI	CLR	74°	NO	.057	7.7			BRN		280	7.5	12			LITE	°		CLR	7.7	8.5										X		UV
	30	SAT	CLR	91°	NO	.067				BRN		280	7.4				LITE	°		CLR	7.6	8.1										X		UV
	31			°														°																
TOTAL						2.053														0	x		12.0	23.0	x	0.0	21.6	0.0	0.0	21.6	3.70		x	
AVERAGE						.068														x	x	x	3.0	5.8	x	ND	21.6	ND	ND	21.6	3.70		x	
MAXIMUM						.186														x	7.8	x	7.0	10.0	x	ND	21.6	ND	ND	21.6	3.70		x	UV
MINIMUM						.050														x	7.4	7.8	x	x	x	x	x		x	x	x		x	

Comments: Per permit, lab results for 29 MAY will be used in JUN max weekly calculations.

Chesapeake Labs, Inc. 1000 Butterworth Court Stevensville, MD 21666 (410) 643-8745	Report To:	Water Services, Inc. Ed Crooks 14E Iron Gate Drive Waldorf, MD 20602	Report #: 1806-Boones Report Month: June 2018 Plant Name: Boones Mobile Home Park WWTP

LABORATORY RESULTS

Collection			BOD mg/L	TSS mg/L	NH_3 mg/L	E. Coli MPN/100 ml
Location	001 Comp., E. Coli Grab	Result	7	10	ND	4.1
Date	06/06/18	Date Analyzed	06/06/18	06/08/18	06/08/18	06/06/18
Time	1010 Comp., 1010 Grab	Time Analyzed	1245	1230	1000	1435
By	EC	Analyst	ES	MM	RS	CR
Received	06/06/18, 1230	Qualifiers				

Collection			BOD mg/L	TSS mg/L	NH_3 mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	3	7	ND	2
Date	06/12/18	Date Analyzed	06/13/18	06/13/18	06/18/18	06/12/18
Time	0850 Comp., 0850 Grab	Time Analyzed	0745	1300	1300	1300
By	EC	Analyst	ES	MM	RS	CR
Received	06/12/18, 1230	Qualifiers				

Collection			BOD mg/L	TSS mg/L	NH_3 mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	2	3	ND	9.5
Date	06/19/18	Date Analyzed	06/20/18	06/20/18	06/21/18	06/19/18
Time	1155 Comp., 1155 Grab	Time Analyzed	0745	1000	1200	1545
By	EC	Analyst	ES/AH	MM	RS	CR
Received	06/19/18, 1530	Qualifiers				

Collection			BOD mg/L	TSS mg/L	T. Phos mg/L	NH3 mg/L	NO2+NO3 mg/L	Organic N mg/L	Total N mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	ND	3	3.70	ND	21.6	ND	21.6	1.0
Date	06/26/18	Date Analyzed	06/27/18	06/27/18	06/27/18	07/05/18	06/27/18	07/05/18	06/29/18	06/26/18
Time	1220 Comp., 1220 Grab	Time Analyzed	0745	1300	1530	1000	1131	1000	1008	1610
By	EC	Analyst	ES	MM	ES	RS	SRB	RS	ES	CR
Received	06/26/18, 1610	Qualifiers								

Comments:
Results are valid only when an approval signature has been added to the document
Sodium thiosulfate present in E. coli sample prior to testing
ND: Not Detected above the reporting limit

EPA Lab ID: MD00086
Approved by Laboratory Director,

[redacted]

Methods of Analysis: BOD: SM 5210 B-2011, TSS: SM20 2540D, Total Phosphorus: HACH 8190, Ortho Phosphorus: HACH 8190, Ammonia (NH_3): SM22 4500-NH_3 G, TKN: EPA 351.2, Nitrate-nitrite (NO_3 + NO_2): EPA 353.2, SM20 4500-NO_3 D, E. Coli: Colilert-18 R
Reporting Limits: BOD: 2 mg/L, TSS: 1 mg/L, Total and Ortho Phosphorus: 0.10 mg/L, Ammonia: 0.5 mg/L, TKN: 0.625 mg/L, Nitrate + nitrite: 0.5 mg/L, E. Coli: 1 MPN/100 ml
Qualifiers: MS: matrix spike recovery out of acceptable limits; R: RPD out of acceptable limits; H: sample out of holding time; L: lab fortified blank out of acceptable range; A: sample not acidified to pH < 2; T: sample not received at correct temperature; C: see comments

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:
14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:
REQUESTED COMPLETION DATE: PO#:
PROJECT NAME/STATE:
PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	NH3		E. COLI					LAB ID NUMBER
					CONTAINER:			P	P		S					
					PRESERV.:			7	2		7					
6-6	1010	WW	☒	☐	BOONES MHP	3	4°	X	X							
6-6	1010	WW	☐	☒	BOONES MHP	1					X					
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: (TO CROOKS)	DATE/TIME: See Above	RELINQUISHED BY: (TO CROOKS)	DATE/TIME: 5-6-18 1230
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
[redacted]	DATE/TIME: 6/6/18 1230	SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES	
	Ice: Yes or No	Temperature: 3.7°C	Custody Seal: Intact Broken/Missing COOLER #

FOR LAB USE ONLY
Comments:
LAB #
In-house location:
Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:

14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	NH3		E. COLI					LAB ID NUMBER
					CONTAINER:	P	P		S							
					PRESERV.:	7	2		7							
6 12	0850	WW	☒	☐	BOONES MHP	3	4.3	X	X							
6 12	0850	WW	☐	☒	BOONES MHP	1					X					
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED CROOKS	DATE/TIME: See Above	RELINQUISHED BY: ED CROOKS	DATE/TIME: 6/12/18 1230
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY (b) (4) [redacted]	DATE/TIME: 6/12/18 1230	SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES	
pH: Labeled Preserved ✓	Ice: Yes, or No	Temperature: Custody Seal: Intact Broken/Missing	COOLER #

FOR LAB USE ONLY

Comments:

LAB #

In-house location:

Entered into LIMS:

Please use Black Ink to complete form

Chain of Custody Record

Water Testing Labs of Maryland, inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wilmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:

14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	NH3		E. COLI				
						CONTAINER:		P	P		S				
						PRESERV.:		7	2		7				
6.19	1155	WW	☒	☐	BOONES MHP	3	1.2°	X	X						
6.19	1155	WW	☐	☒	BOONES MHP	1					X				
			☐	☐											
			☐	☐											
			☐	☐											
			☐	☐											
			☐	☐											
			☐	☐											
			☐	☐											

LAB ID NUMBER

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: CO CROOKS	DATE/TIME: See Above	RELINQUISHED BY: CO CROOKS	DATE/TIME: 6.19.18 1530
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY LAB: (b) (4)	DATE/TIME: 6/19/18 1530	SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT OTHER FIELD SERVICES	
pH: Labeled Preserved ✓	Ice: Yes or No	Temperature: 4.0°C	Custody Seal: Intact Broken/Missing COOLER #

FOR LAB USE ONLY

Comments:

LAB #

In-house location:

Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:

14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	NH3 ORG-N TP NO2,NO3 TN		E. COLI					LAB ID NUMBER
					CONTAINER:			P	P		S					
					PRESERV.:			7	2		7					
6·26	1220	WW	☒	☐	BOONES MHP	3	3°	X	X							
6·26	1220	WW	☐	☒	BOONES MHP	1					X					
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: EO CROOD	DATE/TIME: See Above	RELINQUISHED BY: EO CROOD	DATE/TIME: 6·26·18 1610
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:

FOR LAB USE ONLY
Comments:
LAB #

[redacted] (b) (4)
pH: Labeled Received

DATE/TIME: 6/26/18 1610
Ice: Yes or No

SAMPLE SHIPPED VIA:
UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES

Temperature: 4.0 °C
Custody Seal: Intact Broken/Missing
COOLER #

In-house location:
Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104