DMR Copy of Record

Permit					
Permit #:	**MD0024333**	**Permittee:**	MARYLAND MOBILE ESTATES, LLC	**Facility:**	MARYLAND MANOR WWTP
Major:	No	**Permittee Address:**	4922 FAIRMONT AVENUE, SUITE 280 BETHESDA (0811--AA), MD 20814	**Facility Location:**	4600 SANDS ROAD ANNE ARUNDEL COUNTY HARWOOD, MD 20776
Permitted Feature:	001 External Outfall	**Discharge:**	**001-A** 12-DP-0811		
Report Dates & Status					
Monitoring Period:	**From 04/01/17 to 04/30/17**	**DMR Due Date:**	**05/28/17**	**Status:**	**NetDMR Validated**
Considerations for Form Completion					
DISCHARGE SHALL BE LIMITED AT ALL TIMES. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM OTHER THAN TRACE AMOUNT. FLOW USED IN WASTE ALLOCATION CALCULATIONS, NOT TO BE CONSIDERED A LIMITATION.					
Principal Executive Officer					
First Name:	Edward	**Title:**	Superintendent	**Telephone:**	410-353-0383
Last Name:	Crooks				
No Data Indicator (NODI)					
Form NODI:	--				

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	8.1	=	9.2			19 - mg/L		01/01 - Daily	GR - GRAB
					Permit Req.						>=	5 INST MIN	>=	5.5 MO AV MN			19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	1	--	Sample						=	8.9					19 - mg/L		01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MN WK AV					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	1.8	=	2.7	26 - lb/d			=	5	=	7	19 - mg/L		01/07 - Weekly	08 - COMP-8
					Permit Req.	<=	23 MX MO AV	<=	34 MX WK AV	26 - lb/d			<=	30 MX MO AV	<=	45 MX WK AV	19 - mg/L		01/07 - Weekly	08 - COMP-8
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.3			=	8	12 - SU		01/01 - Daily	GR - GRAB
					Permit Req.						>=	6.5 MINIMUM			<=	8 5 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1.8	=	3.5	26 - lb/d			=	5.3	=	9	19 - mg/L		01/07 - Weekly	08 - COMP-8
					Permit Req.	<=	23 MX MO AV	<=	34 MX WK AV	26 - lb/d			<=	30 MX MO AV	<=	45 MX WK AV	19 - mg/L		01/07 - Weekly	08 - COMP-8
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	28.1			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	1	--	Sample			=	296.9	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	2	--	Sample			=	1160.2	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon CUM TOTL	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Value NODI															
00605	Nitrogen, organic total [as N]	1 - Effluent Gross	0	--	Sample															
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI									B - Below Detection Limit/No Detection						
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample															
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI									B - Below Detection Limit/No Detection						
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample								=	28.1			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample								=	2.1			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8

					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample			=	22 2	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	2	--	Sample			=	102.3	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon CUM TOTL	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Value NODI															
04175	Phosphate, ortho [as P]	1 - Effluent Gross	0	--	Sample								=	1.2			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.042	=	0.058	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample															
					Permit Req.										<=	.1 DAILY MX	19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI											B - Below Detection Limit/No Detection				
51040	E. coli	1 - Effluent Gross	0	--	Sample										=	1	30 - MPN/100mL		01/07 - Weekly	GR - GRAB
					Permit Req.										<=	126 MX MO GMN	30 - MPN/100mL		01/07 - Weekly	GR - GRAB
					Value NODI															
82220	Flow, total	1 - Effluent Gross	0	--	Sample			=	1.267	80 - Mgal/mo									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon TOTAL	80 - Mgal/mo									01/30 - Monthly	CA - CALCTD
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
MDManor.PDF	pdf	459510

Report Last Saved By

MARYLAND MOBILE ESTATES, LLC

User: (b) (6) | Date/Time: 2017-05-25 11:00 (Time Zone: -04:00)

Name: Edward Crooks

E-Mail: (b) (6)

Superintendent of record: Edward Crooks
Certification no. 00281
14 E Irongate Drive Waldorf, MD 20602

Maryland Manor WWTP-NPDES # MD-0024333
MONTHLY OPERATING REPORT
Activated Sludge WWTP - Anne Arundel County

APR 2017		GENERAL					INFLUENT			ACTIVATED SLUDGE PROCESS													FINAL EFFLUENT											
				F			SU	mg/L	mg/L		mg/L		mg/L			Blanket		Inches		udge (gallon			SU	mg/L	mg/l	mpn	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	Chlorine p
hit / tim	Date	Day	Wx	Temp	Odor	MGD	pH	BOD	SS	Color	D. O.	Settle	ph	SVI	aeratio n level	in feet	Foam	Waste	Appear ance	waste	hauled		pH	D. O	BOD	E. Coli	TSS	NH3	NO2+NO3	Org N	TN	TP	OP	CTC	Final
	01	SAT	CLD	50	NO	.042				BRN		270	7.0					36	CLR				7.4	9.7											0.0
	02	SUN	CLR	54	NO	.047				BRN		300	6.9					60	CLR				7.3	9.8											0.0
	03	MON	CLR	64	NO	.046	9.1			BRN		320	6.9					60	CLR				7.5	9.8											0.0
	04	TUE	CLD	64	NO	.037	8.9			BRN		300	7.0					60	CLR				7.4	9.1	5.0	ND	4.0	ND	28.1	ND	28.1	2.10	1.20		0.0
	05	WED	CLR	66	NO	.041	8.9			BRN		310	6.9					60	CLR				7.4	9.3											0.0
	06	THU	RAIN	61	NO	.047	9.3			BRN		340	6.9					54	CLR				7.4	9.4											0.0
	07	FRI	RAIN	50	NO	.044	9.2			BRN		360	6.9					60	CLR				7.6	9.7											0.0
	08	SAT	CLR	44	NO	.038				BRN		290	7.0					36	CLR				7.5	9.6											0.0
	09	SUN	CLR	63	NO	.042				BRN		250	7.0						CLR				7.4	9.8											0.0
	10	MON	CLR	59	NO	.040	8.9			BRN		390	6.9					18	CLR				7.6	9.6											0.0
	11	TUE	CLR	84	NO	.044	8.8			BRN			6.9						CLR				8.0	9.8	2.0	1.0	5.0								0.0
	12	WED	CLR	74	NO	.030	8.9			BRN		290	6.9					48	CLR				7.4	9.2											0.0
	13	THU	CLR	53	NO	.031	8.9			BRN		280	6.8					48	CLR				7.7	9.5											0.0
	14	FRI	CLD	55	NO	.040	8.8			BRN		290	6.8					60	CLR				7.5	9.2											0.0
	15	SAT	CLR	70	NO	.053				BRN		300	6.9					60	CLR				7.4	9.4											0.0
	16	SUN	CLR	70	NO	.038				BRN		300	6.9					60	CLR				7.5	8.5											0.0
	17	MON	RAIN	62	NO	.043	7.1			BRN		330	6.6					48	CLR				7.4	8.8											0.0
	18	TUE	CLR	65	NO	.039	8.8			BRN		370	6.7				MED	60	CLR				7.5	8.8											0.0
	19	WED	RAIN	52	NO	.034	9.0			BRN		310	6.8				MED	60	CLR				7.8	9.0	6.0	1.0	3.0								0.0
	20	THU	RAIN	59	NO	.041	9.2			BRN		270	6.8				MED	42	CLR				7.5	8.9											0.0
	21	FRI	RAIN	64	NO	.042	9.0			BRN		270	6.7				MED	42	CLR				7.7	8.6											0.0
	22	SAT	RAIN	56	NO	.042				BRN		250	6.8				MED		CLR				7.6	9.0											0.0
	23	SUN	CLR	50	NO	.058				BRN		350	6.8				MED	60	CLR				7.4	8.9											0.0
	24	MON	RAIN	52	NO	.045	9.1			BRN		390	6.8				MED	60	CLR				7.6	9.0											0.0
	25	TUE	RAIN	57	NO	.052	9.0			BRN		330	6.7				MED	60	CLR				7.3	9.3	7.0	ND	9.0								0.0
	26	WED	RAIN	60	NO	.046	9.2			BRN		270	6.7				MED	36	CLR				7.4	8.9											0.0
	27	THU	CLR	82	NO	.049	9.4			BRN		280	6.8				MED	48	CLR				7.5	9.3											0.0
	28	FRI	CLR	76	NO	.033	9.4			BRN		250	6.7				MED	19	CLR				7.4	9.0											0.0
	29	SAT	CLR	73	NO	.041				BRN		250	6.7				MED		CLR				7.4	8.8											0.0
	30	SUN	CLR	71	NO	.042				BRN		300	6.7				MED	60	CLR				7.4	8.1											0.0
							8.9																												
TOTAL		x	x	x	x	1.267	187.8	x	x	x	x	8810	204.9	x	x	x	x	x	x	x	x		224.9	275.8	20.0	X	21.0	ND	28.1	ND	28.1	2.10	1.20		0.0
AVERAGE		x	x	x	x	042	8.9	#DIV/0!	#####	####	#DIV/0!	304	6.8	###	#DIV/0!	#####	#DIV/0!	51	#DIV/0!	x	x		7.5	9.2	5.0	X	5.3	ND	28.1	ND	28.1	2.10	1.20	x	0.0
MAXIMUM		x	x	x	x	058	9.4	000	000	000	000	390	7.0	000	000	000	000	60	000	x	x		8.0	9.8	7.0	X	9.0	ND	28.1	ND	28.1	2.10	1.20	x	0.0
MINIMUM		x	x	x	x	030	7.1	000	000	000	000	250	6.6	000	000	000	000	18	000	x	x		7.3	8.1	X	X	X	ND	28.1	ND	28.1	2.10	1.20	x	0.0

Comments:

Chesapeake Labs, Inc. 1000 Butterworth Court Stevensville, MD 21666 (410) 643-8745	Report To:	Water Services, Inc. Ed Crooks 14E Iron Gate Drive Waldorf, MD 20602	

Report #:	1704-MD Manor	Page 1 of 1
Report Month:	April 2017	
Plant Name:	Maryland Manor MHP WWTP	

LABORATORY RESULTS

Collection			BOD mg/L	TSS mg/L	Total Phos mg/L	NH3 mg/L	NO2+NO3 mg/L	Organic N mg/L	Total N mg/L	E. Coli MPN/100 ml	Ortho Phos. mg/L
Location	001 Comp, E. Coli Grab	Result	5	4	2.10	ND	28.1	ND	28.1	ND	1.20
Date	04/04/17	Date Analyzed	04/05/17	04/05/17	04/05/17	04/10/17	04/05/17	04/10/17	04/10/17	04/04/17	04/04/17
Time	1355 Comp, 1355 Grab	Time Analyzed	0800	1400	1500	1000	1230	1000	1000	1645	1645
By	EC, Operator	Analyst	ES/AFH	ES	AC	AC	SRB	AC	AC	CR	AC
Received	04/04/17, 1630	Qualifiers									

Collection			BOD mg/L	TSS mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	2	5	1.0
Date	04/11/17	Date Analyzed	04/12/17	04/12/17	04/11/17
Time	1310 Comp, 1310 Grab	Time Analyzed	0800	1030	1550
By	EC, Operator	Analyst	ES/AFH	ES	JG
Received	04/11/17, 1550	Qualifiers			

Collection			BOD mg/L	TSS mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	6	3	1.0
Date	04/19/17	Date Analyzed	04/19/17	04/21/17	04/19/17
Time	1000 Comp, 1000 Grab	Time Analyzed	1300	1400	1415
By	EC	Analyst	ES/AFH	ES	CR
Received	04/19/17, 1245	Qualifiers			

Collection			BOD mg/L	TSS mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	7	9	ND
Date	04/25/17	Date Analyzed	04/26/17	04/28/17	04/25/17
Time	1320 Comp, 1320 Grab	Time Analyzed	0750	0930	1630
By	EC	Analyst	ES/AFH	ES	JG/SB
Received	04/25/17, 1620	Qualifiers			

Comments:

Results are valid only when an approval signature has been added to the document
Sodium thiosulfate present in E. coli sample prior to testing

EPA Lab ID: MD00086
Approved by Laboratory Director,
[redacted] (b) (4)

Methods of Analysis: BOD: SM 5210 B-2011, TSS: SM20 2540D, Total Phosphorus: HACH 8190, Ortho Phosphorus: HACH 8190, Ammonia (NH_3): SM22 4500-NH_3 G, TKN: EPA 351.2, Nitrate-nitrite (NO_3 + NO_2): EPA 353.2, SM20 4500-NO_3 D, E. Coli: Colilert-18 /R/
Reporting Limits: BOD: 2 mg/L, TSS: 1 mg/L, Total and Ortho Phosphorus: 0.10 mg/L, Ammonia: 0.5 mg/L, TKN: 0.625 mg/L, Nitrate + nitrite: 0.5 mg/L, E. Coli: 1 MPN/100 ml
Qualifiers: MS: matrix spike recovery out of acceptable limits; R: RPD out of acceptable limits; H: sample out of holding time; L: lab fortified blank out of acceptable range; A: sample not acidified to pH <2; T: sample not received at correct temperature; C: see comments

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:
14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:
REQUESTED COMPLETION DATE: PO#:
PROJECT NAME/STATE:
PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	TP	NH3, TN, NO2 - NO3, ORG. N	ORTHO P		E. COLI			LAB ID NUMBER
					CONTAINER:			P	P	P	P		S			
					PRESERV.:			7	2	2	7		7			
4-4	1355	WW	☒	☐	MD. MANOR	4	1°	X	X	X	X					
4-4	1355	WW	☐	☒	MD. MANOR	1							X			
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED CROOKS DATE/TIME: See Above RELINQUISHED BY: ED CROOKS DATE/TIME: 4-4-17 1630
RECEIVED BY: DATE/TIME: RELINQUISHED BY: DATE/TIME:
RECEIVED BY: DATE/TIME: RELINQUISHED BY: DATE/TIME:

(b) (4) DATE/TIME: 4/4/17 1630 SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES
pH: Labeled Preserved Ice: Yes or No Temperature: 3.8 Custody Seal: Intact Broken/Missing COOLER #

FOR LAB USE ONLY
Comments:
LAB #
In-house location:
Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:
14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:
REQUESTED COMPLETION DATE: PO#:
PROJECT NAME/STATE:
PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS		E. COLI						LAB ID NUMBER
					CONTAINER:			P		S						
					PRESERV.:			7		7						
4-11	1310	WW	☒	☐	MD. MANOR	2		X								
4-11	1310	WW	☐	☒	MD. MANOR	1				X						
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: FD CROOKD	DATE/TIME: See Above	RELINQUISHED BY: FD CROOKD	DATE/TIME: 4-11-17 1550
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED B[redacted]	DATE/TIME: 4/11/17 1550	SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES	
pH: Labeled/Preserved ✓	Ice: Yes or No	Temperature: 3.9	Custody Seal: Intact Broken/Missing COOLER #

(b) (4)

FOR LAB USE ONLY
Comments:
LAB #
In-house location:
Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park: Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:

14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS		E. COLI						LAB ID NUMBER
						CONTAINER:		P		S						
						PRESERV.:		7		7						
4-19	1200	WW	☒	☐	MD. MANOR	2	2°	X								
4-19	1200	WW	☐	☒	MD. MANOR	1				X						
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED CROOK	DATE/TIME: See Above	RELINQUISHED BY: ED CROOK	DATE/TIME: 4/19/19 1245
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
[redacted] (b) (4)	DATE/TIME: 4/19/19 1245	SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES	
pH: Labels Received	Ice: Yes or No	Temperature: 4.0	Custody Seal: Intact Broken/Missing COOLER #

FOR LAB USE ONLY

Comments:

LAB #

In-house location:

Entered into LIMS:

Please use Black Ink to complete form

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:
14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS		E. COLI						LAB ID NUMBER
CONTAINER:								P		S						
PRESERV.:								7		7						
4/25/17	1320	WW	☒	☐	MD. MANOR	2	3°C	X								
4/25/17	1320	WW	☐	☒	MD. MANOR	1				X						
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED CROOKS DATE/TIME: See Above RELINQUISHED BY: ED CROOKS DATE/TIME: 4-21-17 1620

RECEIVED BY: DATE/TIME: RELINQUISHED BY: DATE/TIME:

RECEIVED BY: DATE/TIME: RELINQUISHED BY: DATE/TIME:

(b) (4) DATE/TIME: 4/25/17 1620 SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES

Ice: Yes or No Temperature: 4°C Custody Seal: Intact Broken/Missing COOLER #

FOR LAB USE ONLY
Comments:
LAB #
In-house location:
Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104