DMR Copy of Record

Permit					
Permit #:	**MD0024333**	**Permittee:**	MARYLAND MOBILE ESTATES, LLC	**Facility:**	MARYLAND MANOR WWTP
Major:	No	**Permittee Address:**	4922 FAIRMONT AVENUE, SUITE 280 BETHESDA (0811--AA), MD 20814	**Facility Location:**	4600 SANDS ROAD ANNE ARUNDEL COUNTY HARWOOD, MD 20776
Permitted Feature:	001 External Outfall	**Discharge:**	**001-A** 12-DP-0811		
Report Dates & Status					
Monitoring Period:	**From 03/01/17 to 03/31/17**	**DMR Due Date:**	**04/28/17**	**Status:**	**NetDMR Validated**
Considerations for Form Completion					
DISCHARGE SHALL BE LIMITED AT ALL TIMES. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM OTHER THAN TRACE AMOUNT. FLOW USED IN WASTE ALLOCATION CALCULATIONS, NOT TO BE CONSIDERED A LIMITATION.					
Principal Executive Officer					
First Name:	Edward	**Title:**	Superintendent	**Telephone:**	410-353-0383
Last Name:	Crooks				
No Data Indicator (NODI)					
Form NODI:	--				

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	**Oxygen, dissolved [DO]**	1 - Effluent Gross	0	--	Sample						=	9.3	=	9.9			19 - mg/L		01/01 - Daily	GR - GRAB
					Permit Req.						>=	5 INST MIN	>=	5.5 MO AV MN			19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00300	**Oxygen, dissolved [DO]**	1 - Effluent Gross	1	--	Sample						=	9.8					19 - mg/L		01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MN WK AV					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00310	**BOD, 5-day, 20 deg. C**	1 - Effluent Gross	0	--	Sample	=	0.9	=	1 3	26 - lb/d			=	2.5	=	3	19 - mg/L		01/07 - Weekly	08 - COMP-8
					Permit Req.	<=	23 MX MO AV	<=	34 MX WK AV	26 - lb/d			<=	30 MX MO AV	<=	45 MX WK AV	19 - mg/L		01/07 - Weekly	08 - COMP-8
					Value NODI															
00400	**pH**	1 - Effluent Gross	0	--	Sample						=	7.2			=	7.6	12 - SU		01/01 - Daily	GR - GRAB
					Permit Req.						>=	6.5 MINIMUM			<=	8.5 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	**Solids, total suspended**	1 - Effluent Gross	0	--	Sample	=	0.9	=	1 3	26 - lb/d			=	2.5	=	3	19 - mg/L		01/07 - Weekly	08 - COMP-8
					Permit Req.	<=	23 MX MO AV	<=	34 MX WK AV	26 - lb/d			<=	30 MX MO AV	<=	45 MX WK AV	19 - mg/L		01/07 - Weekly	08 - COMP-8
					Value NODI															
00600	**Nitrogen, total [as N]**	1 - Effluent Gross	0	--	Sample								=	23.5			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI															
00600	**Nitrogen, total [as N]**	1 - Effluent Gross	1	--	Sample			=	270.1	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Value NODI															
00600	**Nitrogen, total [as N]**	1 - Effluent Gross	2	--	Sample			=	863.3	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon CUM TOTL	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Value NODI															
00605	**Nitrogen, organic total [as N]**	1 - Effluent Gross	0	--	Sample															
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI									B - Below Detection Limit/No Detection						
00610	**Nitrogen, ammonia total [as N]**	1 - Effluent Gross	0	--	Sample															
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value									B - Below Detection Limit/No						

					NODI									Detection						
00630	**Nitrite + Nitrate total [as N]**	1 - Effluent Gross	0	--	Sample								=	23.5			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI															
00665	**Phosphorus, total [as P]**	1 - Effluent Gross	0	--	Sample								=	1.95			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI															
00665	**Phosphorus, total [as P]**	1 - Effluent Gross	1	--	Sample			=	22.4	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo									01/30 - Monthly	CA - CALCTD
					Value NODI															
00665	**Phosphorus, total [as P]**	1 - Effluent Gross	2	--	Sample			=	80.1	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon CUM TOTL	50 - lb/yr									01/30 - Monthly	CA - CALCTD
					Value NODI															
04175	**Phosphate, ortho [as P]**	1 - Effluent Gross	0	--	Sample								=	1.65			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	08 - COMP-8
					Value NODI															
50050	**Flow, in conduit or thru treatment plant**	1 - Effluent Gross	0	--	Sample	=	0.044	=	0 07	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Value NODI															
50060	**Chlorine, total residual**	1 - Effluent Gross	0	--	Sample															
					Permit Req.										<=	.1 DAILY MX	19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI											B - Below Detection Limit/No Detection				
51040	**E. coli**	1 - Effluent Gross	0	--	Sample										=	1	30 - MPN/100mL		01/07 - Weekly	GR - GRAB
					Permit Req.										<=	126 MX MO GMN	30 - MPN/100mL		01/07 - Weekly	GR - GRAB
					Value NODI															
82220	**Flow, total**	1 - Effluent Gross	0	--	Sample			=	1 378	80 - Mgal/mo									01/30 - Monthly	CA - CALCTD
					Permit Req.				Req Mon TOTAL	80 - Mgal/mo									01/30 - Monthly	CA - CALCTD
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
MDManor.PDF	pdf	473392

Report Last Saved By

MARYLAND MOBILE ESTATES, LLC

User: (b) (6)

Name: edward crooks

E-Mail: (b) (6)

Date/Time: 2017-04-28 11:11 (Time Zone: -04:00)

Report Last Signed By

User:

Name:

E-Mail:

Date/Time: (Time Zone:)

Superintendent of record: Edward Crooks
Certification no. 00281
14 E Irongate Drive Waldorf, MD 20602

Maryland Manor WWTP-NPDES # MD-0024333
MONTHLY OPERATING REPORT
Activated Sludge WWTP - Anne Arundel County

MARCH 2017		GENERAL					INFLUENT			ACTIVATED SLUDGE PROCESS													FINAL EFFLUENT											
				F			SU	mg/L	mg/L		mg/L					Blanket		Inches	Appearance	udge (gallon			SU	mg/L	mg/l	mpn	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	Chlorine p	
nit / tim	Date	Day	Wx	Temp	Odor	MGD	pH	BOD	SS	Color	D.O.	Settle	ph	SVI	aeration level	in feet	Foam	Waste		waste	hauled		pH	D.O.	BOD	E. Coli	TSS	NH3	NO2+NO3	Org N	TN	TP	OP	CTC	Final
	01	WED	CLD	70	NO	.040	9.2			BRN		290	6.7					48	CLR				7.5	9.7											0.0
	02	THU	CLR	48	NO	.028	9.3			BRN		280	6.8					48	CLR				7.5	9.9											0.0
	03	FRI	CLR	40	NO	.042	9.1			BRN		300	6.8					60	CLR				7.4	10.1											0.0
	04	SAT	CLR	35	NO	.048				BRN		300	6.9					36	CLR				7.4	10.3											0.0
	05	SUN	CLR	27	NO	.036				BRN		260	7.0					24	CLR				7.5	10.5											0.0
	06	MON	CLD	40	NO	.049	9.0			BRN		330	6.9					60	CLR				7.5	10.3											0.0
	07	TUE	CLD	67	NO	.041	8.9			BRN		310	6.7					60	CLR				7.5	9.6	2.0	ND	2.0								0.0
	08	WED	RAIN	51	NO	.033	9.0			BRN		280	6.8					48	CLR				7.6	9.4											0.0
	09	THU	CLR	62	NO	.039	9.4			BRN		290	6.8					60	CLR				7.3	9.9											0.0
	10	FRI	RAIN	43	NO	.035	9.0			BRN		250	6.9					28	CLR				7.3	9.4											0.0
	11	SAT	CLR	26	NO	.049				BRN		280	6.8					30	CLR				7.3	9.4											0.0
	12	SUN	CLR	26	NO	.047				BRN		300	6.9					36	CLR				7.4	9.7											0.0
	13	MON	CLD	30	NO	.057	9.2			BRN		260	6.9					12	CLR				7.6	10.6											0.0
	14	TUE	SNOW	32	NO	.066	9.0			BRN		320	7.0					48	CLR				7.4	9.9	3.0	2.0	2.0	ND	23.5	ND	23.5	1.95	1.65		0.0
	15	WED	CLD	27	NO	.070	8.8			BRN		320	6.8					60	CLR				7.2	10.2											0.0
	16	THU	CLD	24	NO	.056	9.3			BRN		410	7.1					60	CLR				7.5	10.2											0.0
	17	FRI	CLD	25	NO	.048	9.3			BRN		350	7.0					60	CLR				7.4	10.5											0.0
	18	SAT	RAIN	40	NO	.042				BRN		290	6.9					36	CLR				7.3	9.8											0.0
	19	SUN	CLD	35	NO	.047				BRN		250	6.9					24	CLR				7.5	11.6											0.0
	20	MON	CLR	33	NO	.047	8.9			BRN		280	7.0					48	CLR				7.6	9.9											0.0
	21	TUE	CLD	45	NO	.049	9.1			BRN		290	6.9					60	CLR				7.4	9.4	3.0	ND	3.0								0.0
	22	WED	CLR	45	NO	.038	9.0			BRN		280	7.0					60	CLR				7.5	9.7											0.0
	23	THU	CLR	27	NO	.041	9.0			BRN		260	7.1					36	CLR				7.5	10.0											0.0
	24	FRI	CLD	36	NO	.037	8.8			BRN		240	7.2					10	CLR				7.5	10.1											0.0
	25	SAT	CLR	60	NO	.039				BRN		250	7.2						CLR				7.5	10.0											0.0
	26	SUN	CLR	50	NO	.033				BRN		250	7.1						CLR				7.5	9.3											0.0
	27	MON	RAIN	50	NO	.056	9.0			BRN		320	7.0					60	CLR				7.5	9.8											0.0
	28	TUE	CLD	67	NO	.040	9.2			BRN		300	6.8					60	CLR				7.4	9.8	2.0	ND	3.0								0.0
	29	WED	CLR	60	NO	.044	8.8			BRN		320	6.8					60	CLR				7.5	9.3											0.0
	30	THU	CLD	45	NO	.033	8.9			BRN		310	6.9					60	CLR				7.4	9.6											0.0
	31	FRI	RAIN	49	NO	.048	8.9			BRN		300	6.9					60	CLR				7.6	9.5											0.0
TOTAL		x	x	x	x	1.378	208.1	x	x	x	x	9070	214.5	x	x	x	x	x	x	x	x		231.0	307.4	10.0	X	10.0	ND	23.5	ND	23.5	1.95	1.65		0.0
AVERAGE		x	x	x	x	.044	9.0	#DIV/0!	#####	####	#DIV/0!	293	6.9	###	#DIV/0!	#####	#DIV/0!	47	#DIV/0!	x	x		7.5	9.9	2.5	X	2.5	ND	23.5	ND	23.5	1.95	1.65	x	0.0
MAXIMUM		x	x	x	x	.070	9.4	.000	.000	.000	.000	410	7.2	.000	.000	.000	.000	60	.000	x	x		7.6	11.6	3.0	X	3.0	ND	23.5	ND	23.5	1.95	1.65	x	0.0
MINIMUM		x	x	x	x	.028	8.8	.000	.000	.000	.000	240	6.7	.000	.000	.000	.000	10	.000	x	x		7.2	9.3	X	X	X	ND	23.5	ND	23.5	1.95	1.65	x	0.0

Comments:

Chesapeake Labs, Inc. 1000 Butterworth Court Stevensville, MD 21666 (410) 643-8745	Report To:	Water Services, Inc. Ed Crooks 14E Iron Gate Drive Waldorf, MD 20602	Report #: 1703-MD Manor — Page 1 of 1 Report Month: March 2017 Plant Name: Maryland Manor MHP WWTP

LABORATORY RESULTS

Collection			BOD mg/L	TSS mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	2	2	ND
Date	03/07/17	Date Analyzed	03/08/17	03/08/17	03/07/17
Time	1310 Comp, 1310 Grab	Time Analyzed	0750	1400	1515
By	EC, Operator	Analyst	ES/AFH	ES	CR
Received	03/07/17, 1445	Qualifiers			

Collection			BOD mg/L	TSS mg/L	Total Phos mg/L	NH3 mg/L	NO2+NO3 mg/L	Organic N mg/L	Total N mg/L	E. Coli MPN/100 ml	Ortho Phos. mg/L
Location	001 Comp, E. Coli Grab	Result	3	2	1.95	ND	23.5	ND	23.5	2.0	1.65
Date	03/14/17	Date Analyzed	03/15/17	03/17/17	03/20/17	03/15/17	03/15/17	03/17/17	03/17/17	03/14/17	03/15/17
Time	1415 Comp, 1415 Grab	Time Analyzed	0750	0830	1100	1430	1124	0942	0942	1620	1545
By	EC	Analyst	ES/AFH	ES	AC	AC	SRB	AC	AC	CR	AC
Received	03/14/17, 1620	Qualifiers									

Collection			BOD mg/L	TSS mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	3	3	ND
Date	03/21/17	Date Analyzed	03/22/17	03/22/17	03/21/17
Time	1235 Comp, 1235 Grab	Time Analyzed	0750	1400	1430
By	EC	Analyst	ES/AFH	ES	AH/SB
Received	03/21/17, 1420	Qualifiers			

Collection			BOD mg/L	TSS mg/L	E. Coli MPN/100 ml
Location	001 Comp, E. Coli Grab	Result	2	3	ND
Date	03/28/17	Date Analyzed	03/29/17	03/28/17	03/28/17
Time	1130 Comp, 1130 Grab	Time Analyzed	0750	1430	1450
By	EC	Analyst	ES/AFH	ES	CR
Received	03/28/17, 1430	Qualifiers			

Comments:
Results are valid only when an approval signature has been added to the document
Sodium thiosulfate present in E. coli sample prior to testing

EPA Lab ID: MD00086
Approved by Laboratory Director,
[redacted] (b) (4)

Methods of Analysis: BOD: SM 5210 B-2011, TSS: SM20 2540D, Total Phosphorus: HACH 8190, Ortho Phosphorus: HACH 8190, Ammonia (NH_3): SM22 4500-NH_3 G, TKN: EPA 351.2, Nitrate-nitrite (NO_3 + NO_2): EPA 353.2, SM20 4500-NO_3^- D, E. Coli: Colilert-18
Reporting Limits: BOD: 2 mg/L, TSS: 1 mg/L, Total and Ortho Phosphorus: 0.10 mg/L, Ammonia: 0.5 mg/L, TKN: 0.625 mg/L, Nitrate + nitrite: 0.5 mg/L, E. Coli: 1 MPN/100 ml
Qualifiers: MS: matrix spike recovery out of acceptable limits; R: RPD out of acceptable limits; H: sample out of holding time; L: lab fortified blank out of acceptable range; A: sample not acidified to pH <2; T: sample not received at correct temperature; C: see comments

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:
14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS		E. COLI						LAB ID NUMBER
CONTAINER:								P		S						
PRESERV.:								7		7						
3-7	1310	WW	☒	☐	MD. MANOR	2	2°	X								
3-7	1310	WW	☐	☒	MD. MANOR	1				X						
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED CROOKS	DATE/TIME: See Above	RELINQUISHED BY: ED CROOKS	DATE/TIME: 3-7-17 1445
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
(b) (4)	DATE/TIME: 3/7/17 1445	SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES	
	Ice: Yes or No	Temperature: 4.0	Custody Seal: Intact Broken/Missing COOLER #

FOR LAB USE ONLY
Comments:
LAB #
In-house location:
Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:
14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:
REQUESTED COMPLETION DATE: PO#:
PROJECT NAME/STATE:
PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	TP	NH3, TN, NO2 - NO3, ORG. N	ORTHO P		E. COLI			LAB ID NUMBER
CONTAINER:								P	P	P	P		S			
PRESERV.:								7	2	2	7		7			
3-14	1415	WW	X		MD. MANOR	4	1°	X	X	X	X					
3-14	1415	WW		X	MD. MANOR	1							X			

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED GROOKS	DATE/TIME: See Above	RELINQUISHED BY: ED GROOKS	DATE/TIME: 3-14-17 1620
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:

FOR LAB USE ONLY
Comments:
LAB #
In-house location:
Entered into LIMS:

(b) (4) DATE/TIME: 3/14/17 1620
pH: Labeled Preserved Ice: Yes or No
SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT OTHER FIELD SERVICES
Temperature: 3.7 Custody Seal: Intact Broken/Missing COOLER #

Please use Black Ink to complete form

© Water Testing Labs of MD, Document Control # WTL-STE-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:

14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS	E. COLI	LAB ID NUMBER
CONTAINER:								P	S	
PRESERV.:								7	7	
3 28	1235	WW	☒	☐	MD. MANOR	2	2°	X		
3 28	1235	WW	☐	☒	MD. MANOR	1			X	
			☐	☐						
			☐	☐						
			☐	☐						
			☐	☐						
			☐	☐						
			☐	☐						
			☐	☐						

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED CROCK DATE/TIME: See Above RELINQUISHED BY: ED CROCK DATE/TIME: 3 28 17 1470

RECEIVED BY: DATE/TIME: RELINQUISHED BY: DATE/TIME:

RECEI[redacted] DATE/TIME: RELINQUISHED BY: DATE/TIME:

RECEI[redacted] DATE/TIME: 3/28/17 1470

pH: [redacted] Ice: Yes or No

SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES

Temperature: 4 Custody Seal: Intact Broken/Missing COOLER #

FOR LAB USE ONLY

Comments:

LAB #

In-house location:

Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104

Chain of Custody Record

Water Testing Labs of Maryland, Inc.
Chesapeake Labs, Inc.
1000 Butterworth Court, Thompson Creek Business Park; Stevensville, MD 21666
Phone: 410-643-7711 Fax: 410-643-5034 www.wtlmd.com

CLIENT NAME: WATER SERVICES, INC.

CLIENT ADDRESS/PHONE NUMBER/FAX NUMBER:

14 E. IRONGATE DR.
WALDORF, MD. 20602
301-645-2798 (PHONE)
301-705-5734 (FAX)

ATTENTION: CC:

REQUESTED COMPLETION DATE: PO#:

PROJECT NAME/STATE:

PROJECT #:

ANALYSIS REQUESTED

DATE	TIME	MATRIX CODE *	COMP	GRAB	SAMPLE IDENTIFICATION	# of CONTAINERS	SAMPLE TEMP.	BOD, TSS		E. COLI						LAB ID NUMBER
					CONTAINER:			P		S						
					PRESERV.:			7		7						
3.28	1130	WW	☒	☐	MD. MANOR	2	1°	X								
3.28	1130	WW	☐	☒	MD. MANOR	1				X						
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												
			☐	☐												

CONTAINER TYPE	PRESERVATION
P – PLASTIC	1 – HCl, 4°
A – AMBER GLASS	2 – H_2SO_4, 4°
G – CLEAR GLASS	3 – HNO_3, 4°
V – VOA VIAL	4 – NaOH, 4°
S – STERILE	5 – NaOH/ZnAc, 4°
O – OTHER	6 – $Na_2S_2O_3$, 4°
	7 – 4°
	8 – none

*MATRIX CODES

DW – DRINKING WATER	S – SOIL
WW – WASTE WATER	SL – SLUDGE
GW – GROUND WATER	SD – SOLID
ST – STORM WATER	A – AIR
SW – SURFACE WATER	L – LIQUID
	P – PRODUCT

REMARKS/ADDITIONAL INFORMATION

SAMPLED BY: ED CROOKS	DATE/TIME: See Above	RELINQUISHED BY: ED CROOKS	DATE/TIME: 3.28.17 1430
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED BY:	DATE/TIME:	RELINQUISHED BY:	DATE/TIME:
RECEIVED [redacted] (b) (4)	DATE/TIME: 3/28/17 1430	SAMPLE SHIPPED VIA: UPS FED-EX COURIER CLIENT/OTHER FIELD SERVICES	
pH: L[redacted]	Ice: Yes or No	Temperature: 3.7°C	Custody Seal: Intact Broken/Missing

FOR LAB USE ONLY

Comments:

LAB #

In-house location:

COOLER #

Entered into LIMS:

Please use Black Ink to complete form

© Water Testing Labs of MD; Document Control # WTL-STE-WW-005-1104